


VENTILATION AUDIT REPORT

SCHOOL:	Blairmount Public School (4535)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Campbelltown
LOCAL GOVERNMENT AREA:	Campbelltown

4535 - Blairmount Public School
Site Plan (10143)



1:1,139

Printed: 12-Jun-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0010 - Practical Activities - 1hb - (40.48 SQM)	● Student Space (18)	
B00A - R0011 - Home Base - (59.26 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R0013 - Withdrawal Space - 1hb - (12.66 SQM)	● Student Space (5)	
B00A - R0015 - Home Base - (59.26 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R0018 - Practical Activities - 1hb - (38.2 SQM)	● Student Space (17)	
B00A - R0019 - Home Base - (59.26 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R0022 - Withdrawal Space - 1hb - (12.66 SQM)	● Student Space (5)	
B00A - R0023 - Home Base - (59.26 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R0028 - Movement - (14.13 SQM)	Not Applicable	Circulation or storage space.
B00A - R0029 - Practical Activities - 1hb - (48.51 SQM)	● Student Space (22)	
B00A - R0030 - Home Base - (59.26 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R0032 - Withdrawal Space - 1hb - (12.61 SQM)	● Student Space (5)	
B00A - R0035 - Home Base - (59.26 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R0037 - Movement - (10.64 SQM)	Not Applicable	Circulation or storage space.
B00A - R0039 - Practical Activities - 1hb - (37.74 SQM)	● Student Space (17)	
B00A - R0040 - Home Base - (59.26 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R0043 - Withdrawal Space - 1hb - (13.93 SQM)	● Student Space (6)	
B00A - R0044 - Home Base - (59.26 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R0047 - Staff Room Annexe - (11.66 SQM)	● Office (2)	
B00A - R0048 - Movement - (52.34 SQM)	Not Applicable	Circulation or storage space.
B00A - R0051 - Movement - (33.89 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Reading Area - (234.83 SQM)	● Student Space (108)	
B00B - R0006 - Staff Room Annexe - (11.63 SQM)	● Office (2)	
B00B - R0008 - Home Base - (59.48 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R0010 - Withdrawal Space - 1hb - (14.15 SQM)	● Student Space (6)	
B00B - R0012 - Home Base - (59.48 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R0014 - Practical Activities - 1hb - (42.26 SQM)	● Student Space (19)	
B00B - R0015 - Practical Activities - 1hb - (40.07 SQM)	● Student Space (18)	
B00B - R0018 - Home Base - (59.28 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R0022 - Withdrawal Space - 1hb - (12.65 SQM)	● Student Space (5)	
B00B - R0025 - Home Base - (59.28 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R0027 - Special Programs Room - (43.32 SQM)	● Student Space (20)	
B00B - R0031 - Movement - (108.59 SQM)	Not Applicable	Circulation or storage space.
B00B - R0034 - Practical Activities - 1hb - (42.88 SQM)	● Student Space (19)	
B00B - R0035 - Movement - (19.16 SQM)	Not Applicable	Circulation or storage space.
B00B - R0036 - Home Base - (59 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R0039 - Withdrawal Space - 1hb - (14.11 SQM)	● Student Space (6)	
B00B - R0041 - Home Base - (59 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R0044 - Staff Room Annexe - (11.66 SQM)	● Office (2)	
B00B - R0050 - Movement - (14.49 SQM)	Not Applicable	Circulation or storage space.
B00B - R0059 - Home Base - (58.58 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R0061 - Withdrawal Space - 1hb - (12.59 SQM)	● Student Space (5)	
B00B - R0063 - Home Base - (59.5 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R0065 - Practical Activities - 1hb - (40.74 SQM)	● Student Space (18)	
B00B - R0066 - Movement - (11.94 SQM)	Not Applicable	Circulation or storage space.
B00B - R0067 - Movement - (8.35 SQM)	Not Applicable	Circulation or storage space.
B00B - R0068 - Special Programs Room - (28.96 SQM)	● Student Space (13)	
B00C - R0005 - Movement - (7.36 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R0008 - Movement - (90.67 SQM)	Not Applicable	Circulation or storage space.
B00C - R0009 - Principal - (21.47 SQM)	Office (5)	
B00C - R0010 - Interview - (12.54 SQM)	Office (3)	
B00C - R0011 - Staff Room Annexe - (12.54 SQM)	Office (3)	
B00C - R0012 - Deputy Principal - (12.5 SQM)	Office (3)	
B00C - R0013 - Sick Bay - (12.54 SQM)	Student Space (5)	
B00C - R0015 - Entry Vestibule - (14.82 SQM)	Not Applicable	Circulation or storage space.
B00C - R0016 - Clerical Office - (12.43 SQM)	Office (3)	
B00C - R0017 - Duplicating Workroom - (31.49 SQM)	Office (7)	
B00C - R0021 - Home Base - (59.26 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R0023 - Withdrawal Space - 1hb - (12.71 SQM)	Student Space (5)	
B00C - R0026 - Home Base - (59.34 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R0027 - Practical Activities - 1hb - (32.98 SQM)	Student Space (15)	
B00C - R0032 - Practical Activities - 1hb - (68.58 SQM)	Student Space (31)	
B00C - R0034 - Home Base - (59.4 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R0035 - Withdrawal Space - 1hb - (5.39 SQM)	Student Space (2)	
B00C - R0039 - Home Base - (59.4 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R0040 - Withdrawal Space - 1hb - (12.59 SQM)	Student Space (5)	
B00C - R0042 - Home Base - (59.48 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R0044 - Staff Room Annexe - (12.28 SQM)	Office (3)	
B00C - R0045 - Staff Room - (72.36 SQM)	Office (18)	
B00C - R0053 - Canteen - (46.5 SQM)	Not Applicable	Circulation or storage space.
B00C - R0055 - Movement - (98.82 SQM)	Not Applicable	Circulation or storage space.
B00C - R0059 - Special Programs Room - (40.02 SQM)	Student Space (18)	
B00C - R0060 - Raised Platform - (51.67 SQM)	Not Applicable	Circulation or storage space.
B00C - R0061 - Communal Space - (216.19 SQM)	Student Space (100)	
OS 602 14015 - OS 602 14015 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 19506 - OS 602 19506 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 19698 - OS 602 19698 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	