

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Blaxcell Street Public School (1257)</b>
<b>AMU REGION:</b>	<b>South Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Auburn</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Cumberland</b>



1257 - Blaxcell Street Public School  
Site Plan (10899)



1:1,017

Printed: 07-Jul-2021

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0004 - Clerical Office - (47.16 SQM)	Office (11)	
B00A - R0005 - Special Programs Room - (46.86 SQM)	Student Space (21)	
B00A - R0006 - Home Base - (47.09 SQM) - Teaching Space: 1	Student Space (21)	
B00A - R0008 - Movement - (73.11 SQM)	Not Applicable	Circulation or storage space.
B00A - R0012 - Deputy Principal - (12.91 SQM)	Office (3)	
B00A - R0014 - Deputy Principal - (15.85 SQM)	Office (3)	
B00A - R0015 - Movement - (10.43 SQM)	Not Applicable	Circulation or storage space.
B00A - R0019 - Entry Vestibule - (19.58 SQM)	Not Applicable	Circulation or storage space.
B00A - R0025 - Principal - (16.6 SQM)	Office (4)	
B00A - R0026 - Clerical Office - (18.43 SQM)	Office (4)	
B00A - R0027 - Sick Bay - (6.24 SQM)	Student Space (2)	
B00A - R0028 - Duplicating Workroom - (39.58 SQM)	Office (9)	
B00A - R0031 - Movement - (19.25 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - Home Base - (48.81 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1002 - Home Base - (46.93 SQM) - Teaching Space: 1	Student Space (21)	
B00A - R1003 - Home Base - (46.86 SQM) - Teaching Space: 1	Student Space (21)	
B00A - R1004 - Home Base - (47.51 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1005 - Special Programs Room - (47.87 SQM)	Student Space (22)	
B00A - R1009 - Interview - (12.53 SQM)	Office (3)	
B00A - R1015 - Movement - (100.03 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Movement - (59.35 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Home Base - (49.97 SQM) - Teaching Space: 1	Student Space (23)	
B00B - R0003 - Practical Activities - 1hb - (15.49 SQM)	Student Space (7)	
B00B - R0004 - Practical Activities - 1hb - (15.57 SQM)	Student Space (7)	
B00B - R0005 - Home Base - (49.97 SQM) - Teaching Space: 1	Student Space (23)	
B00B - R0006 - Movement - (59.62 SQM)	Not Applicable	Circulation or storage space.
B00B - R0007 - Home Base - (50.11 SQM) - Teaching Space: 1	Student Space (23)	
B00B - R0008 - Practical Activities - 1hb - (15.74 SQM)	Student Space (7)	
B00B - R0009 - Movement - (95.66 SQM)	Not Applicable	Circulation or storage space.
B00B - R0012 - Practical Activities - 1hb - (15.36 SQM)	Student Space (7)	
B00B - R0013 - Home Base - (50.11 SQM) - Teaching Space: 1	Student Space (23)	
B00B - R1003 - Seminar/Study - (14.84 SQM)	Office (3)	
B00B - R1010 - Movement - (15.15 SQM)	Not Applicable	Circulation or storage space.
B00B - R1013 - Movement - (58.41 SQM)	Not Applicable	Circulation or storage space.
B00B - R1014 - Movement - (8.42 SQM)	Not Applicable	Circulation or storage space.
B00B - R1015 - Reading Area - (256.23 SQM)	Student Space (118)	
B00C - R0001 - Movement - (45.62 SQM)	Not Applicable	Circulation or storage space.
B00C - R0006 - Canteen - (19.22 SQM)	Not Applicable	Circulation or storage space.
B00C - R0009 - Movement - (10.32 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Movement - (102.29 SQM)	Not Applicable	Circulation or storage space.
B00D - R0006 - Home Base - (51.74 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0007 - Home Base - (51.59 SQM) - Teaching Space: 1	Student Space (23)	
B00D - R0014 - Home Base - (51.36 SQM) - Teaching Space: 1	Student Space (23)	
B00D - R0015 - Home Base - (51.03 SQM) - Teaching Space: 1	Student Space (23)	
B00D - R0023 - Staff Room - (138.5 SQM)	Office (34)	
B00D - R0028 - Home Base - (51.18 SQM) - Teaching Space: 1	Student Space (23)	
B00D - R0029 - Home Base - (51.44 SQM) - Teaching Space: 1	Student Space (23)	
B00D - R0036 - Staff Room Annexe - (20.91 SQM)	Office (5)	
B00D - R0038 - Interview - (13.38 SQM)	Office (3)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R0039 - Home Base - (67.03 SQM) - Teaching Space: 1	● Student Space (31)	
B00D - R0040 - Home Base - (70.2 SQM) - Teaching Space: 1	● Student Space (32)	
B00D - R0041 - Movement - (208.11 SQM)	Not Applicable	Circulation or storage space.
B00D - R0042 - Movement - (10.14 SQM)	Not Applicable	Circulation or storage space.
B00D - R0044 - Outdoor Learning Area - (66.42 SQM)	Not Applicable	Circulation or storage space.
B00D - R0045 - Movement - (8 SQM)	Not Applicable	Circulation or storage space.
B00D - R0046 - Raised Platform - (9.18 SQM)	Not Applicable	Circulation or storage space.
B00D - R0047 - Special Programs Room - (17.37 SQM)	● Student Space (8)	
B00E - R0003 - Home Base - (53.43 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R0004 - Movement - (38.35 SQM)	Not Applicable	Circulation or storage space.
B00E - R0005 - Home Base - (53.66 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R0006 - Home Base - (53.51 SQM) - Teaching Space: 1	● Student Space (24)	
B00F - R0004 - Home Base - (53.65 SQM) - Teaching Space: 1	● Student Space (24)	
B00F - R0005 - Home Base - (53.8 SQM) - Teaching Space: 1	● Student Space (24)	
B00F - R0008 - Home Base - (53.5 SQM) - Teaching Space: 1	● Student Space (24)	
B00F - R0009 - Home Base - (53.5 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R0004 - Home Base - (53.44 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R0005 - Home Base - (53.5 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R0006 - Home Base - (53.29 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R0007 - Home Base - (53.51 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R0009 - Movement - (74.44 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Movement - (24.86 SQM)	Not Applicable	Circulation or storage space.
B00H - R0003 - Practical Activities - 1hb - (28.12 SQM)	● Student Space (13)	
B00H - R0004 - Practical Activities - 1hb - (47.91 SQM)	● Student Space (22)	
B00N - R0001 - Communal Space - (204.2 SQM)	● Student Space (94)	
B00N - R0002 - Raised Platform - (51.05 SQM)	Not Applicable	Circulation or storage space.
B00N - R0010 - Canteen - (44.11 SQM)	Not Applicable	Circulation or storage space.
B00N - R0014 - Movement - (46.8 SQM)	Not Applicable	Circulation or storage space.
B00O - R0001 - Practical Activities - 1hb - (18.91 SQM)	● Student Space (8)	
B00O - R0003 - Home Base - (60.83 SQM) - Teaching Space: 1	● Student Space (28)	
B00O - R0004 - Withdrawal Space - 2hb - (11.51 SQM)	● Student Space (5)	
B00O - R0005 - Home Base - (61.02 SQM) - Teaching Space: 1	● Student Space (28)	
B00O - R0007 - Practical Activities - 1hb - (18.26 SQM)	● Student Space (8)	
B00O - R1001 - Practical Activities - 1hb - (19.16 SQM)	● Student Space (8)	
B00O - R1003 - Home Base - (61.11 SQM) - Teaching Space: 1	● Student Space (28)	
B00O - R1004 - Withdrawal Space - 2hb - (11.71 SQM)	● Student Space (5)	
B00O - R1005 - Home Base - (61.1 SQM) - Teaching Space: 1	● Student Space (28)	
B00O - R1007 - Practical Activities - 1hb - (19.16 SQM)	● Student Space (8)	
OS 601 10585 - OS 601 10585 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 11424 - OS 601 11424 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 11495 - OS 601 11495 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 13802 - OS 601 13802 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 15331 - OS 601 15331 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 16196 - OS 601 16196 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 602 10070 - OS 602 10070 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 10971 - OS 602 10971 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 15368 - OS 602 15368 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 603 18199 - OS 603 18199 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	● Student Space (35)	

Entity Location	Audit Condition Classification (Capacity)	Comment
OS 750 15133 - OS 750 15133 - Learning Unit - ESL - (38 SQM)	 Student Space (17)	
OS 751 12303 - OS 751 12303 - Learning Unit - ESL - (76 SQM)	 Student Space (35)	