

VENTILATION AUDIT REPORT

SCHOOL:	Blayney Public School (1260)
AMU REGION:	North Western NSW
STATE ELECTORATE:	Bathurst
LOCAL GOVERNMENT AREA:	Blayney

1260 - Blayney Public School
Site Plan (13209)



1:790

Printed: 14-May-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0003 - Movement - (5.88 SQM)	Not Applicable	Circulation or storage space.
B00A - R0004 - Staff Room Annexe - (11.64 SQM)	Office (2)	
B00A - R0007 - Movement - (11.79 SQM)	Not Applicable	Circulation or storage space.
B00A - R0009 - Staff Room - (62.15 SQM)	Office (15)	
B00A - R0017 - Movement - (8.87 SQM)	Not Applicable	Circulation or storage space.
B00A - R0024 - Raised Platform - (23.83 SQM)	Not Applicable	Circulation or storage space.
B00A - R0030 - Reading Area - (100.02 SQM)	Student Space (46)	
B00A - R0031 - Movement - (18.68 SQM)	Not Applicable	Circulation or storage space.
B00A - R0033 - Movement - (16.78 SQM)	Not Applicable	Circulation or storage space.
B00A - R0034 - Movement - (35.83 SQM)	Not Applicable	Circulation or storage space.
B00A - R0035 - Staff Room - (67.29 SQM)	Office (16)	
B00A - R0036 - Principal - (23.72 SQM)	Office (5)	
B00A - R0037 - Clerical Office/Workroom - (57.43 SQM)	Office (14)	
B00A - R0039 - Movement - (18.81 SQM)	Not Applicable	Circulation or storage space.
B00A - R0041 - Interview - (12.94 SQM)	Office (3)	
B00A - R0044 - Sick Bay - (8.44 SQM)	Student Space (3)	
B00A - R1001 - Reading Area - (108.67 SQM)	Student Space (50)	
B00A - R1004 - Home Base - (47.88 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1005 - Home Base - (47.78 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1006 - Home Base - (48.54 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1008 - Withdrawal Space - 1hb - (29.48 SQM)	Student Space (13)	
B00A - R1009 - Movement - (63.66 SQM)	Not Applicable	Circulation or storage space.
B00A - R1011 - Movement - (6.68 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Home Base - (75.71 SQM) - Teaching Space: 1	Student Space (35)	
B00B - R0006 - Home Base - (53.05 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0008 - Movement - (19.79 SQM)	Not Applicable	Circulation or storage space.
B00B - R0009 - Movement - (17.29 SQM)	Not Applicable	Circulation or storage space.
B00B - R0011 - Home Base - (54.11 SQM) - Teaching Space: 1	Student Space (25)	
B00B - R0014 - Staff Room Annexe - (18.27 SQM)	Office (4)	
B00B - R0019 - Movement - (30.9 SQM)	Not Applicable	Circulation or storage space.
B00B - R0021 - Staff Room Annexe - (15.67 SQM)	Office (3)	
B00B - R0022 - Home Base - (53.79 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0026 - Movement - (5.62 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Home Base - (72.12 SQM) - Teaching Space: 1	Student Space (33)	
B00E - R0004 - Home Base - (64.79 SQM) - Teaching Space: 1	Student Space (30)	
B00E - R0005 - Practical Activities - 1hb - (8.1 SQM)	Student Space (3)	
B00E - R0007 - Movement - (37.92 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Practical Activities - 1hb - (10.68 SQM)	Student Space (4)	
B00F - R0006 - Home Base - (78.8 SQM) - Teaching Space: 1	Student Space (36)	
B00G - R0006 - Movement - (16.56 SQM)	Not Applicable	Circulation or storage space.
B00G - R0008 - Canteen - (49.06 SQM)	Not Applicable	Circulation or storage space.
B00G - R0009 - Canteen - (35.57 SQM)	Not Applicable	Circulation or storage space.
B00G - R0010 - Movement - (10.37 SQM)	Not Applicable	Circulation or storage space.
B00K - R0013 - Raised Platform - (60.21 SQM)	Not Applicable	Circulation or storage space.
B00K - R0014 - Communal Space - (144.38 SQM)	Student Space (66)	
B00K - R0016 - Movement - (13 SQM)	Not Applicable	Circulation or storage space.
B00K - R0018 - Movement - (6.17 SQM)	Not Applicable	Circulation or storage space.
B00L - R0001 - Practical Activities - 1hb - (17.26 SQM)	Student Space (8)	
B00L - R0002 - Home Base - (60.91 SQM) - Teaching Space: 1	Student Space (28)	
B00L - R0003 - Withdrawal Space - 2hb - (16.51 SQM)	Student Space (7)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00L - R0006 - Home Base - (60.91 SQM) - Teaching Space: 1	● Student Space (28)	
B00L - R0007 - Practical Activities - 1hb - (17.26 SQM)	● Student Space (8)	
OS 602 13650 - OS 602 13650 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 603 14437 - OS 603 14437 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	● Student Space (35)	
OS 606 10919 - OS 606 10919 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	