

VENTILATION AUDIT REPORT

SCHOOL:	Bletchington Public School (5265)
AMU REGION:	North Western NSW
STATE ELECTORATE:	Orange
LOCAL GOVERNMENT AREA:	Orange

5265 - Bletchington Public School
Site Plan (12350)























1:1,229

Printed: 03-Aug-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B001 - R0001 - Movement - (77.67 SQM)	Not Applicable	Circulation or storage space.
B001 - R0008 - Interview - (16.15 SQM)	Office (4)	
B001 - R0009 - Home Base - (53.58 SQM) - Teaching Space: 1	Student Space (24)	
B001 - R0010 - Home Base - (53.58 SQM) - Teaching Space: 1	Student Space (24)	
B001 - R0011 - Home Base - (53.57 SQM) - Teaching Space: 1	Student Space (24)	
B001 - R0012 - Home Base - (53.58 SQM) - Teaching Space: 1	Student Space (24)	
B001 - R0013 - Withdrawal Space - 1hb - (16.58 SQM)	Student Space (7)	
B001 - R0014 - Staff Room Annexe - (5.57 SQM)	Office (1)	
B001 - R0016 - Deputy Principal - (12.85 SQM)	Office (3)	
B007 - R0003 - Home Base - (58.05 SQM) - Teaching Space: 1	Student Space (26)	
B007 - R0004 - Home Base - (58.05 SQM) - Teaching Space: 1	Student Space (26)	
B007 - R0011 - Home Base - (58.13 SQM) - Teaching Space: 1	Student Space (26)	
B007 - R0015 - Home Base - (57.65 SQM) - Teaching Space: 1	Student Space (26)	
B007 - R0017 - Movement - (130.08 SQM)	Not Applicable	Circulation or storage space.
B007 - R0019 - Deputy Principal - (12.59 SQM)	Office (3)	
B008 - R0007 - Home Base - (57.88 SQM) - Teaching Space: 1	Student Space (26)	
B008 - R0011 - Home Base - (58.05 SQM) - Teaching Space: 1	Student Space (26)	
B008 - R0012 - Home Base - (57.81 SQM) - Teaching Space: 1	Student Space (26)	
B008 - R0016 - Home Base - (57.82 SQM) - Teaching Space: 1	Student Space (26)	
B008 - R0025 - Movement - (118.03 SQM)	Not Applicable	Circulation or storage space.
B008 - R0026 - Home Base - (69.03 SQM) - Teaching Space: 1	Student Space (32)	
B008 - R0027 - Withdrawal Space - 1hb - (7.44 SQM)	Student Space (3)	
B008 - R0029 - Practical Activities - 1hb - (12.43 SQM)	Student Space (5)	
B008 - R0030 - Home Base - (78.25 SQM) - Teaching Space: 1	Student Space (36)	
B008 - R0032 - Withdrawal Space - 1hb - (7.44 SQM)	Student Space (3)	
B008 - R0034 - Home Base - (75.45 SQM) - Teaching Space: 1	Student Space (35)	
B008 - R0035 - Practical Activities - 1hb - (17.47 SQM)	Student Space (8)	
B008 - R0037 - Deputy Principal - Type 1 - (16.66 SQM)	Office (4)	
B010 - R0002 - Practical Activities - 1hb - (19.4 SQM)	Student Space (9)	
B010 - R0004 - Home Base - (59.19 SQM) - Teaching Space: 1	Student Space (27)	
B010 - R0005 - Withdrawal Space - 2hb - (11.35 SQM)	Student Space (5)	
B010 - R0006 - Home Base - (59.19 SQM) - Teaching Space: 1	Student Space (27)	
B010 - R0008 - Practical Activities - 1hb - (19.41 SQM)	Student Space (9)	
B011 - R0002 - Entry Vestibule - (23.17 SQM)	Not Applicable	Circulation or storage space.
B011 - R0003 - Clerical Office - (43.33 SQM)	Office (10)	
B011 - R0004 - Clerical Office - (25.67 SQM)	Office (6)	
B011 - R0006 - Sick Bay - (8.38 SQM)	Student Space (3)	
B011 - R0008 - Clerical/Printing - (16.41 SQM)	Not Applicable	Circulation or storage space.
B011 - R0011 - Movement - (16.3 SQM)	Not Applicable	Circulation or storage space.
B011 - R0012 - Staff Room - (66 SQM)	Office (16)	
B011 - R0013 - Staff Room Annexe - (27.72 SQM)	Office (6)	
B011 - R0014 - Movement - (17.6 SQM)	Not Applicable	Circulation or storage space.
B011 - R0018 - Movement - (21.11 SQM)	Not Applicable	Circulation or storage space.
B011 - R0019 - Deputy Principal - Type 1 - (13.19 SQM)	Office (3)	
B011 - R0020 - Deputy Principal - Type 1 - (13.19 SQM)	Office (3)	
B011 - R0021 - Principal - (17.15 SQM)	Office (4)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B011 - R0022 - Interview - (13.09 SQM)	 Office (3)	
B012 - R0001 - Reading Area - (229.74 SQM)	 Student Space (106)	
B012 - R0004 - Special Programs Room - Type 2 - (15.93 SQM)	 Student Space (7)	
B012 - R0005 - Special Programs Room - Type 2 - (15.93 SQM)	 Student Space (7)	
B013 - R0001 - Communal Space - (198.39 SQM)	 Student Space (92)	
B013 - R0002 - Movement - (8.91 SQM)	Not Applicable	Circulation or storage space.
B013 - R0003 - Movement - (57.14 SQM)	Not Applicable	Circulation or storage space.
B015 - R0002 - Practical Activities - 1hb - (19.52 SQM)	 Student Space (9)	
B015 - R0003 - Home Base - (59.35 SQM) - Teaching Space: 1	 Student Space (27)	
B015 - R0005 - Withdrawal Space - 2hb - (10.64 SQM)	 Student Space (4)	
B015 - R0006 - Home Base - (59.27 SQM) - Teaching Space: 1	 Student Space (27)	
B015 - R0008 - Practical Activities - 1hb - (19.43 SQM)	 Student Space (9)	
B016 - R0002 - Canteen - (37.35 SQM)	Not Applicable	Circulation or storage space.
OS 601 10844 - OS 601 10844 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 601 13893 - OS 601 13893 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 601 14010 - OS 601 14010 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 601 15708 - OS 601 15708 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 602 10561 - OS 602 10561 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 11423 - OS 602 11423 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 11783 - OS 602 11783 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 603 14557 - OS 603 14557 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	 Student Space (35)	
OS 606 19678 - OS 606 19678 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	
OS 606 19681 - OS 606 19681 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	