

VENTILATION AUDIT REPORT

SCHOOL:	Bligh Park Public School (4585)
AMU REGION:	Western Sydney
STATE ELECTORATE:	Hawkesbury
LOCAL GOVERNMENT AREA:	Hawkesbury

4585 - Bligh Park Public School
Site Plan (12625)



1:1,025

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Entry Vestibule - (15.68 SQM)	Not Applicable	Circulation or storage space.
B00A - R0003 - Duplicating Workroom - (32.64 SQM)	Office (8)	
B00A - R0005 - Principal - (16.96 SQM)	Office (4)	
B00A - R0006 - Interview - (12.69 SQM)	Office (3)	
B00A - R0010 - Staff Room Annexe - (29.78 SQM)	Office (7)	
B00A - R0011 - Staff Room - (57.1 SQM)	Office (14)	
B00A - R0012 - Movement - (48.77 SQM)	Not Applicable	Circulation or storage space.
B00A - R0013 - Interview - (12.98 SQM)	Office (3)	
B00A - R0014 - Interview - (13.13 SQM)	Office (3)	
B00A - R0018 - Sick Bay - (8.65 SQM)	Student Space (4)	
B00A - R0019 - Clerical Office - (17.45 SQM)	Office (4)	
B00B - R0001 - Canteen - (48.46 SQM)	Not Applicable	Circulation or storage space.
B00B - R0010 - Movement - (22.35 SQM)	Not Applicable	Circulation or storage space.
B00C - R0005 - Communal Space - (211.58 SQM)	Student Space (98)	
B00C - R0013 - Movement - (6.2 SQM)	Not Applicable	Circulation or storage space.
B00C - R0014 - Entry Vestibule - (8.12 SQM)	Not Applicable	Circulation or storage space.
B00C - R0015 - Raised Platform - (45.79 SQM)	Not Applicable	Circulation or storage space.
B00C - R0017 - Movement - (6.16 SQM)	Not Applicable	Circulation or storage space.
B00C - R0021 - Movement - (60.34 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Practical Activities - 1hb - (21.09 SQM)	Student Space (9)	
B00D - R0004 - Withdrawal Space - 1hb - (6.18 SQM)	Student Space (2)	
B00D - R0005 - Home Base - (59.78 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0006 - Home Base - (59.47 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0007 - Practical Activities - 1hb - (21.03 SQM)	Student Space (9)	
B00D - R0009 - Withdrawal Space - 1hb - (12.14 SQM)	Student Space (5)	
B00D - R0012 - Practical Activities - 1hb - (21.02 SQM)	Student Space (9)	
B00D - R0013 - Home Base - (59.62 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0014 - Home Base - (59.47 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0015 - Practical Activities - 1hb - (21.08 SQM)	Student Space (9)	
B00D - R0017 - Withdrawal Space - 1hb - (6.3 SQM)	Student Space (2)	
B00E - R0001 - Home Base - (59.39 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0002 - Practical Activities - 1hb - (20.91 SQM)	Student Space (9)	
B00E - R0004 - Withdrawal Space - 1hb - (12.15 SQM)	Student Space (5)	
B00E - R0006 - Practical Activities - 1hb - (21 SQM)	Student Space (9)	
B00E - R0008 - Home Base - (59.24 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0009 - Home Base - (59.08 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0010 - Practical Activities - 1hb - (21.08 SQM)	Student Space (9)	
B00E - R0012 - Withdrawal Space - 1hb - (6.22 SQM)	Student Space (2)	
B00F - R0004 - Movement - (26.23 SQM)	Not Applicable	Circulation or storage space.
B00F - R0005 - Practical Activities - 1hb - (23.05 SQM)	Student Space (10)	
B00F - R0007 - Withdrawal Space - 1hb - (6.22 SQM)	Student Space (2)	
B00F - R0008 - Home Base - (58.86 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R0009 - Home Base - (59.4 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R0010 - Practical Activities - 1hb - (21.07 SQM)	Student Space (9)	
B00F - R0012 - Withdrawal Space - 1hb - (12.14 SQM)	Student Space (5)	
B00F - R0014 - Practical Activities - 1hb - (21.05 SQM)	Student Space (9)	
B00F - R0015 - Home Base - (59.4 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R0017 - Practical Activities - 1hb - (21.11 SQM)	Student Space (9)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00F - R0018 - Home Base - (59.16 SQM) - Teaching Space: 1	● Student Space (27)	
B00F - R0020 - Withdrawal Space - 1hb - (6.31 SQM)	● Student Space (2)	
B00G - R0001 - Practical Activities - 1hb - (21.06 SQM)	● Student Space (9)	
B00G - R0002 - Home Base - (59.46 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R0004 - Withdrawal Space - 1hb - (12.15 SQM)	● Student Space (5)	
B00G - R0007 - Home Base - (59.24 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R0008 - Practical Activities - 1hb - (21.06 SQM)	● Student Space (9)	
B00G - R0009 - Home Base - (59.31 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R0010 - Practical Activities - 1hb - (21.06 SQM)	● Student Space (9)	
B00G - R0012 - Withdrawal Space - 1hb - (6.29 SQM)	● Student Space (2)	
B00H - R0001 - Movement - (136.25 SQM)	Not Applicable	Circulation or storage space.
B00H - R0006 - Reading Area - (229.25 SQM)	● Student Space (106)	
B00H - R0007 - Special Programs Room - (42.66 SQM)	● Student Space (19)	
B00H - R0011 - Movement - (45.95 SQM)	Not Applicable	Circulation or storage space.
B00I - R0001 - Movement - (38.5 SQM)	Not Applicable	Circulation or storage space.
B00I - R0002 - Practical Activities - 1hb - (19.4 SQM)	● Student Space (9)	
B00I - R0004 - Home Base - (59.22 SQM) - Teaching Space: 1	● Student Space (27)	
B00I - R0005 - Withdrawal Space - 2hb - (11.36 SQM)	● Student Space (5)	
B00I - R0006 - Home Base - (59.22 SQM) - Teaching Space: 1	● Student Space (27)	
B00I - R0008 - Practical Activities - 1hb - (19.41 SQM)	● Student Space (9)	
B00J - R0001 - Home Base - (60.22 SQM) - Teaching Space: 1	● Student Space (27)	
B00J - R0003 - Practical Activities/Movement - 1hb - (19.59 SQM)	● Student Space (9)	
B00J - R0004 - Withdrawal Space - 2hb - (11.62 SQM)	● Student Space (5)	
B00J - R0005 - Home Base - (60.11 SQM) - Teaching Space: 1	● Student Space (27)	
B00J - R0006 - Practical Activities/Movement - 1hb - (19.46 SQM)	● Student Space (9)	
B00J - R0008 - Special Programs Room - (41.98 SQM)	● Student Space (19)	
B00J - R0011 - Home Base - (59.83 SQM) - Teaching Space: 1	● Student Space (27)	
B00J - R0013 - Practical Activities/Movement - 1hb - (19.8 SQM)	● Student Space (9)	
B00J - R0014 - Withdrawal Space - 2hb - (11.7 SQM)	● Student Space (5)	
B00J - R0015 - Home Base - (60.1 SQM) - Teaching Space: 1	● Student Space (27)	
B00J - R0016 - Practical Activities/Movement - 1hb - (19.75 SQM)	● Student Space (9)	