


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Blue Haven Public School (4623)</b>
<b>AMU REGION:</b>	<b>Hunter/Central Coast</b>
<b>STATE ELECTORATE:</b>	<b>Wyong</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Central Coast</b>

4623 - Blue Haven Public School  
Site Plan (13303)



1:1,154

Printed: 22-Aug-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Entry Vestibule - (23.74 SQM)	Not Applicable	Circulation or storage space.
B00A - R0004 - Sick Bay - (7.89 SQM)	● Student Space (3)	
B00A - R0006 - Interview - (13.31 SQM)	● Office (3)	
B00A - R0007 - Deputy Principal - (13.31 SQM)	● Office (3)	
B00A - R0008 - Deputy Principal - (13.31 SQM)	● Office (3)	
B00A - R0017 - Principal - (16.52 SQM)	● Office (4)	
B00A - R0018 - Duplicating Workroom - (19.93 SQM)	● Office (4)	
B00A - R0019 - Movement - (35.01 SQM)	Not Applicable	Circulation or storage space.
B00A - R0021 - Clerical Office - (40.47 SQM)	● Office (10)	
B00A - R0022 - Staff Room - (65.86 SQM)	● Office (16)	
B00A - R0023 - Staff Room Annexe - (25.7 SQM)	● Office (6)	
B00A - R0025 - Movement - (6.81 SQM)	Not Applicable	Circulation or storage space.
B00A - R0026 - Duplicating Workroom - (10.77 SQM)	● Office (2)	
B00B - R0002 - Home Base - (60.27 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R0003 - Practical Activities - 1hb - (19.9 SQM)	● Student Space (9)	
B00B - R0004 - Withdrawal Space - 1hb - (10.61 SQM)	● Student Space (4)	
B00B - R0005 - Home Base - (60.29 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R0006 - Practical Activities - 1hb - (19.92 SQM)	● Student Space (9)	
B00B - R0009 - Home Base - (60.27 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R0010 - Practical Activities - 1hb - (19.93 SQM)	● Student Space (9)	
B00B - R0011 - Withdrawal Space - 1hb - (10.61 SQM)	● Student Space (4)	
B00B - R0012 - Practical Activities - 1hb - (20.52 SQM)	● Student Space (9)	
B00B - R0013 - Home Base - (60.26 SQM) - Teaching Space: 1	● Student Space (27)	
B00C - R0001 - Withdrawal Space - 1hb - (32.79 SQM)	● Student Space (15)	
B00D - R0025 - Canteen - (33.91 SQM)	Not Applicable	Circulation or storage space.
B00D - R0028 - Communal Space - (217.24 SQM)	● Student Space (100)	
B00D - R0029 - Movement - (9.27 SQM)	Not Applicable	Circulation or storage space.
B00D - R0030 - Raised Platform - (64.96 SQM)	Not Applicable	Circulation or storage space.
B00D - R0031 - Movement - (25.32 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Practical Activities - 1hb - (19.94 SQM)	● Student Space (9)	
B00E - R0004 - Home Base - (60.4 SQM) - Teaching Space: 1	● Student Space (28)	
B00E - R0005 - Withdrawal Space - 1hb - (10.6 SQM)	● Student Space (4)	
B00E - R0006 - Home Base - (60.39 SQM) - Teaching Space: 1	● Student Space (28)	
B00E - R0007 - Practical Activities - 1hb - (19.86 SQM)	● Student Space (9)	
B00E - R0020 - Reading Area - (224.87 SQM)	● Student Space (104)	
B00F - R0005 - Practical Activities - 1hb - (19.98 SQM)	● Student Space (9)	
B00F - R0006 - Home Base - (60.14 SQM) - Teaching Space: 1	● Student Space (27)	
B00F - R0007 - Withdrawal Space - 1hb - (10.6 SQM)	● Student Space (4)	
B00F - R0008 - Home Base - (60.25 SQM) - Teaching Space: 1	● Student Space (27)	
B00F - R0009 - Practical Activities - 1hb - (19.91 SQM)	● Student Space (9)	
B00F - R0012 - Practical Activities - 1hb - (19.91 SQM)	● Student Space (9)	
B00F - R0013 - Home Base - (60.31 SQM) - Teaching Space: 1	● Student Space (27)	
B00F - R0014 - Withdrawal Space - 1hb - (10.6 SQM)	● Student Space (4)	
B00F - R0015 - Home Base - (60.38 SQM) - Teaching Space: 1	● Student Space (28)	
B00F - R0016 - Practical Activities - 1hb - (19.87 SQM)	● Student Space (9)	
B00G - R0001 - Home Base - (60.58 SQM) - Teaching Space: 1	● Student Space (28)	
B00G - R0003 - Practical Activities - 1hb - (19.73 SQM)	● Student Space (9)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R0004 - Withdrawal Space - 2hb - (11.58 SQM)	Student Space (5)	
B00G - R0005 - Home Base - (60.44 SQM) - Teaching Space: 1	Student Space (28)	
B00G - R0006 - Practical Activities - 1hb - (19.3 SQM)	Student Space (8)	
B00G - R0009 - Practical Activities - 1hb - (19.29 SQM)	Student Space (8)	
B00G - R0010 - Home Base - (60.56 SQM) - Teaching Space: 1	Student Space (28)	
B00G - R0011 - Withdrawal Space - 2hb - (11.61 SQM)	Student Space (5)	
B00G - R0012 - Home Base - (60.77 SQM) - Teaching Space: 1	Student Space (28)	
B00G - R0013 - Practical Activities - 1hb - (19.79 SQM)	Student Space (9)	
B00G - R0015 - Special Programs Room - (43.22 SQM)	Student Space (20)	
B00G - R0026 - Movement - (5.51 SQM)	Not Applicable	Circulation or storage space.
B00G - R1001 - Home Base - (60.51 SQM) - Teaching Space: 1	Student Space (28)	
B00G - R1003 - Practical Activities - 1hb - (19.86 SQM)	Student Space (9)	
B00G - R1004 - Withdrawal Space - 2hb - (11.52 SQM)	Student Space (5)	
B00G - R1005 - Home Base - (60.67 SQM) - Teaching Space: 1	Student Space (28)	
B00G - R1006 - Practical Activities - 1hb - (19.31 SQM)	Student Space (8)	
B00G - R1009 - Practical Activities - 1hb - (19.44 SQM)	Student Space (9)	
B00G - R1010 - Home Base - (60.15 SQM) - Teaching Space: 1	Student Space (27)	
B00G - R1011 - Withdrawal Space - 2hb - (11.59 SQM)	Student Space (5)	
B00G - R1012 - Home Base - (60.6 SQM) - Teaching Space: 1	Student Space (28)	
B00G - R1013 - Practical Activities - 1hb - (19.28 SQM)	Student Space (8)	
B00G - R1016 - Practical Activities - 1hb - (19.28 SQM)	Student Space (8)	
B00G - R1017 - Home Base - (60.3 SQM) - Teaching Space: 1	Student Space (27)	
B00G - R1018 - Withdrawal Space - 2hb - (11.62 SQM)	Student Space (5)	
B00G - R1019 - Home Base - (60.79 SQM) - Teaching Space: 1	Student Space (28)	
B00G - R1020 - Practical Activities - 1hb - (19.62 SQM)	Student Space (9)	
B00G - R1026 - Movement - (5.81 SQM)	Not Applicable	Circulation or storage space.
B00H - R0004 - Practical Activities - 1hb - (19.06 SQM)	Student Space (8)	
B00H - R0006 - Home Base - (60.64 SQM) - Teaching Space: 1	Student Space (28)	
B00H - R0007 - Withdrawal Space - 2hb - (11.63 SQM)	Student Space (5)	
B00H - R0008 - Practical Activities - 1hb - (17.95 SQM)	Student Space (8)	
B00H - R0010 - Home Base - (60.63 SQM) - Teaching Space: 1	Student Space (28)	
B00H - R0012 - Special Programs Room - (36.82 SQM)	Student Space (17)	
B00H - R1001 - Practical Activities - 1hb - (19.06 SQM)	Student Space (8)	
B00H - R1003 - Home Base - (60.64 SQM) - Teaching Space: 1	Student Space (28)	
B00H - R1004 - Withdrawal Space - 2hb - (11.63 SQM)	Student Space (5)	
B00H - R1005 - Practical Activities - 1hb - (17.95 SQM)	Student Space (8)	
B00H - R1007 - Home Base - (60.63 SQM) - Teaching Space: 1	Student Space (28)	
OS 606 10810 - OS 606 10810 - Learning Unit - Standard With P.A.A A/C - (95 SQM)	Student Space (44)	
OS 606 15726 - OS 606 15726 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	Student Space (35)	