


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Bomaderry High School (8448)</b>
<b>AMU REGION:</b>	<b>Southern NSW</b>
<b>STATE ELECTORATE:</b>	<b>Kiama</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Shoalhaven</b>

8448 - Bomaderry High School  
Site Plan (10903)



1:2,316

Printed: 24-Mar-2021

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0003 - Laboratory L.S. - (92.61 SQM) - Teaching Space: 1	● Student Space (42)	
B00A - R0004 - Preparation - (29.48 SQM)	Not Applicable	Circulation or storage space.
B00A - R0005 - Preparation - (8.83 SQM)	Not Applicable	Circulation or storage space.
B00A - R0006 - Laboratory L.S. - (85.01 SQM) - Teaching Space: 1	● Student Space (39)	
B00A - R0010 - Movement - (10.59 SQM)	Not Applicable	Circulation or storage space.
B00A - R0011 - Leading Teacher - (8.74 SQM)	● Office (2)	
B00A - R0012 - Deputy Principal Office - (14.17 SQM)	● Office (3)	
B00A - R0014 - Ancillary Staff - (12.58 SQM)	● Office (3)	
B00A - R0015 - Clinic - Boys - (11.9 SQM)	● Office (2)	
B00A - R0016 - Interview/Office - Type 1 - (13.84 SQM)	● Office (3)	
B00A - R0017 - Leading Teacher - (12.32 SQM)	● Office (3)	
B00A - R0018 - Commonroom - (17.15 SQM)	● Office (4)	
B00A - R0021 - Public Entry - (46.66 SQM)	Not Applicable	Circulation or storage space.
B00A - R0022 - Administration - Clerical - (28.4 SQM)	● Office (7)	
B00A - R0023 - Administration - Clerical - (25.2 SQM)	● Office (6)	
B00A - R0024 - Duplicating Workroom - (32.13 SQM)	● Office (8)	
B00A - R0025 - Principal Office - (19.58 SQM)	● Office (4)	
B00A - R0028 - General Learning Space - (58.33 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R0032 - Special Learning Space - (52.63 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R0034 - Movement - (185.69 SQM)	Not Applicable	Circulation or storage space.
B00A - R1002 - General Learning Space - (52.48 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R1003 - Staff Study - (52.48 SQM)	● Office (13)	
B00A - R1004 - Commonroom - (138.56 SQM)	● Office (34)	
B00A - R1007 - General Learning Space - (52.48 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R1009 - Staff Study - (12.85 SQM)	● Office (3)	
B00A - R1010 - General Learning Space - (58.33 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R1012 - General Learning Space - (52.41 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R1014 - General Learning Space - (65.93 SQM) - Teaching Space: 1	● Student Space (30)	
B00A - R1018 - Design L.S. - (71.61 SQM) - Teaching Space: 1	● Student Space (33)	
B00A - R1021 - Computer Learning Space - (52.48 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R1024 - Movement - (170.87 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Materials Technology L.S. - (81.02 SQM) - Teaching Space: 1	● Student Space (37)	
B00B - R0005 - Materials Technology L.S. - (89.09 SQM) - Teaching Space: 1	● Student Space (41)	
B00B - R0007 - Design L.S. - (48.44 SQM) - Teaching Space: 1	● Student Space (22)	
B00B - R0013 - Staff Study - (51.6 SQM)	● Office (12)	
B00B - R0015 - Staff Study - (31.62 SQM)	● Office (7)	
B00B - R0016 - Staff Study - (25.69 SQM)	● Office (6)	
B00B - R0017 - Food Technology L.S. - (66.02 SQM) - Teaching Space: 1	● Student Space (30)	
B00B - R0018 - Food/Research Space - (12.64 SQM)	Not Applicable	Circulation or storage space.
B00B - R0020 - Food Technology L.S. - (79.57 SQM) - Teaching Space: 1	● Student Space (36)	
B00B - R0028 - Music Learning Space - (52.63 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0031 - Movement - (186.06 SQM)	Not Applicable	Circulation or storage space.
B00B - R0032 - Workshop Area - (67.53 SQM)	● Student Space (31)	
B00B - R1001 - Materials Technology L.S. - (84.47 SQM) - Teaching Space: 1	● Student Space (39)	
B00B - R1002 - Wood Technology Bay - (34.17 SQM)	Not Applicable	Circulation or storage space.
B00B - R1004 - Materials Technology L.S. - (79.42 SQM) - Teaching Space: 1	● Student Space (36)	
B00B - R1005 - Computer Learning Space - (58.33 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R1011 - Staff Study - (31.47 SQM)	● Office (7)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R1013 - Art Learning Space - (52.77 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1016 - Art Learning Space - (52.26 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1018 - Art Learning Space - (71.88 SQM) - Teaching Space: 1	Student Space (33)	
B00B - R1022 - Music Learning Space - (52.63 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1025 - Movement - (177.5 SQM)	Not Applicable	Circulation or storage space.
B00B - R1026 - Photographic Studio - (24.35 SQM)	Office (6)	
B00B - R1027 - Computer Room - (26.13 SQM)	Student Space (12)	
B00C - R0001 - Movement - (312.96 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Movement - (11.83 SQM)	Not Applicable	Circulation or storage space.
B00C - R0007 - Student Canteen - (56.52 SQM)	Not Applicable	Circulation or storage space.
B00C - R0012 - Movement - (19.36 SQM)	Not Applicable	Circulation or storage space.
B00C - R0013 - Movement - (6.65 SQM)	Not Applicable	Circulation or storage space.
B00C - R0014 - General Assistants - (22.2 SQM)	Office (5)	
B00C - R0015 - Movement - (11.58 SQM)	Not Applicable	Circulation or storage space.
B00C - R1001 - Movement - (12.98 SQM)	Not Applicable	Circulation or storage space.
B00C - R1015 - Movement - (13.25 SQM)	Not Applicable	Circulation or storage space.
B00D - R0009 - General Learning Space - (52.34 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0013 - Laboratory L.S. - (92.47 SQM) - Teaching Space: 1	Student Space (42)	
B00D - R0016 - Darkroom Space - (12.44 SQM)	Office (3)	
B00D - R0023 - Staff Study - (12.85 SQM)	Office (3)	
B00D - R0024 - Movement - (180.09 SQM)	Not Applicable	Circulation or storage space.
B00D - R0025 - Staff Study - (52.77 SQM)	Office (13)	
B00D - R0028 - Laboratory L.S. - (84.97 SQM) - Teaching Space: 1	Student Space (39)	
B00D - R0029 - Preparation - Science - (38.98 SQM)	Not Applicable	Circulation or storage space.
B00D - R0030 - Laboratory L.S. - (92.41 SQM) - Teaching Space: 1	Student Space (42)	
B00D - R0031 - General Learning Space - Bd/Cd/Ed - (52.8 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0033 - General Learning Space - Bd/Cd/Ed - (47.45 SQM) - Teaching Space: 1	Student Space (22)	
B00D - R0034 - Kitchen - Type 2 - (5.01 SQM)	Student Space (2)	
B00D - R1001 - General Learning Space - (58.18 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R1002 - General Learning Space - (52.56 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1003 - General Learning Space - (52.56 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1004 - Darkroom Space - (12.44 SQM)	Office (3)	
B00D - R1005 - Staff Study - (25.69 SQM)	Office (6)	
B00D - R1007 - General Learning Space - (57.96 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R1012 - General Learning Space - (58.48 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R1013 - General Learning Space - (52.7 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1014 - Senior Study - (25.81 SQM)	Office (6)	
B00D - R1017 - Staff Study - (25.8 SQM)	Office (6)	
B00D - R1020 - General Learning Space - (58.04 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R1023 - General Learning Space - (52.41 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1025 - Staff Study - (12.85 SQM)	Office (3)	
B00D - R1026 - Movement - (171.59 SQM)	Not Applicable	Circulation or storage space.
B00D - R1030 - Tea Room - (39.03 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Staff Study - (32.53 SQM)	Office (8)	
B00E - R0002 - General Learning Space - (52.56 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0004 - Staff Study - (12.49 SQM)	Office (3)	
B00E - R0005 - Senior Study - (25.8 SQM)	Office (6)	
B00E - R0006 - Performance Workspace - (66.08 SQM) - Teaching Space: 1	Student Space (30)	
B00E - R0009 - General Learning Space - (51.39 SQM) - Teaching Space: 1	Student Space (23)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R0015 - Staff Study - (39.3 SQM)	Office (9)	
B00E - R0016 - Commonroom - (17.66 SQM)	Office (4)	
B00E - R0018 - General Learning Space - (52.27 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0019 - General Learning Space - (52.69 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0020 - General Learning Space - (72.68 SQM) - Teaching Space: 1	Student Space (33)	
B00E - R0021 - General Learning Space - (53.21 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0027 - Movement - (161.32 SQM)	Not Applicable	Circulation or storage space.
B00E - R1001 - Laboratory L.S. - (85.71 SQM) - Teaching Space: 1	Student Space (39)	
B00E - R1002 - Preparation - (22.4 SQM)	Not Applicable	Circulation or storage space.
B00E - R1004 - Preparation - (12.94 SQM)	Not Applicable	Circulation or storage space.
B00E - R1009 - General Learning Space - (51.39 SQM) - Teaching Space: 1	Student Space (23)	
B00E - R1014 - Computer Learning Space - (59.21 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R1015 - Staff Study - (25.8 SQM)	Office (6)	
B00E - R1016 - General Learning Space - (52.63 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R1017 - General Learning Space - (52.63 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R1018 - General Learning Space - (59.35 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R1019 - Staff Study - (12.88 SQM)	Office (3)	
B00E - R1020 - General Learning Space - (51.45 SQM) - Teaching Space: 1	Student Space (23)	
B00E - R1025 - Movement - (180.61 SQM)	Not Applicable	Circulation or storage space.
B00E - R1026 - Laboratory L.S. - (92.74 SQM) - Teaching Space: 1	Student Space (43)	
B00F - R0001 - Main Area - (401.16 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Seminar - (12.25 SQM)	Office (3)	
B00F - R0003 - Seminar - (12.11 SQM)	Office (3)	
B00F - R0004 - Seminar - (12.14 SQM)	Office (3)	
B00F - R0006 - Audio Visual Workroom - (38.3 SQM)	Student Space (17)	
B00F - R0007 - Workroom - (42.84 SQM)	Office (10)	
B00F - R0008 - Public Entry - (14.67 SQM)	Not Applicable	Circulation or storage space.
B00F - R0014 - Interview/Meeting - (7.24 SQM)	Office (1)	
B00F - R0016 - Interview/Meeting - (24.44 SQM)	Office (6)	
B00F - R0017 - Main Area - (395.61 SQM)	Not Applicable	Circulation or storage space.
B00G - M0001 - Multi-Purpose Space - (133.08 SQM)	Student Space (61)	
B00G - R0001 - Staff Study - (18.36 SQM)	Office (4)	
B00G - R0002 - Student Canteen - (12.45 SQM)	Not Applicable	Circulation or storage space.
B00G - R0003 - Public Entry - (24.78 SQM)	Not Applicable	Circulation or storage space.
B00G - R0012 - Multi-Purpose Space - (478.83 SQM)	Student Space (222)	
B00G - R0016 - Stage - (87.57 SQM)	Not Applicable	Circulation or storage space.
B00G - R0017 - Movement - (6.03 SQM)	Not Applicable	Circulation or storage space.
B00G - R0019 - Movement - (6.02 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Entry - (10.89 SQM)	Not Applicable	Circulation or storage space.
B00H - R0002 - Administration - Clerical - (16.31 SQM)	Office (4)	
B00H - R0003 - Commonroom - (42.1 SQM)	Office (10)	
B00H - R0004 - Staff Kitchen - (9.06 SQM)	Office (2)	
B00H - R0005 - Hydrotherapy - Spa - (8.18 SQM)	Not Applicable	Circulation or storage space.
B00H - R0013 - Movement - (28.49 SQM)	Not Applicable	Circulation or storage space.
B00H - R0014 - General Learning Space - S/P - (41.82 SQM) - Teaching Space: 1	Student Space (19)	
B00H - R0015 - Practical Activity Area - (15.49 SQM)	Student Space (7)	
B00H - R0016 - Practical Activity Area - (15.52 SQM)	Student Space (7)	
B00H - R0017 - General Learning Space - S/P - (41.82 SQM) - Teaching Space: 1	Student Space (19)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00H - R0018 - Movement - (10.6 SQM)	Not Applicable	Circulation or storage space.
B00H - R0025 - Movement - (22.11 SQM)	Not Applicable	Circulation or storage space.
B00H - R0026 - Movement - (16.7 SQM)	Not Applicable	Circulation or storage space.
B00M - R0001 - Gymnasium - (629.95 SQM)	● Student Space (292)	
B00M - R0002 - Tea Room - (33.5 SQM)	Not Applicable	Circulation or storage space.
OS 523 15807 - OS 523 15807 - Staff Study With Toilets - (76 SQM)	● Office (19)	
OS 523 18210 - OS 523 18210 - Staff Study With Toilets - (76 SQM)	● Office (19)	
OS 601 13800 - OS 601 13800 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 606 13211 - OS 606 13211 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 606 19211 - OS 606 19211 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 606 19214 - OS 606 19214 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 606 19225 - OS 606 19225 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 606 19249 - OS 606 19249 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 606 19272 - OS 606 19272 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 606 19284 - OS 606 19284 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 606 19595 - OS 606 19595 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 606 19740 - OS 606 19740 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 606 19741 - OS 606 19741 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 606 19813 - OS 606 19813 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 606 19814 - OS 606 19814 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	