

VENTILATION AUDIT REPORT

SCHOOL:	Bomaderry Public School (1287)
AMU REGION:	Southern NSW
STATE ELECTORATE:	Kiama
LOCAL GOVERNMENT AREA:	Shoalhaven

1287 - Bomaderry Public School
Site Plan (10917)



1:1,180

Printed: 13-Jul-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Staff Room - (86.97 SQM)	Office (21)	
B00A - R0002 - Principal - (20.92 SQM)	Office (5)	
B00A - R0003 - Entry Vestibule - (14.27 SQM)	Not Applicable	Circulation or storage space.
B00A - R0004 - Clerical Office - (15.13 SQM)	Office (3)	
B00A - R0005 - Clerical Office/Workroom - (15.27 SQM)	Office (3)	
B00A - R0006 - Deputy Principal - (12.16 SQM)	Office (3)	
B00A - R0009 - Interview - (7.38 SQM)	Office (1)	
B00A - R0010 - Sick Bay - (6.8 SQM)	Student Space (3)	
B00A - R0012 - Movement - (20.35 SQM)	Not Applicable	Circulation or storage space.
B00A - R0013 - Movement - (6.39 SQM)	Not Applicable	Circulation or storage space.
B00A - R0017 - Movement - (10.53 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Home Base - (56.42 SQM)	Student Space (26)	
B00B - R0004 - Movement - (12.21 SQM)	Not Applicable	Circulation or storage space.
B00B - R0005 - Home Base - (56.94 SQM)	Student Space (26)	
B00B - R0007 - Home Base - (56.87 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0011 - Movement - (5.84 SQM)	Not Applicable	Circulation or storage space.
B00B - R0012 - Home Base - (56.94 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0019 - Movement - (5.91 SQM)	Not Applicable	Circulation or storage space.
B00B - R0021 - Home Base - E - (56.79 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0022 - Practical Activities - E - (16.64 SQM)	Student Space (7)	
B00B - R0024 - Movement - (24.1 SQM)	Not Applicable	Circulation or storage space.
B00B - R0026 - Home Base - (56.95 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0001 - Home Base - (51.49 SQM) - Teaching Space: 1	Student Space (23)	
B00C - R0003 - Home Base - (56.71 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0007 - Movement - (5.73 SQM)	Not Applicable	Circulation or storage space.
B00C - R0008 - Home Base - (56.5 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0011 - Practical Activities - (9.92 SQM)	Student Space (4)	
B00D - R0001 - Home Base - (60.53 SQM) - Teaching Space: 1	Student Space (28)	
B00D - R0002 - Practical Activities - 1hb - (7.54 SQM)	Student Space (3)	
B00D - R0004 - Home Base - (64.52 SQM) - Teaching Space: 1	Student Space (29)	
B00D - R0005 - Practical Activities - 1hb - (7.52 SQM)	Student Space (3)	
B00D - R0006 - Staff Room Annexe - (12.73 SQM)	Office (3)	
B00D - R0009 - Home Base - (63.89 SQM) - Teaching Space: 1	Student Space (29)	
B00D - R0011 - Home Base - M - (63.27 SQM) - Teaching Space: 1	Student Space (29)	
B00D - R0013 - Canteen - (31.57 SQM)	Not Applicable	Circulation or storage space.
B00D - R0017 - Movement - (19.81 SQM)	Not Applicable	Circulation or storage space.
B00D - R0018 - Movement - (88.6 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Communal Space - (243.85 SQM)	Student Space (113)	
B00E - R0004 - Raised Platform - (49.89 SQM)	Not Applicable	Circulation or storage space.
B00E - R0011 - Movement - (105.97 SQM)	Not Applicable	Circulation or storage space.
B00E - R1001 - Movement - (6.21 SQM)	Not Applicable	Circulation or storage space.
B00E - R1005 - Staff Room Annexe - (14.31 SQM)	Office (3)	
B00E - R1006 - Staff Room Annexe - (13.4 SQM)	Office (3)	
B00E - R1009 - Movement - (7.72 SQM)	Not Applicable	Circulation or storage space.
B00E - R1010 - Movement - (6.4 SQM)	Not Applicable	Circulation or storage space.
B00E - R1011 - Reading Area - (241.06 SQM)	Student Space (111)	
B00E - R1012 - Seminar/Study - (14.14 SQM)	Office (3)	
B00E - R1015 - Movement - (6.2 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Movement - (151.34 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Practical Activities - 1hb - (13.86 SQM)	Student Space (6)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R0002 - Home Base - (59.08 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R0003 - Home Base - (57.96 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R0004 - Practical Activities - 1hb - (14.4 SQM)	● Student Space (6)	
B00G - R0006 - Movement - (5.9 SQM)	Not Applicable	Circulation or storage space.
B00G - R0009 - Practical Activities - 1hb - (13.84 SQM)	● Student Space (6)	
B00G - R0010 - Home Base - (57.73 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R0011 - Home Base - (57.09 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R0012 - Practical Activities - 1hb - (14.19 SQM)	● Student Space (6)	
B00G - R0013 - Movement - (6.58 SQM)	Not Applicable	Circulation or storage space.
B00G - R0015 - Movement - (23.34 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Staff Room Annexe - (14.01 SQM)	● Office (3)	
B00H - R0005 - Special Programs Room - (22.9 SQM)	● Student Space (10)	
B00H - R0007 - Duplicating Workroom - (12.89 SQM)	● Office (3)	
B00H - R0011 - Home Base - (71.34 SQM) - Teaching Space: 1	● Student Space (33)	
B00H - R0012 - Practical Activities - 1hb - (13.53 SQM)	● Student Space (6)	
B00H - R0014 - Home Base - (71.53 SQM) - Teaching Space: 1	● Student Space (33)	
B00H - R0015 - Practical Activities - 1hb - (13.56 SQM)	● Student Space (6)	
B00H - R0017 - Movement - (73.21 SQM)	Not Applicable	Circulation or storage space.
B00H - R0018 - Entry Vestibule - (33.21 SQM)	Not Applicable	Circulation or storage space.
B00I - R0007 - Movement - (57.35 SQM)	Not Applicable	Circulation or storage space.
B00J - R0002 - Home Base - (82.25 SQM) - Teaching Space: 1	● Student Space (38)	
B00J - R0003 - Practical Activities - 1hb - (13.3 SQM)	● Student Space (6)	
B00J - R0005 - Home Base - (82.16 SQM) - Teaching Space: 1	● Student Space (38)	
B00J - R0007 - Practical Activities - 1hb - (13.52 SQM)	● Student Space (6)	
B00K - R0001 - Practical Activities - 1hb - (12.39 SQM)	● Student Space (5)	
B00K - R0002 - Home Base - (63.92 SQM) - Teaching Space: 1	● Student Space (29)	
B00K - R0005 - Movement - (50.33 SQM)	Not Applicable	Circulation or storage space.
B00K - R0006 - Practical Activities - 1hb - (32.89 SQM)	● Student Space (15)	
B00K - R0007 - Home Base - (48.22 SQM) - Teaching Space: 1	● Student Space (22)	
OS 602 14051 - OS 602 14051 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	