


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Bongongo Public School (1293)</b>
<b>AMU REGION:</b>	<b>Southern NSW</b>
<b>STATE ELECTORATE:</b>	<b>Cootamundra</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Cootamundra-Gundagai</b>

1293 - Bongongo Public School  
Site Plan (12357)



1:1,063

Printed: 17-Apr-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R0001 - Practical Activities - (21.46 SQM)	● Student Space (9)	
B00D - R0002 - Withdrawal Space - 1hb - (42.04 SQM)	● Student Space (19)	
B00D - R0003 - Staff Kitchen - (7.86 SQM)	● Office (1)	
B00D - R0004 - Movement - (8.2 SQM)	Not Applicable	Circulation or storage space.
B00D - R0005 - Principal - (13.39 SQM)	● Office (3)	
B00D - R0006 - Movement - (5.03 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Home Base - (59.86 SQM) - Teaching Space: 1	● Student Space (27)	
OS 601 12363 - OS 601 12363 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	