

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Bonnells Bay Public School (2532)</b>
<b>AMU REGION:</b>	<b>Hunter/Central Coast</b>
<b>STATE ELECTORATE:</b>	<b>Lake Macquarie</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Lake Macquarie</b>

2532 - Bonnells Bay Public School  
Site Plan (12358)



















1:1,393

Printed: 30-Mar-2021

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Clerical Office - (16.56 SQM)	Office (4)	
B00A - R0003 - Principal - (17.01 SQM)	Office (4)	
B00A - R0004 - Staff Room Annexe - (13.15 SQM)	Office (3)	
B00A - R0006 - Staff Room Annexe - (13.05 SQM)	Office (3)	
B00A - R0007 - Staff Room Annexe - (18.61 SQM)	Office (4)	
B00A - R0008 - Staff Room - (48.08 SQM)	Office (12)	
B00A - R0009 - Movement - (26.46 SQM)	Not Applicable	Circulation or storage space.
B00A - R0014 - Duplicating Workroom - (20 SQM)	Office (5)	
B00A - R0017 - Sick Bay - (8.76 SQM)	Student Space (4)	
B00A - R0018 - Interview - (13.51 SQM)	Office (3)	
B00A - R0019 - Entry Vestibule - (13.73 SQM)	Not Applicable	Circulation or storage space.
B00A - R0020 - Movement - (5.59 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Movement - (27.46 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Canteen - (14.36 SQM)	Not Applicable	Circulation or storage space.
B00B - R0003 - Canteen - (17.07 SQM)	Not Applicable	Circulation or storage space.
B00C - R0006 - Communal Space - (157.4 SQM)	Student Space (73)	
B00C - R0011 - Raised Platform - (41.51 SQM)	Not Applicable	Circulation or storage space.
B00C - R0015 - Movement - (9.34 SQM)	Not Applicable	Circulation or storage space.
B00D - R0005 - Special Programs Room - (33.71 SQM)	Student Space (15)	
B00D - R0008 - Reading Area - (159.69 SQM)	Student Space (74)	
B00F - R0002 - Practical Activities - 1hb - (18.79 SQM)	Student Space (8)	
B00F - R0003 - Home Base - (59.17 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R0005 - Withdrawal Space - 1hb - (6.57 SQM)	Student Space (3)	
B00F - R0007 - Practical Activities - 1hb - (18.11 SQM)	Student Space (8)	
B00F - R0009 - Home Base - (55.67 SQM) - Teaching Space: 1	Student Space (25)	
B00F - R0010 - Withdrawal Space - 1hb - (11.19 SQM)	Student Space (5)	
B00F - R0011 - Home Base - (55.46 SQM) - Teaching Space: 1	Student Space (25)	
B00F - R0012 - Practical Activities - 1hb - (18.08 SQM)	Student Space (8)	
B00G - R0003 - Practical Activities - 1hb - (18.14 SQM)	Student Space (8)	
B00G - R0005 - Home Base - (55.96 SQM) - Teaching Space: 1	Student Space (25)	
B00G - R0006 - Withdrawal Space - 1hb - (11.19 SQM)	Student Space (5)	
B00G - R0007 - Home Base - (55.97 SQM) - Teaching Space: 1	Student Space (25)	
B00G - R0008 - Practical Activities - 1hb - (18.14 SQM)	Student Space (8)	
B00H - R0002 - Practical Activities - 1hb - (18.99 SQM)	Student Space (8)	
B00H - R0003 - Home Base - (58.91 SQM) - Teaching Space: 1	Student Space (27)	
B00H - R0005 - Withdrawal Space - 1hb - (6.53 SQM)	Student Space (3)	
B00H - R0007 - Practical Activities - 1hb - (18.09 SQM)	Student Space (8)	
B00H - R0009 - Home Base - (55.92 SQM) - Teaching Space: 1	Student Space (25)	
B00H - R0010 - Withdrawal Space - 1hb - (11.16 SQM)	Student Space (5)	
B00H - R0011 - Home Base - (55.96 SQM) - Teaching Space: 1	Student Space (25)	
B00H - R0012 - Practical Activities - 1hb - (18 SQM)	Student Space (8)	
B00I - R0003 - Practical Activities - 1hb - (17.8 SQM)	Student Space (8)	
B00I - R0005 - Home Base - (56.53 SQM) - Teaching Space: 1	Student Space (26)	
B00I - R0006 - Withdrawal Space - 1hb - (11.12 SQM)	Student Space (5)	
B00I - R0007 - Home Base - (56.23 SQM) - Teaching Space: 1	Student Space (26)	
B00I - R0008 - Practical Activities - 1hb - (17.95 SQM)	Student Space (8)	
B00J - R0001 - Special Programs Room - (49.65 SQM)	Student Space (23)	
B00L - R0001 - Special Programs Room - (35.62 SQM)	Student Space (16)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00L - R0004 - Practical Activities - 1hb - (18.33 SQM)	 Student Space (8)	
B00L - R0006 - Home Base - (60.34 SQM) - Teaching Space: 1	 Student Space (27)	
B00L - R0007 - Withdrawal Space - 2hb - (11.57 SQM)	 Student Space (5)	
B00L - R0008 - Practical Activities - 1hb - (18.9 SQM)	 Student Space (8)	
B00L - R0009 - Home Base - (60.87 SQM) - Teaching Space: 1	 Student Space (28)	
B00L - R0011 - Practical Activities - 1hb - (19.17 SQM)	 Student Space (8)	
B00L - R0013 - Home Base - (60.81 SQM) - Teaching Space: 1	 Student Space (28)	
B00L - R0014 - Withdrawal Space - 2hb - (11.5 SQM)	 Student Space (5)	
B00L - R0015 - Practical Activities - 1hb - (18.14 SQM)	 Student Space (8)	
B00L - R0016 - Home Base - (60.15 SQM) - Teaching Space: 1	 Student Space (27)	
OS 602 11547 - OS 602 11547 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 14852 - OS 602 14852 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 603 10687 - OS 603 10687 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	 Student Space (35)	
OS 603 15110 - OS 603 15110 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	 Student Space (35)	
OS 606 19251 - OS 606 19251 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	
OS 606 19900 - OS 606 19900 - Learning Unit - Standard With P.A.A A/C - ( SQM)	 Student Space ( )	