


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Bonnet Bay Public School (4507)</b>
<b>AMU REGION:</b>	<b>Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Miranda</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Sutherland</b>

4507 - Bonnet Bay Public School  
Site Plan (10906)











1:855

Printed: 21-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - M0001 - Withdrawal Space - 1hb - (6.37 SQM)	● Student Space (2)	
B00A - M0002 - Withdrawal Space - 1hb - (6.41 SQM)	● Student Space (2)	
B00A - R0001 - Movement - (26.78 SQM)	Not Applicable	Circulation or storage space.
B00A - R0003 - Withdrawal Space - 1hb - (5.12 SQM)	● Student Space (2)	
B00A - R0004 - Home Base - (62.71 SQM) - Teaching Space: 1	● Student Space (29)	
B00A - R0008 - Movement - (167.73 SQM)	Not Applicable	Circulation or storage space.
B00A - R0009 - Practical Activities - 1hb - (49.6 SQM)	● Student Space (23)	
B00A - R0011 - Home Base - (62.71 SQM) - Teaching Space: 1	● Student Space (29)	
B00A - R0013 - Withdrawal Space - 1hb - (12.32 SQM)	● Student Space (5)	
B00A - R0015 - Home Base - (61.96 SQM) - Teaching Space: 1	● Student Space (28)	
B00A - R0016 - Movement - (26.57 SQM)	Not Applicable	Circulation or storage space.
B00A - R0017 - Practical Activities - 1hb - (45.19 SQM)	● Student Space (20)	
B00A - R0021 - Home Base - (62.71 SQM) - Teaching Space: 1	● Student Space (29)	
B00A - R0025 - Withdrawal Space - 1hb - (5.14 SQM)	● Student Space (2)	
B00A - R0028 - Home Base - (61.98 SQM) - Teaching Space: 1	● Student Space (28)	
B00A - R0029 - Movement - (26.68 SQM)	Not Applicable	Circulation or storage space.
B00A - R0030 - Practical Activities - 1hb - (50.64 SQM)	● Student Space (23)	
B00A - R0032 - Outdoor Learning Area - (24.49 SQM)	Not Applicable	Circulation or storage space.
B00A - R0033 - Home Base - (62.52 SQM) - Teaching Space: 1	● Student Space (29)	
B00A - R0035 - Withdrawal Space - 1hb - (5.13 SQM)	● Student Space (2)	
B00B - M0001 - Withdrawal Space - 1hb - (6.54 SQM)	● Student Space (3)	
B00B - R0001 - Outdoor Learning Area - (24.35 SQM)	Not Applicable	Circulation or storage space.
B00B - R0003 - Withdrawal Space - 1hb - (5.13 SQM)	● Student Space (2)	
B00B - R0004 - Home Base - (62.73 SQM) - Teaching Space: 1	● Student Space (29)	
B00B - R0008 - Movement - (145.76 SQM)	Not Applicable	Circulation or storage space.
B00B - R0009 - Special Programs Room - (40.5 SQM)	● Student Space (18)	
B00B - R0011 - Home Base - (62.94 SQM) - Teaching Space: 1	● Student Space (29)	
B00B - R0013 - Practical Activities - 1hb - (50.01 SQM)	● Student Space (23)	
B00B - R0015 - Withdrawal Space - 1hb - (12.08 SQM)	● Student Space (5)	
B00B - R0016 - Home Base - (62.01 SQM) - Teaching Space: 1	● Student Space (28)	
B00B - R0017 - Movement - (13 SQM)	Not Applicable	Circulation or storage space.
B00B - R0018 - Practical Activities - 1hb - (50.41 SQM)	● Student Space (23)	
B00B - R0020 - Home Base - (62.94 SQM) - Teaching Space: 1	● Student Space (29)	
B00B - R0024 - Withdrawal Space - 1hb - (5.1 SQM)	● Student Space (2)	
B00B - R0026 - Reading Area - (270.92 SQM)	● Student Space (125)	
B00B - R0027 - Movement - (15.57 SQM)	Not Applicable	Circulation or storage space.
B00B - R0041 - Communal Space - (237.82 SQM)	● Student Space (110)	
B00B - R0042 - Movement - (29.85 SQM)	Not Applicable	Circulation or storage space.
B00B - R0046 - Raised Platform - (38.84 SQM)	Not Applicable	Circulation or storage space.
B00B - R0051 - Movement - (33.33 SQM)	Not Applicable	Circulation or storage space.
B00B - R0054 - Canteen - (39.67 SQM)	Not Applicable	Circulation or storage space.
B00B - R0059 - Movement - (5.01 SQM)	Not Applicable	Circulation or storage space.
B00B - R0062 - Movement - (18.05 SQM)	Not Applicable	Circulation or storage space.
B00B - R0065 - Home Base - (40.5 SQM) - Teaching Space: 1	● Student Space (18)	
B00B - R0066 - Movement - (140.93 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Movement - (16.94 SQM)	Not Applicable	Circulation or storage space.
B00D - R0003 - Entry Vestibule - (34.02 SQM)	Not Applicable	Circulation or storage space.
B00D - R0004 - Interview - (12.24 SQM)	● Office (3)	
B00D - R0006 - Duplicating Workroom - (37.72 SQM)	● Office (9)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R0009 - Staff Room - (67.93 SQM)	 Office (16)	
B00D - R0010 - Staff Room Annexe - (22.86 SQM)	 Office (5)	
B00D - R0011 - Movement - (19.06 SQM)	Not Applicable	Circulation or storage space.
B00D - R0012 - Movement - (12.65 SQM)	Not Applicable	Circulation or storage space.
B00D - R0015 - Staff Room Annexe - (18.1 SQM)	 Office (4)	
B00D - R0016 - Principal - (19.75 SQM)	 Office (4)	
B00D - R0017 - Deputy Principal - (14.45 SQM)	 Office (3)	
B00D - R0018 - Sick Bay - (12.6 SQM)	 Student Space (5)	
B00D - R0019 - Clerical Office/Workroom - (14.2 SQM)	 Office (3)	
B00D - R0020 - Movement - (20.33 SQM)	Not Applicable	Circulation or storage space.
B00D - R0021 - Movement - (33.48 SQM)	Not Applicable	Circulation or storage space.
OS 606 19167 - OS 606 19167 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	