


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Bonville Public School (1297)</b>
<b>AMU REGION:</b>	<b>North Coast</b>
<b>STATE ELECTORATE:</b>	<b>Coffs Harbour</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Coffs Harbour</b>

1297 - Bonville Public School  
Site Plan (12429)



Printed: 26-May-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B001 - R0004 - Home Base - (56.78 SQM) - Teaching Space: 1	● Student Space (26)	
B001 - R0005 - Practical Activities - 1hb - (19.21 SQM)	● Student Space (8)	
B001 - R0008 - Practical Activities - 1hb - (20.78 SQM)	● Student Space (9)	
B001 - R0009 - Home Base - (47.6 SQM) - Teaching Space: 1	● Student Space (22)	
B001 - R0010 - Special Programs Room - (40.88 SQM)	● Student Space (18)	
B001 - R0011 - Practical Activities - 1hb - (15.36 SQM)	● Student Space (7)	
B001 - R0012 - Home Base - (61.38 SQM) - Teaching Space: 1	● Student Space (28)	
B001 - R0013 - Withdrawal Space - 1hb - (17.94 SQM)	● Student Space (8)	
B001 - R0015 - Canteen - (10.5 SQM)	Not Applicable	Circulation or storage space.
B001 - R0017 - Staff Kitchen - (5.19 SQM)	● Office (1)	
B001 - R0018 - Staff Room - (18.02 SQM)	● Office (4)	
B002 - R0001 - Principal - (13.39 SQM)	● Office (3)	
B002 - R0002 - Clerical Office - (10.12 SQM)	● Office (2)	
B002 - R0003 - Entry Vestibule - (11.49 SQM)	Not Applicable	Circulation or storage space.
B002 - R0005 - Home Base - (58.58 SQM) - Teaching Space: 1	● Student Space (27)	
B002 - R0007 - Practical Activities - 1hb - (17.94 SQM)	● Student Space (8)	
B002 - R0008 - Duplicating Workroom - (11.57 SQM)	● Office (2)	
B004 - R0001 - Reading Area - (91.56 SQM)	● Student Space (42)	
OS 602 13546 - OS 602 13546 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 801 14739 - OS 801 14739 - FSU - (57 SQM)	Not Applicable	Circulation or storage space.