


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Booragul Public School (4017)</b>
<b>AMU REGION:</b>	<b>Hunter/Central Coast</b>
<b>STATE ELECTORATE:</b>	<b>Lake Macquarie</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Lake Macquarie</b>



## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Staff Room Annexe - (19.68 SQM)	Office (4)	
B00A - R0002 - Staff Room - (45.61 SQM)	Office (11)	
B00A - R0004 - Movement - (33.69 SQM)	Not Applicable	Circulation or storage space.
B00A - R0006 - Interview - (13.05 SQM)	Office (3)	
B00A - R0007 - Staff Room Annexe - (13.11 SQM)	Office (3)	
B00A - R0008 - Staff Room Annexe - (13.19 SQM)	Office (3)	
B00A - R0010 - Sick Bay - (8.58 SQM)	Student Space (3)	
B00A - R0011 - Clerical Office - (17.77 SQM)	Office (4)	
B00A - R0012 - Entry Vestibule - (24.07 SQM)	Not Applicable	Circulation or storage space.
B00A - R0014 - Duplicating Workroom - (19.88 SQM)	Office (4)	
B00A - R0015 - Principal - (16.72 SQM)	Office (4)	
B00B - R0002 - Home Base - (57.2 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0004 - Movement - (13.77 SQM)	Not Applicable	Circulation or storage space.
B00B - R0006 - Home Base - (57.27 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0005 - Movement - (16.8 SQM)	Not Applicable	Circulation or storage space.
B00C - R0007 - Home Base - (58.84 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0006 - Raised Platform - (44.64 SQM)	Not Applicable	Circulation or storage space.
B00D - R0008 - Communal Space - (135.02 SQM)	Student Space (62)	
B00D - R0010 - Canteen - (26.97 SQM)	Not Applicable	Circulation or storage space.
B00E - R0005 - Staff Kitchen - (29.57 SQM)	Office (7)	
B00E - R0008 - Special Programs Room - (16.97 SQM)	Student Space (7)	
B00E - R0010 - Home Base - (76.55 SQM) - Teaching Space: 1	Student Space (35)	
B00E - R0014 - Withdrawal Space - 1hb - (13.79 SQM)	Student Space (6)	
B00E - R0021 - Home Base - (91.12 SQM) - Teaching Space: 1	Student Space (42)	
B00E - R0023 - Home Base - (72.05 SQM) - Teaching Space: 1	Student Space (33)	
B00E - R0026 - Home Base - (72.03 SQM) - Teaching Space: 1	Student Space (33)	
B00F - R0001 - Reading Area - (168.89 SQM)	Student Space (78)	
B00F - R0008 - Special Programs Room - (35.21 SQM)	Student Space (16)	
B00G - R0006 - Home Base - (60.25 SQM) - Teaching Space: 1	Student Space (27)	
B00G - R0008 - Practical Activities - 1hb - (15 SQM)	Student Space (6)	
B00G - R0009 - Withdrawal Space - 2hb - (11.51 SQM)	Student Space (5)	
B00G - R0010 - Home Base - (60.35 SQM) - Teaching Space: 1	Student Space (27)	
B00G - R0012 - Practical Activities - 1hb - (14.91 SQM)	Student Space (6)	
B00G - R0014 - Withdrawal Space - 1hb - (9.18 SQM)	Student Space (4)	
B00G - R0016 - Home Base - (58.93 SQM) - Teaching Space: 1	Student Space (27)	
B00G - R0017 - Practical Activities - 1hb - (14.93 SQM)	Student Space (6)	