

VENTILATION AUDIT REPORT

SCHOOL:	Boorowa Central School (1313)
AMU REGION:	Southern NSW
STATE ELECTORATE:	Goulburn
LOCAL GOVERNMENT AREA:	Hilltops

1313 - Boorowa Central School
Site Plan (13473)



1:509

Printed: 28-Jun-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0006 - Staff Room Annexe - (18.71 SQM)	Office (4)	
B00A - R0007 - Staff Room - (51.4 SQM)	Office (12)	
B00A - R0009 - Movement - (50.72 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Staff Room Annexe - (13.89 SQM)	Office (3)	
B00A - R0012 - Sick Bay - (13.89 SQM)	Student Space (6)	
B00A - R0016 - Sick Bay - (13.89 SQM)	Student Space (6)	
B00A - R0019 - Interview - (13.89 SQM)	Office (3)	
B00A - R0020 - Duplicating Workroom - (31.17 SQM)	Office (7)	
B00A - R0021 - Clerical Office/Workroom - (35.22 SQM)	Office (8)	
B00A - R0023 - Movement - (6.21 SQM)	Not Applicable	Circulation or storage space.
B00A - R0024 - Principal - (14.55 SQM)	Office (3)	
B00A - R0026 - Entry Vestibule - (22.21 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Staff Room Annexe - (17.58 SQM)	Office (4)	
B00B - R0002 - Home Base - (47.33 SQM) - Teaching Space: 1	Student Space (21)	
B00B - R0003 - Movement - (36.23 SQM)	Not Applicable	Circulation or storage space.
B00B - R0005 - Movement - (19.53 SQM)	Not Applicable	Circulation or storage space.
B00B - R0008 - Home Base - (44.59 SQM) - Teaching Space: 1	Student Space (20)	
B00B - R0009 - Home Base - (43.77 SQM) - Teaching Space: 1	Student Space (20)	
B00B - R0010 - Home Base - (44.04 SQM) - Teaching Space: 1	Student Space (20)	
B00B - R0012 - Staff Study - (13.63 SQM)	Office (3)	
B00B - R0013 - Movement - (8.46 SQM)	Not Applicable	Circulation or storage space.
B00B - R0014 - Outdoor Learning Area - (181.63 SQM)	Not Applicable	Circulation or storage space.
B00B - R0015 - Special Learning Space - (29.87 SQM) - Teaching Space: 1	Student Space (13)	
B00B - R0016 - Seminar - Type 1 - (13.59 SQM)	Office (3)	
B00D - R0001 - Home Base - (67.17 SQM) - Teaching Space: 1	Student Space (31)	
B00D - R0003 - Withdrawal Space - 1hb - (10.79 SQM)	Student Space (5)	
B00D - R0004 - Practical Activities - 1hb - (9.88 SQM)	Student Space (4)	
B00D - R0005 - Movement - (5.42 SQM)	Not Applicable	Circulation or storage space.
B00D - R0006 - Home Base - (67.06 SQM) - Teaching Space: 1	Student Space (31)	
B00D - R0007 - Home Base - (47.93 SQM) - Teaching Space: 1	Student Space (22)	
B00D - R0008 - Practical Activities - 1hb - (8.73 SQM)	Student Space (4)	
B00E - R0005 - Staff Room Annexe - (8.69 SQM)	Office (2)	
B00E - R0010 - Movement - (58.06 SQM)	Not Applicable	Circulation or storage space.
B00E - R0011 - Movement - (5.83 SQM)	Not Applicable	Circulation or storage space.
B00E - R0012 - Movement - (5.84 SQM)	Not Applicable	Circulation or storage space.
B00E - R0013 - Raised Platform - (65.84 SQM)	Not Applicable	Circulation or storage space.
B00E - R0019 - Canteen - (50.75 SQM)	Not Applicable	Circulation or storage space.
B00E - R0024 - Communal Space - (480.31 SQM)	Student Space (222)	
B00F - R0001 - General Learning Space - (53.15 SQM)	Student Space (24)	
B00F - R0002 - Reading Area - (189.92 SQM)	Student Space (88)	
B00F - R0011 - Seminar/Study - (12.86 SQM)	Office (3)	
B00F - R0012 - Special Programs Room - (12.75 SQM)	Student Space (5)	
B00G - R0001 - Preparation - (9.54 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Preparation - (29.44 SQM)	Not Applicable	Circulation or storage space.
B00G - R0003 - Laboratory L.S. - (92.98 SQM) - Teaching Space: 1	Student Space (43)	
B00G - R0005 - Entry Vestibule - (15.18 SQM)	Not Applicable	Circulation or storage space.
B00G - R0006 - Staff Room Annexe - (20.34 SQM)	Office (5)	
B00G - R0015 - Seminar/Study - (24.9 SQM)	Office (6)	
B00G - R0019 - Design/Technology L.S. - (65.6 SQM) - Teaching Space: 1	Student Space (30)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R0020 - Staff Room Annexe - (12.82 SQM)	Office (3)	
B00G - R0021 - Staff Room Annexe - (12.82 SQM)	Office (3)	
B00H - R0001 - Preparation - (31.97 SQM)	Not Applicable	Circulation or storage space.
B00H - R0004 - Laboratory L.S. - (81.28 SQM) - Teaching Space: 1	Student Space (37)	
B00H - R0005 - Food Technology L.S. - (95.73 SQM) - Teaching Space: 1	Student Space (44)	
B00H - R0008 - Food/Research Space - (10.04 SQM)	Not Applicable	Circulation or storage space.
B00H - R0009 - Staff Room Annexe - (29.29 SQM)	Office (7)	
B00H - R0011 - General Learning Space - (46.51 SQM) - Teaching Space: 1	Student Space (21)	
B00I - R0001 - Materials Technology L.S. - (79.73 SQM) - Teaching Space: 1	Student Space (36)	
B00I - R0002 - Materials Technology L.S. - (101.41 SQM) - Teaching Space: 1	Student Space (47)	
B00J - R0001 - Art Learning Space - (65.02 SQM) - Teaching Space: 1	Student Space (30)	
B00J - R0006 - Music Learning Space - (64.99 SQM) - Teaching Space: 1	Student Space (30)	
B00J - R0013 - Computer Learning Space - (32.83 SQM) - Teaching Space: 1	Student Space (15)	
B00J - R0014 - Computer Learning Space - (48.13 SQM) - Teaching Space: 1	Student Space (22)	
B00J - R0015 - General Learning Space - (48.06 SQM) - Teaching Space: 1	Student Space (22)	
B00J - R0016 - Staff Room Annexe - (25.47 SQM)	Office (6)	
B00J - R0018 - Movement - (70.02 SQM)	Not Applicable	Circulation or storage space.
B00J - R0019 - General Learning Space - (47.52 SQM) - Teaching Space: 1	Student Space (22)	
B00J - R0020 - General Learning Space - (47.81 SQM) - Teaching Space: 1	Student Space (22)	
B00J - R0022 - Staff Study - (17.24 SQM)	Office (4)	
B00J - R1001 - General Learning Space - (48.35 SQM) - Teaching Space: 1	Student Space (22)	
B00J - R1002 - General Learning Space - (48.35 SQM) - Teaching Space: 1	Student Space (22)	
B00J - R1003 - Movement - (18.57 SQM)	Not Applicable	Circulation or storage space.
B00L - R0004 - Special Learning Space - (39.78 SQM) - Teaching Space: 1	Student Space (18)	
B00L - R0007 - Staff Room Annexe - (5.57 SQM)	Office (1)	
B00L - R0010 - Materials Learning Space - Type 1 - (59.93 SQM) - Teaching Space: 1	Student Space (27)	
B00M - R0001 - T.A.S. Outdoor Area - (54.24 SQM)	Not Applicable	Circulation or storage space.
B00N - R0001 - Welding Area - (6.35 SQM)	Not Applicable	Circulation or storage space.
B00N - R0006 - Materials Technology L.S. - (162.03 SQM) - Teaching Space: 1	Student Space (75)	
B00N - R0010 - Seminar/Technology Space - (41.23 SQM)	Office (10)	