


VENTILATION AUDIT REPORT

SCHOOL:	Boronia Park Public School (1320)
AMU REGION:	Northern Sydney
STATE ELECTORATE:	Lane Cove
LOCAL GOVERNMENT AREA:	Hunters Hill

1320 - Boronia Park Public School
Site Plan (10076)
















1:728

Printed: 15-May-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0004 - Sick Bay - (6.96 SQM)	● Student Space (3)	
B00A - R0005 - Entry Vestibule - (12.78 SQM)	Not Applicable	Circulation or storage space.
B00A - R0007 - Principal - (15.96 SQM)	● Office (3)	
B00A - R0015 - Home Base - (70.37 SQM) - Teaching Space: 1	● Student Space (32)	
B00A - R0027 - Clerical Office - (14.76 SQM)	● Office (3)	
B00A - R0029 - Clerical Office - (6.04 SQM)	● Office (1)	
B00A - R0030 - Interview/Office - Type 3 - (12.84 SQM)	● Office (3)	
B00A - R0037 - Clerical/Printing - (15.83 SQM)	Not Applicable	Circulation or storage space.
B00A - R0038 - Staff Room - (59.2 SQM)	● Office (14)	
B00A - R0039 - Staff Kitchen - (17.49 SQM)	● Office (4)	
B00A - R0040 - Staff Kitchen - (28.16 SQM)	● Office (7)	
B00A - R0043 - Movement - (13.5 SQM)	Not Applicable	Circulation or storage space.
B00A - R0044 - Deputy Principal - (13.85 SQM)	● Office (3)	
B00A - R0045 - Clerical Office - (10.4 SQM)	● Office (2)	
B00A - R1009 - Reading Area - (52.72 SQM)	● Student Space (24)	
B00A - R1010 - Reading Area - (213.68 SQM)	● Student Space (99)	
B00B - R0001 - Canteen - (22.93 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Practical Activities - 1hb - (41.37 SQM)	● Student Space (19)	
B00C - R0007 - Special Programs Room - (31.8 SQM)	● Student Space (14)	
B00D - R0001 - Home Base - (54.49 SQM) - Teaching Space: 1	● Student Space (25)	
B00D - R0002 - Home Base - (54.48 SQM) - Teaching Space: 1	● Student Space (25)	
B00F - R0003 - Movement - (16.15 SQM)	Not Applicable	Circulation or storage space.
B00F - R0007 - Practical Activities - 1hb - (21.55 SQM)	● Student Space (9)	
B00F - R0008 - Home Base - (63.3 SQM) - Teaching Space: 1	● Student Space (29)	
B00F - R0009 - Movement - (16.08 SQM)	Not Applicable	Circulation or storage space.
B00F - R0013 - Raised Platform - (18.35 SQM)	Not Applicable	Circulation or storage space.
B00F - R0014 - Communal Space - (123.51 SQM)	● Student Space (57)	
B00F - R0015 - Movement - (35.65 SQM)	Not Applicable	Circulation or storage space.
B00F - R0019 - Movement - (16.12 SQM)	Not Applicable	Circulation or storage space.
B00F - R0020 - Home Base - (63.04 SQM) - Teaching Space: 1	● Student Space (29)	
B00F - R0021 - Practical Activities - 1hb - (21.54 SQM)	● Student Space (9)	
B00F - R0024 - Movement - (16.34 SQM)	Not Applicable	Circulation or storage space.
B00F - R1001 - Staff Room Annexe - (18.34 SQM)	● Office (4)	
B00F - R1002 - Movement - (5.17 SQM)	Not Applicable	Circulation or storage space.
B00F - R1005 - Home Base - (48.94 SQM) - Teaching Space: 1	● Student Space (22)	
B00F - R1006 - Home Base - (48.61 SQM) - Teaching Space: 1	● Student Space (22)	
B00F - R1007 - Home Base - (48.87 SQM) - Teaching Space: 1	● Student Space (22)	
B00F - R1008 - Home Base - (48.67 SQM) - Teaching Space: 1	● Student Space (22)	
B00F - R1012 - Movement - (5.15 SQM)	Not Applicable	Circulation or storage space.
B00F - R1014 - Movement - (71.53 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Practical Activities - 1hb - (19.5 SQM)	● Student Space (9)	
B00G - R0005 - Home Base - (58.11 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R0007 - Withdrawal Space - 1hb - (13.1 SQM)	● Student Space (6)	
B00G - R0009 - Home Base - (58.11 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R1002 - Practical Activities - 1hb - (19.5 SQM)	● Student Space (9)	
B00G - R1005 - Home Base - (58.11 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R1007 - Withdrawal Space - 1hb - (13.1 SQM)	● Student Space (6)	
B00G - R1009 - Home Base - (58.1 SQM) - Teaching Space: 1	● Student Space (26)	
B00R - R0001 - Home Base - (60.57 SQM) - Teaching Space: 1	● Student Space (28)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00R - R0002 - Home Base - (60.41 SQM) - Teaching Space: 1	 Student Space (28)	
B00R - R0005 - Practical Activities - 1hb - (19.3 SQM)	 Student Space (8)	
B00R - R0006 - Withdrawal Space - 2hb - (11.75 SQM)	 Student Space (5)	
B00R - R0007 - Practical Activities - 1hb - (19.01 SQM)	 Student Space (8)	
B00R - R1001 - Home Base - (60.14 SQM) - Teaching Space: 1	 Student Space (27)	
B00R - R1002 - Home Base - (60.14 SQM) - Teaching Space: 1	 Student Space (27)	
B00R - R1004 - Practical Activities - 1hb - (19.04 SQM)	 Student Space (8)	
B00R - R1005 - Withdrawal Space - 2hb - (11.75 SQM)	 Student Space (5)	
B00R - R1006 - Practical Activities - 1hb - (19.04 SQM)	 Student Space (8)	
OS 602 10004 - OS 602 10004 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 11070 - OS 602 11070 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 15877 - OS 602 15877 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 606 16832 - OS 606 16832 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	