

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Bossley Park High School (8582)</b>
<b>AMU REGION:</b>	<b>South Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Prospect</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Fairfield</b>

8582 - Bossley Park High School  
Site Plan (10908)






## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - M0002 - Tiered Learning Area - (22.04 SQM)	Student Space (10)	
B00A - R0003 - Staff Study - (15.5 SQM)	Office (3)	
B00A - R0004 - General Learning Space - (48.3 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R0006 - General Learning Space - (41.01 SQM) - Teaching Space: 1	Student Space (19)	
B00A - R0007 - General Learning Space - (47.99 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R0008 - Study Space - (15.66 SQM)	Not Applicable	Circulation or storage space.
B00A - R0009 - General Learning Space - (48.04 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R0011 - Main Area - (437.71 SQM)	Not Applicable	Circulation or storage space.
B00A - R0014 - Seminar - (19.32 SQM)	Office (4)	
B00A - R0015 - Seminar - (19.24 SQM)	Office (4)	
B00A - R0016 - Audio Visual Workroom - (31.14 SQM)	Student Space (14)	
B00A - R0021 - General Learning Space - (47.84 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R0023 - General Learning Space - (48.05 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R0024 - General Learning Space - (41.1 SQM) - Teaching Space: 1	Student Space (19)	
B00A - R0026 - General Learning Space - (47.69 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R0028 - General Learning Space - (51.97 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R0029 - General Learning Space - (52.08 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R0031 - General Learning Space - (40.48 SQM) - Teaching Space: 1	Student Space (18)	
B00A - R0041 - Deputy Principal Office - (13.58 SQM)	Office (3)	
B00A - R0045 - Administration - Clerical - (13.21 SQM)	Office (3)	
B00A - R0046 - Leading Teacher - (12.46 SQM)	Office (3)	
B00A - R0063 - Special Learning Space - (47.97 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R0065 - Special Learning Space - (38.95 SQM) - Teaching Space: 1	Student Space (18)	
B00A - R0067 - Staff Study - (39.33 SQM)	Office (9)	
B00A - R0069 - Darkroom Space - (12.07 SQM)	Office (3)	
B00A - R0071 - Dark Room - (16.53 SQM)	Office (4)	
B00A - R0072 - Tiered Learning Area - (41.46 SQM)	Student Space (19)	
B00A - R0073 - Staff Study - (38.84 SQM)	Office (9)	
B00A - R0076 - Movement - (537.39 SQM)	Not Applicable	Circulation or storage space.
B00A - R0078 - Tea Room - (5.26 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - General Learning Space - (47.68 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1002 - General Learning Space - (48.34 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1003 - Senior Study - (15.62 SQM)	Office (3)	
B00A - R1004 - General Learning Space - (47.73 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1005 - General Learning Space - (47.38 SQM) - Teaching Space: 1	Student Space (21)	
B00A - R1006 - General Learning Space - (47.37 SQM) - Teaching Space: 1	Student Space (21)	
B00A - R1007 - General Learning Space - (48.17 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1008 - Senior Study - (15.5 SQM)	Office (3)	
B00A - R1009 - General Learning Space - (48.1 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1012 - General Learning Space - (63 SQM) - Teaching Space: 1	Student Space (29)	
B00A - R1013 - Interview/Office - Type 1 - (13.53 SQM)	Office (3)	
B00A - R1014 - Interview/Office - Type 1 - (13.53 SQM)	Office (3)	
B00A - R1015 - Computer Learning Space - (47.69 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1016 - Seminar - Type 1 - (15.63 SQM)	Office (3)	
B00A - R1017 - General Learning Space - (48.17 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1018 - General Learning Space - (47.57 SQM) - Teaching Space: 1	Student Space (22)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R1019 - General Learning Space - (47.79 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1020 - General Learning Space - (48.04 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1021 - Leading Teacher - (15.59 SQM)	Office (3)	
B00A - R1022 - General Learning Space - (48.18 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1023 - General Learning Space - (47.82 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1025 - General Learning Space - (40.2 SQM) - Teaching Space: 1	Student Space (18)	
B00A - R1026 - Staff Study - (14.8 SQM)	Office (3)	
B00A - R1032 - General Learning Space - (40.55 SQM) - Teaching Space: 1	Student Space (18)	
B00A - R1034 - General Learning Space - (40.35 SQM) - Teaching Space: 1	Student Space (18)	
B00A - R1040 - Staff Study - (14.67 SQM)	Office (3)	
B00A - R1043 - Movement - (452.69 SQM)	Not Applicable	Circulation or storage space.
B00A - R1047 - Staff Study - (38.97 SQM)	Office (9)	
B00A - R1049 - Staff Study - (27.86 SQM)	Office (6)	
B00A - R1051 - Commonroom - (72.81 SQM)	Office (18)	
B00A - R1052 - Tea Room - (8.05 SQM)	Not Applicable	Circulation or storage space.
B00A - R1053 - Commonroom - (32.83 SQM)	Office (8)	
B00A - R1054 - Staff Study - (27.81 SQM)	Office (6)	
B00B - R0005 - Laboratory L.S. - (81.2 SQM) - Teaching Space: 1	Student Space (37)	
B00B - R0006 - Computer Learning Space - (31.96 SQM) - Teaching Space: 1	Student Space (14)	
B00B - R0007 - Laboratory L.S. - (80.93 SQM) - Teaching Space: 1	Student Space (37)	
B00B - R0010 - Laboratory L.S. - (80.84 SQM) - Teaching Space: 1	Student Space (37)	
B00B - R0012 - Laboratory L.S. - (80.66 SQM) - Teaching Space: 1	Student Space (37)	
B00B - R0017 - Laboratory L.S. - (81.11 SQM) - Teaching Space: 1	Student Space (37)	
B00B - R0018 - Preparation - Science - (32.02 SQM)	Not Applicable	Circulation or storage space.
B00B - R0019 - Laboratory L.S. - (81.29 SQM) - Teaching Space: 1	Student Space (37)	
B00B - R0020 - Movement - (119.4 SQM)	Not Applicable	Circulation or storage space.
B00B - R0021 - Staff Study - (38.85 SQM)	Office (9)	
B00C - R0002 - Growing/Breeding - (7.87 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Art Learning Space - (61.59 SQM) - Teaching Space: 1	Student Space (28)	
B00D - R0002 - Art Learning Space - (61.41 SQM) - Teaching Space: 1	Student Space (28)	
B00D - R0003 - Art Learning Space - (61.64 SQM) - Teaching Space: 1	Student Space (28)	
B00D - R0005 - Art Learning Space - (62.56 SQM) - Teaching Space: 1	Student Space (29)	
B00D - R0008 - Computer Learning Space - (56.91 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0010 - Computer Learning Space - (56.91 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0011 - Materials Workshop - Type 2 - (68.03 SQM)	Student Space (31)	
B00D - R0012 - Welding Area - (12.12 SQM)	Not Applicable	Circulation or storage space.
B00D - R0016 - Metal Technology L.S. - (91.05 SQM) - Teaching Space: 1	Student Space (42)	
B00D - R0017 - Metal Technology Bay - (33.55 SQM)	Not Applicable	Circulation or storage space.
B00D - R0021 - Wood Technology L.S. - (89.75 SQM) - Teaching Space: 1	Student Space (41)	
B00D - R0022 - Wood Technology Bay - (32.28 SQM)	Not Applicable	Circulation or storage space.
B00D - R0023 - Wood Technology L.S. - (89.73 SQM) - Teaching Space: 1	Student Space (41)	
B00D - R0030 - Seminar - Type 1 - (22.07 SQM)	Office (5)	
B00D - R0036 - Workshop - (53.89 SQM)	Student Space (25)	
B00D - R0038 - Staff Study - (20.88 SQM)	Office (5)	
B00D - R0040 - Staff Study - (29.54 SQM)	Office (7)	
B00D - R0042 - Metal Technology L.S. - (42.62 SQM) - Teaching Space: 1	Student Space (19)	
B00D - R0043 - Metal Technology Bay - (46.23 SQM)	Not Applicable	Circulation or storage space.
B00E - R0004 - Administration - Clerical - (38.68 SQM)	Office (9)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R0006 - Deputy Principal Office - (15.96 SQM)	Office (3)	
B00E - R0007 - Interview/Office - Type 1 - (13.05 SQM)	Office (3)	
B00E - R0008 - Clinic - (13.77 SQM)	Office (3)	
B00E - R0013 - Administration - Clerical - (13.61 SQM)	Office (3)	
B00E - R0014 - Principal Office - (19.41 SQM)	Office (4)	
B00E - R0015 - Movement - (20.77 SQM)	Not Applicable	Circulation or storage space.
B00E - R0016 - Public Reception - (27.38 SQM)	Not Applicable	Circulation or storage space.
B00E - R0017 - Movement - (43.29 SQM)	Not Applicable	Circulation or storage space.
B00E - R0018 - Deputy Principal Office - (14.8 SQM)	Office (3)	
B00E - R0023 - Pupil Entry - (9.42 SQM)	Not Applicable	Circulation or storage space.
B00E - R0024 - Ancillary Staff - (16.56 SQM)	Office (4)	
B00E - R0026 - Administration - Clerical - (20.2 SQM)	Office (5)	
B00F - R0004 - Movement - (74.63 SQM)	Not Applicable	Circulation or storage space.
B00F - R0010 - Multi-Purpose Space - (458.55 SQM)	Student Space (212)	
B00F - R0013 - Movement - (13.67 SQM)	Not Applicable	Circulation or storage space.
B00F - R0026 - Student Canteen - (62.49 SQM)	Not Applicable	Circulation or storage space.
B00F - R0028 - General Assistants - (13.81 SQM)	Office (3)	
B00F - R0035 - Stage - (91.59 SQM)	Not Applicable	Circulation or storage space.
B00F - R0037 - Interview/Meeting - (17.52 SQM)	Office (4)	
B00F - R0045 - Movement - (24.58 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Music Learning Space - (76.65 SQM) - Teaching Space: 1	Student Space (35)	
B00G - R0002 - Music Learning Space - (62.38 SQM) - Teaching Space: 1	Student Space (28)	
B00G - R0003 - Practice/Seminar - (26.75 SQM)	Not Applicable	Circulation or storage space.
B00G - R0008 - Practice/Seminar - (24.01 SQM)	Not Applicable	Circulation or storage space.
B00G - R0010 - Textiles Technology L.S. - (68.56 SQM) - Teaching Space: 1	Student Space (31)	
B00G - R0011 - Textiles Technology L.S. - (69.24 SQM) - Teaching Space: 1	Student Space (32)	
B00G - R0017 - Food Technology L.S. - (103.1 SQM) - Teaching Space: 1	Student Space (47)	
B00G - R0019 - Preparation - Materials - (21.47 SQM)	Not Applicable	Circulation or storage space.
B00G - R0020 - Food Technology L.S. - (102.87 SQM) - Teaching Space: 1	Student Space (47)	
B00G - R0021 - Movement - (83.02 SQM)	Not Applicable	Circulation or storage space.
B00G - R0026 - Staff Study - (23.89 SQM)	Office (5)	
B00G - R0030 - Movement - (49.97 SQM)	Not Applicable	Circulation or storage space.
B00G - R0033 - Staff Study - (22.53 SQM)	Office (5)	
B00H - R0007 - Special Learning Space - (119.13 SQM) - Teaching Space: 1	Student Space (55)	
B00H - R0008 - Performance Workshop - (128.2 SQM)	Student Space (59)	
B00K - R0001 - Fitness Laboratory - (105.29 SQM)	Student Space (48)	
B00L - R0001 - General Learning Space - (125.23 SQM) - Teaching Space: 1	Student Space (58)	
B00L - R0002 - Staff Study - (83.63 SQM)	Office (20)	
B00L - R0003 - Tea Room - (6.02 SQM)	Not Applicable	Circulation or storage space.
B00L - R0009 - Movement Studio - (124.58 SQM)	Not Applicable	Circulation or storage space.
NS 110 15241 - NS 110 15241 - Learning Unit - Single Secondary/Secure - (57 SQM)	Student Space (26)	
NS 111 15201 - NS 111 15201 - Learning Unit - Double Secondary/Secure - (114 SQM)	Student Space (52)	
NS 200 12138 - NS 200 12138 - Art Learning Space/Workshop/Bulk Store - (95 SQM)	Not Applicable	Circulation or storage space.
OS 600 10502 - OS 600 10502 - Learning Unit - Small - (57 SQM)	Student Space (26)	
OS 600 10827 - OS 600 10827 - Learning Unit - Small - (57 SQM)	Student Space (26)	
OS 600 11167 - OS 600 11167 - Learning Unit - Small - (57 SQM)	Student Space (26)	
OS 600 11551 - OS 600 11551 - Learning Unit - Small - (57 SQM)	Student Space (26)	
OS 600 11604 - OS 600 11604 - Learning Unit - Small - (57 SQM)	Student Space (26)	
OS 600 11821 - OS 600 11821 - Learning Unit - Small - (57 SQM)	Student Space (26)	
OS 600 12146 - OS 600 12146 - Learning Unit - Small - (57 SQM)	Student Space (26)	

Entity Location	Audit Condition Classification (Capacity)	Comment
OS 600 15970 - OS 600 15970 - Learning Unit - Small - (57 SQM)	 Student Space (26)	
OS 601 11468 - OS 601 11468 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 710 10791 - OS 710 10791 - Home Science/Pantry/Laundry - (95 SQM)	 Office (23)	
OS 720 11810 - OS 720 11810 - Science Laboratory/Prep Room - (114 SQM)	Not Applicable	Circulation or storage space.
OS 720 15971 - OS 720 15971 - Science Laboratory/Prep Room - (114 SQM)	Not Applicable	Circulation or storage space.