

VENTILATION AUDIT REPORT

SCHOOL:	Bossley Park Public School (1321)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Prospect
LOCAL GOVERNMENT AREA:	Fairfield

1321 - Bossley Park Public School
Site Plan (13025)



1:973

Printed: 06-Nov-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Deputy Principal - (12.43 SQM)	Office (3)	
B00A - R0002 - Principal - (17.62 SQM)	Office (4)	
B00A - R0003 - Clerical Office - (12.43 SQM)	Office (3)	
B00A - R0004 - Entry Vestibule - (8.95 SQM)	Not Applicable	Circulation or storage space.
B00A - R0005 - Movement - (11.71 SQM)	Not Applicable	Circulation or storage space.
B00A - R0012 - Staff Room - (82.41 SQM)	Office (20)	
B00A - R0014 - Movement - (29.85 SQM)	Not Applicable	Circulation or storage space.
B00A - R0015 - Interview - (12.27 SQM)	Office (3)	
B00A - R0016 - Movement - (8.45 SQM)	Not Applicable	Circulation or storage space.
B00A - R0017 - Sick Bay - (10.44 SQM)	Student Space (4)	
B00A - R0019 - Clerical Office - (12.14 SQM)	Office (3)	
B00A - R0020 - Duplicating Workroom - (34.38 SQM)	Office (8)	
B00A - R0021 - Movement - (44.96 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Practical Activities - 1hb - (32.61 SQM)	Student Space (15)	
B00B - R0002 - Home Base - (63.58 SQM) - Teaching Space: 1	Student Space (29)	
B00B - R0003 - Withdrawal Space - 1hb - (11.72 SQM)	Student Space (5)	
B00B - R0004 - Home Base - (63.87 SQM) - Teaching Space: 1	Student Space (29)	
B00B - R0008 - Movement - (14.78 SQM)	Not Applicable	Circulation or storage space.
B00B - R0009 - Movement - (52.34 SQM)	Not Applicable	Circulation or storage space.
B00B - R1001 - Practical Activities - 1hb - (32.92 SQM)	Student Space (15)	
B00B - R1002 - Home Base - (63.84 SQM) - Teaching Space: 1	Student Space (29)	
B00B - R1003 - Withdrawal Space - 1hb - (11.65 SQM)	Student Space (5)	
B00B - R1004 - Home Base - (63.26 SQM) - Teaching Space: 1	Student Space (29)	
B00B - R1008 - Movement - (56.82 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Practical Activities - 1hb - (31.44 SQM)	Student Space (14)	
B00C - R0002 - Home Base - (63.62 SQM) - Teaching Space: 1	Student Space (29)	
B00C - R0003 - Withdrawal Space - 1hb - (11.82 SQM)	Student Space (5)	
B00C - R0004 - Home Base - (63.87 SQM) - Teaching Space: 1	Student Space (29)	
B00C - R0008 - Movement - (15.54 SQM)	Not Applicable	Circulation or storage space.
B00C - R0015 - Movement - (52.58 SQM)	Not Applicable	Circulation or storage space.
B00C - R1001 - Home Base - (63.37 SQM) - Teaching Space: 1	Student Space (29)	
B00C - R1002 - Withdrawal Space - 1hb - (11.82 SQM)	Student Space (5)	
B00C - R1003 - Practical Activities - 1hb - (32.57 SQM)	Student Space (15)	
B00C - R1004 - Home Base - (63.66 SQM) - Teaching Space: 1	Student Space (29)	
B00C - R1005 - Movement - (54.73 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Reading Area - (230.81 SQM)	Student Space (107)	
B00D - R0006 - Special Programs Room - (43.12 SQM)	Student Space (20)	
B00D - R0011 - Movement - (83.53 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Movement - (17.35 SQM)	Not Applicable	Circulation or storage space.
B00E - R0003 - Interview - (9.34 SQM)	Office (2)	
B00E - R0005 - Interview - (13.39 SQM)	Office (3)	
B00E - R0006 - Home Base - (53.58 SQM) - Teaching Space: 1	Student Space (24)	
B00F - R0003 - Movement - (5.02 SQM)	Not Applicable	Circulation or storage space.
B00F - R0005 - Special Programs Room - (53.56 SQM)	Student Space (24)	
B00F - R1003 - Home Base - (86.18 SQM) - Teaching Space: 1	Student Space (39)	
B00F - R1007 - Home Base - (57.11 SQM) - Teaching Space: 1	Student Space (26)	
B00F - R1008 - Movement - (39.98 SQM)	Not Applicable	Circulation or storage space.
B00G - R0004 - Communal Space - (198.34 SQM)	Student Space (92)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R0005 - Raised Platform - (55.7 SQM)	Not Applicable	Circulation or storage space.
B00G - R0014 - Movement - (136.75 SQM)	Not Applicable	Circulation or storage space.
B00K - R0002 - Movement - (9.96 SQM)	Not Applicable	Circulation or storage space.
B00K - R0003 - Movement - (11.3 SQM)	Not Applicable	Circulation or storage space.
B00K - R0004 - Movement - (20.88 SQM)	Not Applicable	Circulation or storage space.
B00K - R0005 - Home Base - (48.36 SQM) - Teaching Space: 1	● Student Space (22)	
B00K - R0006 - Home Base - (48.23 SQM) - Teaching Space: 1	● Student Space (22)	
B00L - R0003 - Movement - (11.74 SQM)	Not Applicable	Circulation or storage space.
B00M - R0001 - Canteen - (42.83 SQM)	Not Applicable	Circulation or storage space.
B00N - R0001 - Practical Activities - 1hb - (18.92 SQM)	● Student Space (8)	
B00N - R0002 - Home Base - (59.39 SQM) - Teaching Space: 1	● Student Space (27)	
B00N - R0004 - Withdrawal Space - 1hb - (7.66 SQM)	● Student Space (3)	
B00N - R0005 - Practical Activities - 1hb - (19.06 SQM)	● Student Space (8)	
B00N - R0006 - Home Base - (61.33 SQM) - Teaching Space: 1	● Student Space (28)	
B00N - R0008 - Withdrawal Space - 2hb - (11.78 SQM)	● Student Space (5)	
B00N - R0009 - Practical Activities - 1hb - (19.78 SQM)	● Student Space (9)	
B00N - R0010 - Home Base - (61.22 SQM) - Teaching Space: 1	● Student Space (28)	
B00N - R0020 - Movement - (5.16 SQM)	Not Applicable	Circulation or storage space.
B00N - R0021 - Special Programs Room - (33.31 SQM)	● Student Space (15)	
NS 250 11769 - NS 250 11769 - Learning Unit - Single E.S.L./Store - (38 SQM)	● Student Space (17)	
OS 601 10962 - OS 601 10962 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 15967 - OS 601 15967 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 602 13840 - OS 602 13840 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	