

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Bourke Public School (1326)</b>
<b>AMU REGION:</b>	<b>North Western NSW</b>
<b>STATE ELECTORATE:</b>	<b>Barwon</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Bourke</b>

1326 - Bourke Public School  
Site Plan (10909)













1:2,258

Printed: 05-Apr-2021

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (79.64 SQM)	Not Applicable	Circulation or storage space.
B00A - R0005 - Practical Activities - 1hb - (16.73 SQM)	● Student Space (7)	
B00A - R0006 - Withdrawal Space - 1hb - (16.81 SQM)	● Student Space (7)	
B00A - R0007 - Movement - (10.59 SQM)	Not Applicable	Circulation or storage space.
B00A - R0009 - Staff Room - (50.8 SQM)	● Office (12)	
B00A - R0010 - Duplicating Workroom - (11.26 SQM)	● Office (2)	
B00A - R0011 - Sick Bay - (9.15 SQM)	● Student Space (4)	
B00A - R0012 - Movement - (7.55 SQM)	Not Applicable	Circulation or storage space.
B00A - R0017 - Entry Vestibule - (16.1 SQM)	Not Applicable	Circulation or storage space.
B00A - R0018 - Clerical Office - (14.06 SQM)	● Office (3)	
B00A - R0019 - Clerical Office/Workroom - (14.09 SQM)	● Office (3)	
B00A - R0021 - Movement - (6.01 SQM)	Not Applicable	Circulation or storage space.
B00A - R0026 - Movement - (82.13 SQM)	Not Applicable	Circulation or storage space.
B00A - R0030 - Principal - (17.48 SQM)	● Office (4)	
B00B - R0001 - Movement - (67.58 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Home Base - (57.21 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R0005 - Home Base - (57.21 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R0009 - Home Base - (56.98 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R0010 - Special Programs Room - (57.14 SQM)	● Student Space (26)	
B00B - R0014 - Movement - (68.18 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Home Base - (51.66 SQM) - Teaching Space: 1	● Student Space (23)	
B00C - R0003 - Practical Activities - 1hb - (19.6 SQM)	● Student Space (9)	
B00C - R0004 - Home Base - (51.51 SQM) - Teaching Space: 1	● Student Space (23)	
B00C - R0005 - Practical Activities - 1hb - (19.53 SQM)	● Student Space (9)	
B00C - R0006 - Home Base - S - (57.46 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R0007 - Movement - (5.66 SQM)	Not Applicable	Circulation or storage space.
B00C - R0011 - Movement - (123.94 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Movement - (67.09 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Home Base - (57.13 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R0005 - Home Base - (57.21 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R0008 - Home Base - (57.21 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R0011 - Home Base - (57.39 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R0015 - Movement - (67.22 SQM)	Not Applicable	Circulation or storage space.
B00E - R0011 - Reading Area - (131.35 SQM)	● Student Space (60)	
B00E - R0012 - Special Programs Room - (13.95 SQM)	● Student Space (6)	
B00E - R0017 - Withdrawal Space - 1hb - (22.61 SQM)	● Student Space (10)	
B00E - R0018 - Withdrawal Space - 1hb - (11.23 SQM)	● Student Space (5)	
B00F - R0001 - Movement - (175.32 SQM)	Not Applicable	Circulation or storage space.
B00F - R0005 - Canteen - (33.06 SQM)	Not Applicable	Circulation or storage space.
B00L - R0002 - Practical Activities - (30.4 SQM)	● Student Space (14)	
B00L - R0003 - Movement - (5.26 SQM)	Not Applicable	Circulation or storage space.
B00M - R0012 - Communal Space - (207.19 SQM)	● Student Space (96)	
B00N - R0001 - Clerical Office - (17.57 SQM)	● Office (4)	
B00N - R0002 - Clerical Office - (17.57 SQM)	● Office (4)	
B00N - R0003 - Clerical Office - (35.87 SQM)	● Office (8)	
B00N - R0004 - Breakout Area - (35.35 SQM)	Not Applicable	Circulation or storage space.
B00N - R0005 - Computer Room - (70.48 SQM)	● Student Space (32)	
B00R - R0001 - Practical Activities - (16.84 SQM)	● Student Space (7)	
B00R - R0002 - Staff Room Annexe - (36.56 SQM)	● Office (9)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00R - R0003 - Movement - (8.7 SQM)	Not Applicable	Circulation or storage space.
B00S - R0001 - Clerical Office - (17.75 SQM)	 Office (4)	
B00S - R0002 - Movement - (8.43 SQM)	Not Applicable	Circulation or storage space.
B00S - R0004 - Home Base - (53.91 SQM) - Teaching Space: 1	 Student Space (25)	
B00T - R0001 - Movement - (7.14 SQM)	Not Applicable	Circulation or storage space.
B00T - R0002 - Withdrawal Space - 1hb - (6.07 SQM)	 Student Space (2)	
B00T - R0003 - Home Base - (53.69 SQM) - Teaching Space: 1	 Student Space (24)	
OS 507 10406 - OS 507 10406 - Administration - Library - (95 SQM)	 Office (23)	
OS 523 15552 - OS 523 15552 - Staff Study With Toilets - (76 SQM)	 Office (19)	
OS 601 13733 - OS 601 13733 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 601 13775 - OS 601 13775 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 601 13924 - OS 601 13924 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 602 13296 - OS 602 13296 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 970 15341 - OS 970 15341 - Store - Single Module - (19 SQM)	Not Applicable	Circulation or storage space.