

VENTILATION AUDIT REPORT

SCHOOL:	Bowen Public School (4538)
AMU REGION:	North Western NSW
STATE ELECTORATE:	Orange
LOCAL GOVERNMENT AREA:	Orange












4538 - Bowen Public School
Site Plan (12383)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0005 - Interview - (11.06 SQM)	Office (2)	
B00A - R0008 - Deputy Principal - (10.77 SQM)	Office (2)	
B00A - R0009 - Staff Room Annexe - (14.65 SQM)	Office (3)	
B00A - R0010 - Principal - (15.81 SQM)	Office (3)	
B00A - R0019 - Withdrawal Space - 1hb - (19.85 SQM)	Student Space (9)	
B00A - R0021 - Movement - (7.1 SQM)	Not Applicable	Circulation or storage space.
B00A - R0025 - Staff Room Annexe - (11.83 SQM)	Office (2)	
B00A - R0027 - Entry Vestibule - (16.76 SQM)	Not Applicable	Circulation or storage space.
B00A - R0028 - Movement - (7.24 SQM)	Not Applicable	Circulation or storage space.
B00A - R0029 - Clerical Office - (32.18 SQM)	Office (8)	
B00A - R0030 - Staff Room - (77.57 SQM)	Office (19)	
B00A - R0031 - Movement - (12.7 SQM)	Not Applicable	Circulation or storage space.
B00A - R0032 - Sick Bay - (12.73 SQM)	Student Space (5)	
B00B - R0006 - Home Base - (85.98 SQM) - Teaching Space: 1	Student Space (39)	
B00B - R0009 - Practical Activities - 1hb - (6.94 SQM)	Student Space (3)	
B00B - R0010 - Practical Activities - 1hb - (6.92 SQM)	Student Space (3)	
B00B - R0011 - Home Base - (57.26 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0012 - Home Base - (57.26 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0014 - Practical Activities - 1hb - (6.94 SQM)	Student Space (3)	
B00C - R0006 - Home Base - (85.94 SQM) - Teaching Space: 1	Student Space (39)	
B00C - R0007 - Practical Activities - 1hb - (6.95 SQM)	Student Space (3)	
B00C - R0010 - Practical Activities - 1hb - (6.91 SQM)	Student Space (3)	
B00C - R0011 - Home Base - (57.5 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0012 - Home Base - (57.02 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0014 - Practical Activities - 1hb - (6.9 SQM)	Student Space (3)	
B00E - R0001 - Practical Activities - 1hb - (6.92 SQM)	Student Space (3)	
B00E - R0003 - Home Base - (86.09 SQM) - Teaching Space: 1	Student Space (39)	
B00E - R0010 - Practical Activities - 1hb - (6.87 SQM)	Student Space (3)	
B00E - R0011 - Home Base - (57.27 SQM) - Teaching Space: 1	Student Space (26)	
B00E - R0012 - Home Base - (57.27 SQM) - Teaching Space: 1	Student Space (26)	
B00F - R0001 - Canteen - (44.79 SQM)	Not Applicable	Circulation or storage space.
B00F - R0007 - Movement - (25.73 SQM)	Not Applicable	Circulation or storage space.
B00F - R0012 - Raised Platform - (44.27 SQM)	Not Applicable	Circulation or storage space.
B00F - R0013 - Communal Space - (245.38 SQM)	Student Space (113)	
B00F - R0014 - Movement - (120.31 SQM)	Not Applicable	Circulation or storage space.
B00F - R0015 - Movement - (8.09 SQM)	Not Applicable	Circulation or storage space.
B00F - R0017 - Special Programs Room - (41.05 SQM)	Student Space (19)	
B00F - R0023 - Home Base - (59.42 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R0024 - Home Base - (59.35 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R0025 - Withdrawal Space - 1hb - (11.5 SQM)	Student Space (5)	
B00F - R0030 - Practical Activities - 1hb - (30.49 SQM)	Student Space (14)	
B00F - R0031 - Interview - (16.45 SQM)	Office (4)	
B00F - R0032 - Movement - (117.1 SQM)	Not Applicable	Circulation or storage space.
B00F - R0036 - Home Base - (59.19 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R0037 - Home Base - (59.1 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R0038 - Withdrawal Space - 1hb - (11.49 SQM)	Student Space (5)	
B00F - R0050 - Practical Activities - 1hb - (28.92 SQM)	Student Space (13)	
B00F - R0057 - Home Base - (59.34 SQM) - Teaching Space: 1	Student Space (27)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00F - R0058 - Home Base - (59.34 SQM) - Teaching Space: 1	 Student Space (27)	
B00F - R0059 - Withdrawal Space - 1hb - (11.46 SQM)	 Student Space (5)	
B00F - R0063 - Practical Activities - 1hb - (30.45 SQM)	 Student Space (14)	
B00F - R0064 - Withdrawal Space - 1hb - (16.44 SQM)	 Student Space (7)	
B00F - R0068 - Home Base - (59.35 SQM) - Teaching Space: 1	 Student Space (27)	
B00F - R0069 - Home Base - (59.26 SQM) - Teaching Space: 1	 Student Space (27)	
B00F - R0070 - Withdrawal Space - 1hb - (11.53 SQM)	 Student Space (5)	
B00F - R0072 - Practical Activities - 1hb - (30.35 SQM)	 Student Space (14)	
B00F - R0076 - Movement - (32.03 SQM)	Not Applicable	Circulation or storage space.
B00F - R0077 - Movement - (23.01 SQM)	Not Applicable	Circulation or storage space.
B00F - R0078 - Movement - (6.93 SQM)	Not Applicable	Circulation or storage space.
B00F - R0079 - Movement - (19.55 SQM)	Not Applicable	Circulation or storage space.
B00F - R0080 - Reading Area - (224.2 SQM)	 Student Space (104)	
B00F - R0081 - Seminar/Study - (13.55 SQM)	 Office (3)	
B00F - R0082 - Seminar/Study - (13.69 SQM)	 Office (3)	