

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Bradfordville Public School (4406)</b>
<b>AMU REGION:</b>	<b>Southern NSW</b>
<b>STATE ELECTORATE:</b>	<b>Goulburn</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Goulburn Mulwaree</b>

4406 - Bradfordville Public School  
Site Plan (10111)



## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (46.35 SQM)	Not Applicable	Circulation or storage space.
B00A - R0005 - Home Base - (86.36 SQM) - Teaching Space: 1	● Student Space (40)	
B00A - R0007 - Home Base - (85.97 SQM) - Teaching Space: 1	● Student Space (39)	
B00A - R0012 - Home Base - (71.83 SQM) - Teaching Space: 1	● Student Space (33)	
B00B - R0001 - Movement - (33.09 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Home Base - (57.02 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R0006 - Home Base - (57.02 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R0008 - Home Base - (98.65 SQM) - Teaching Space: 1	● Student Space (45)	
B00B - R0009 - Raised Platform - (9.98 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Staff Room Annexe - (10.92 SQM)	● Office (2)	
B00C - R0002 - Staff Room Annexe - (10.07 SQM)	● Office (2)	
B00C - R0003 - Staff Room - (49.68 SQM)	● Office (12)	
B00C - R0005 - Movement - (14.94 SQM)	Not Applicable	Circulation or storage space.
B00C - R0006 - Interview - (15.93 SQM)	● Office (3)	
B00C - R0007 - Movement - (50.03 SQM)	Not Applicable	Circulation or storage space.
B00C - R0008 - Duplicating Workroom - (27.92 SQM)	● Office (6)	
B00C - R0009 - Staff Room Annexe - (11.72 SQM)	● Office (2)	
B00C - R0011 - Principal - (18.39 SQM)	● Office (4)	
B00C - R0012 - Entry Vestibule - (13.01 SQM)	Not Applicable	Circulation or storage space.
B00C - R0015 - Clerical Office - (19.47 SQM)	● Office (4)	
B00C - R0016 - Sick Bay - (19.33 SQM)	● Student Space (8)	
B00D - R0001 - Reading Area - (159.85 SQM)	● Student Space (74)	
B00E - R0001 - Canteen - (28.89 SQM)	Not Applicable	Circulation or storage space.
B00E - R0012 - Movement - (7.9 SQM)	Not Applicable	Circulation or storage space.
B00E - R0013 - Raised Platform - (49.88 SQM)	Not Applicable	Circulation or storage space.
B00E - R0015 - Movement - (7.8 SQM)	Not Applicable	Circulation or storage space.
B00E - R0017 - Withdrawal Space - 1hb - (18.56 SQM)	● Student Space (8)	
B00E - R0019 - Communal Space - (143.71 SQM)	● Student Space (66)	
B00E - R0022 - Special Programs Room - (18.14 SQM)	● Student Space (8)	
B00L - R0003 - Special Programs Room - (33.15 SQM)	● Student Space (15)	
B00L - R0004 - Movement - (5.98 SQM)	Not Applicable	Circulation or storage space.
B00L - R0005 - Movement - (5.98 SQM)	Not Applicable	Circulation or storage space.
B00L - R0006 - Special Programs Room - (33.15 SQM)	● Student Space (15)	
B00M - R0002 - Practical Activities/Movement - 1hb - (19.09 SQM)	● Student Space (8)	
B00M - R0004 - Home Base - (60.43 SQM) - Teaching Space: 1	● Student Space (28)	
B00M - R0005 - Withdrawal Space - 2hb - (11.74 SQM)	● Student Space (5)	
B00M - R0006 - Home Base - (60.43 SQM) - Teaching Space: 1	● Student Space (28)	
B00M - R0008 - Practical Activities/Movement - 1hb - (19.09 SQM)	● Student Space (8)	
B00M - R0009 - Withdrawal Space - 1hb - (8.72 SQM)	● Student Space (4)	
B00M - R0011 - Home Base - (58.15 SQM) - Teaching Space: 1	● Student Space (26)	
B00M - R0012 - Practical Activities/Movement - 1hb - (20.67 SQM)	● Student Space (9)	
OS 602 10765 - OS 602 10765 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 13468 - OS 602 13468 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 606 19209 - OS 606 19209 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	