


VENTILATION AUDIT REPORT

SCHOOL:	Braidwood Central School (1340)
AMU REGION:	Southern NSW
STATE ELECTORATE:	Monaro
LOCAL GOVERNMENT AREA:	Queanbeyan-Palerang

1340 - Braidwood Central School
Site Plan (14661)



1:1,319













Printed: 29-Apr-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B004 - R0001 - Practical Activities - 1hb - (19.16 SQM)	● Student Space (8)	
B004 - R0003 - Home Base - (60.99 SQM) - Teaching Space: 1	● Student Space (28)	
B004 - R0004 - Withdrawal Space - 2hb - (12.19 SQM)	● Student Space (5)	
B004 - R0005 - Home Base - (61.12 SQM) - Teaching Space: 1	● Student Space (28)	
B004 - R0007 - Practical Activities - 1hb - (19.14 SQM)	● Student Space (8)	
B00A - R0002 - Staff Room - (13.85 SQM)	● Office (3)	
B00A - R0003 - Interview - (13.84 SQM)	● Office (3)	
B00A - R0004 - Teachers Aides - (11.64 SQM)	● Office (2)	
B00A - R0009 - Sick Bay - (8.67 SQM)	● Student Space (4)	
B00A - R0012 - Movement - (12.43 SQM)	Not Applicable	Circulation or storage space.
B00A - R0013 - Entry Vestibule - (7.52 SQM)	Not Applicable	Circulation or storage space.
B00A - R0014 - Clerical Office - (19.44 SQM)	● Office (4)	
B00A - R0016 - Clerical Office/Workroom - (20.38 SQM)	● Office (5)	
B00A - R0017 - Principal - (18.99 SQM)	● Office (4)	
B00A - R0020 - Interview/Meeting - (16.55 SQM)	● Office (4)	
B00A - R0021 - Movement - (7.55 SQM)	Not Applicable	Circulation or storage space.
B00A - R0024 - Movement - (22.83 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Withdrawal Space - 1hb - (6.4 SQM)	● Student Space (2)	
B00C - R0003 - Home Base - (60.5 SQM) - Teaching Space: 1	● Student Space (28)	
B00C - R0004 - Practical Activities - 1hb - (18.05 SQM)	● Student Space (8)	
B00D - R0003 - Practical Activities - 1hb - (17.88 SQM)	● Student Space (8)	
B00D - R0004 - Home Base - (60.65 SQM) - Teaching Space: 1	● Student Space (28)	
B00D - R0005 - Withdrawal Space - 1hb - (6.4 SQM)	● Student Space (2)	
B00E - R0003 - Practical Activities - 1hb - (18.32 SQM)	● Student Space (8)	
B00E - R0004 - Home Base - (60.49 SQM) - Teaching Space: 1	● Student Space (28)	
B00E - R0005 - Withdrawal Space - 1hb - (6.35 SQM)	● Student Space (2)	
B00F - R0002 - Staff Room - (42.72 SQM)	● Office (10)	
B00F - R0003 - Staff Kitchen - (13.44 SQM)	● Office (3)	
B00F - R0005 - Staff Room Annexe - (86.58 SQM)	● Office (21)	
B00F - R0011 - Interview - (21.37 SQM)	● Office (5)	
B00F - R0014 - Staff Study - (16.71 SQM)	● Office (4)	
B00F - R0015 - Movement - (13.64 SQM)	Not Applicable	Circulation or storage space.
B00F - R0016 - Movement - (21.66 SQM)	Not Applicable	Circulation or storage space.
B00F - R0017 - General Learning Space - Type 1 - (53.58 SQM) - Teaching Space: 1	● Student Space (24)	
B00F - R0020 - Shared Learning Space - (30.5 SQM)	● Student Space (14)	
B00F - R0021 - General Learning Space - Type 2 - (63.3 SQM) - Teaching Space: 1	● Student Space (29)	
B00G - R0001 - Home Base - (57.9 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R0002 - Withdrawal Space - 1hb - (13.42 SQM)	● Student Space (6)	
B00G - R0003 - Practical Activities - 1hb - (24.61 SQM)	● Student Space (11)	
B00G - R0004 - Home Base - (57.96 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R0005 - Withdrawal Space - 1hb - (6.79 SQM)	● Student Space (3)	
B00G - R0006 - Deputy Principal - (17.27 SQM)	● Office (4)	
B00G - R0007 - Movement - (17.68 SQM)	Not Applicable	Circulation or storage space.
B00G - R0008 - Movement - (9.54 SQM)	Not Applicable	Circulation or storage space.
B00G - R0011 - Movement - (11.96 SQM)	Not Applicable	Circulation or storage space.
B00G - R0012 - Home Base - (63.84 SQM) - Teaching Space: 1	● Student Space (29)	
B00G - R0013 - Special Programs Room - (18.9 SQM)	● Student Space (8)	
B00H - R0005 - General Learning Space - (39.41 SQM) - Teaching Space: 1	● Student Space (18)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00H - R0006 - General Learning Space - (39.61 SQM) - Teaching Space: 1	Student Space (18)	
B00H - R0010 - General Learning Space - (53.44 SQM) - Teaching Space: 1	Student Space (24)	
B00H - R0014 - Movement - (11.41 SQM)	Not Applicable	Circulation or storage space.
B00I - R0001 - Seminar/Technology Space - (31.1 SQM)	Office (7)	
B00I - R0004 - Art Learning Space - (62.4 SQM) - Teaching Space: 1	Student Space (28)	
B00I - R0005 - Workshop - (49.39 SQM)	Student Space (22)	
B00J - R0003 - T.A.S. Outdoor Area - (6.32 SQM)	Not Applicable	Circulation or storage space.
B00J - R0004 - Staff Study - (26.13 SQM)	Office (6)	
B00J - R0005 - Food Technology L.S. - (110.02 SQM) - Teaching Space: 1	Student Space (51)	
B00J - R0006 - Food/Research Space - (23.01 SQM)	Not Applicable	Circulation or storage space.
B00J - R0007 - Movement - (5.74 SQM)	Not Applicable	Circulation or storage space.
B00J - R1005 - Staff Study - (26.04 SQM)	Office (6)	
B00J - R1006 - General Learning Space - (54.36 SQM) - Teaching Space: 1	Student Space (25)	
B00J - R1007 - Computer Learning Space - (54.36 SQM) - Teaching Space: 1	Student Space (25)	
B00J - R1008 - Study Space - (22.92 SQM)	Not Applicable	Circulation or storage space.
B00J - R1009 - Study Space - (14.55 SQM)	Not Applicable	Circulation or storage space.
B00K - R0004 - Materials Technology L.S. - (105.68 SQM) - Teaching Space: 1	Student Space (49)	
B00K - R0005 - Wood Technology Bay - (23.67 SQM)	Not Applicable	Circulation or storage space.
B00K - R0006 - Metal Technology Bay - (23.88 SQM)	Not Applicable	Circulation or storage space.
B00K - R0010 - Materials Workshop - Type 3 - (53.87 SQM)	Student Space (24)	
B00K - R0011 - Welding Area - (16.19 SQM)	Not Applicable	Circulation or storage space.
B00L - R0001 - General Learning Space - (36.29 SQM) - Teaching Space: 1	Student Space (16)	
B00L - R0003 - Movement - (20.85 SQM)	Not Applicable	Circulation or storage space.
B00L - R0004 - Study Space - (36.5 SQM)	Not Applicable	Circulation or storage space.
B00L - R0005 - General Learning Space - (41.51 SQM) - Teaching Space: 1	Student Space (19)	
B00M - R0003 - Movement - (7.33 SQM)	Not Applicable	Circulation or storage space.
B00M - R0006 - Raised Platform - (50.9 SQM)	Not Applicable	Circulation or storage space.
B00M - R0008 - Movement - (7.31 SQM)	Not Applicable	Circulation or storage space.
B00M - R0014 - Communal Space - (186.23 SQM)	Student Space (86)	
B00M - R0021 - Canteen - (43.49 SQM)	Not Applicable	Circulation or storage space.
B00M - R0024 - Movement - (45.54 SQM)	Not Applicable	Circulation or storage space.
B00N - R0010 - General Learning Space - (59.16 SQM) - Teaching Space: 1	Student Space (27)	
B00N - R0011 - Movement - (13.12 SQM)	Not Applicable	Circulation or storage space.
B00N - R0017 - Laboratory L.S. - (86.64 SQM) - Teaching Space: 1	Student Space (40)	
B00N - R0020 - Laboratory L.S. - (86.35 SQM) - Teaching Space: 1	Student Space (40)	
B00N - R0021 - Preparation - Science - (46.85 SQM)	Not Applicable	Circulation or storage space.
B00N - R1001 - Seminar - (13.1 SQM)	Office (3)	
B00N - R1002 - Seminar/Study - (12.81 SQM)	Office (3)	
B00N - R1003 - Seminar - (13.07 SQM)	Office (3)	
B00N - R1004 - Seminar - (12.71 SQM)	Office (3)	
B00N - R1011 - Movement - (26.34 SQM)	Not Applicable	Circulation or storage space.
B00N - R1014 - Reading Area - (214.21 SQM)	Student Space (99)	
B00N - R1019 - Movement - (5.61 SQM)	Not Applicable	Circulation or storage space.
B00Q - M0002 - Movement - (179.33 SQM)	Not Applicable	Circulation or storage space.
B00Q - R0004 - Movement - (33.06 SQM)	Not Applicable	Circulation or storage space.
B00Q - R0010 - Gymnasium - (526.18 SQM)	Student Space (244)	
B00Q - R0020 - Fitness Laboratory - (46.83 SQM)	Student Space (21)	
B00T - R0001 - Special Programs Room - (67.67 SQM)	Student Space (31)	
B0AA - R0001 - Movement - (9.57 SQM)	Not Applicable	Circulation or storage space.
B0AA - R0002 - Public Reception - (34.73 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B0AA - R0004 - Staff Lounge - (56.01 SQM)	 Office (14)	
B0AA - R0005 - Staff Study - (198.88 SQM)	 Office (49)	
B0AA - R0006 - Administration - Clerical - (7.17 SQM)	 Office (1)	
B0AA - R0007 - Movement - (11.13 SQM)	Not Applicable	Circulation or storage space.
B0AA - R0014 - Clerical Office - (38.8 SQM)	 Office (9)	
B0AA - R0015 - Clinic - (13.82 SQM)	 Office (3)	
B0AA - R0017 - Clinic - (13.7 SQM)	 Office (3)	
B0AA - R0018 - Movement - (25.45 SQM)	Not Applicable	Circulation or storage space.
B0AA - R0019 - Student Reception - (5.32 SQM)	Not Applicable	Circulation or storage space.
B0AA - R0020 - Movement - (5.39 SQM)	Not Applicable	Circulation or storage space.
NS 110 12639 - NS 110 12639 - Learning Unit - Single Secondary/Secure - (57 SQM)	 Student Space (26)	
OS 510 16099 - OS 510 16099 - Staff Common Room - (114 SQM)	 Office (28)	
OS 600 15271 - OS 600 15271 - Learning Unit - Small - (57 SQM)	 Student Space (26)	
OS 601 11758 - OS 601 11758 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 601 13430 - OS 601 13430 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 602 10152 - OS 602 10152 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	