


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Brewongle Environmental Education Centre (5694)</b>
<b>AMU REGION:</b>	<b>Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Hawkesbury</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>The Hills</b>

5694 - Brewongle Environmental Education Centre  
Site Plan (10114)



1:602

Printed: 18-Aug-2021

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R0002 - General Assistants - (7.75 SQM)	Office (1)	
B00F - R0001 - Staff Kitchen - (21.59 SQM)	Office (5)	
B00F - R0002 - Movement - (10.28 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Movement - (12.93 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Clerical Office - (8.5 SQM)	Office (2)	
B00G - R0003 - Home Base - (42.9 SQM) - Teaching Space: 1	Student Space (19)	
B00G - R0004 - Staff Room Annexe - (13.66 SQM)	Office (3)	
B00G - R0005 - Principal - (13.55 SQM)	Office (3)	
B00G - R0006 - Clerical/Printing - (13.55 SQM)	Not Applicable	Circulation or storage space.
B00G - R0007 - Clerical Office - (13.59 SQM)	Office (3)	
B00G - R0010 - Staff Kitchen - (14.56 SQM)	Office (3)	
B00J - R0001 - Dormitory - (18.6 SQM)	Office (4)	
B00K - R0001 - Dormitory - (18.6 SQM)	Office (4)	
B00O - R0001 - Dormitory - (18.6 SQM)	Office (4)	
B00P - R0001 - Dormitory - (18.6 SQM)	Office (4)	
B00Q - R0001 - Communal Space - (59.99 SQM)	Student Space (27)	
B00Q - R0002 - Stage - (10.12 SQM)	Not Applicable	Circulation or storage space.
NS 350 10771 - NS 350 10771 - Dormitory Toilet/Shower - (76 SQM)	Office (19)	
OS 601 14403 - OS 601 14403 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	