

VENTILATION AUDIT REPORT

SCHOOL:	Briar Road Public School (4458)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Campbelltown
LOCAL GOVERNMENT AREA:	Campbelltown

4458 - Briar Road Public School
Site Plan (10106)



1:911

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B001 - R0001 - Movement - (15.94 SQM)	Not Applicable	Circulation or storage space.
B001 - R0007 - Practical Activities - 1hb - (16.29 SQM)	● Student Space (7)	
B001 - R0008 - Home Base - (84.16 SQM) - Teaching Space: 1	● Student Space (39)	
B001 - R0010 - Practical Activities - 1hb - (15.63 SQM)	● Student Space (7)	
B001 - R0012 - Home Base - (82.67 SQM) - Teaching Space: 1	● Student Space (38)	
B001 - R0013 - Home Base - (79.73 SQM) - Teaching Space: 1	● Student Space (36)	
B001 - R0014 - Practical Activities - 1hb - (15.13 SQM)	● Student Space (7)	
B001 - R0016 - Movement - (15.94 SQM)	Not Applicable	Circulation or storage space.
B001 - R0022 - Practical Activities - 1hb - (13.28 SQM)	● Student Space (6)	
B001 - R0023 - Home Base - (59.04 SQM) - Teaching Space: 1	● Student Space (27)	
B001 - R0026 - Movement - (174.74 SQM)	Not Applicable	Circulation or storage space.
B001 - R0027 - Movement - (54.62 SQM)	Not Applicable	Circulation or storage space.
B002 - R0001 - Movement - (22.14 SQM)	Not Applicable	Circulation or storage space.
B002 - R0008 - Practical Activities - 1hb - (11.3 SQM)	● Student Space (5)	
B002 - R0009 - Home Base - (62.81 SQM) - Teaching Space: 1	● Student Space (29)	
B002 - R0010 - Home Base - (62.24 SQM) - Teaching Space: 1	● Student Space (28)	
B002 - R0011 - Practical Activities - 1hb - (11.55 SQM)	● Student Space (5)	
B002 - R0012 - Movement - (22.16 SQM)	Not Applicable	Circulation or storage space.
B002 - R0019 - Home Base - M - (53.23 SQM) - Teaching Space: 1	● Student Space (24)	
B002 - R0020 - Practical Activities - 1hb - (21.08 SQM)	● Student Space (9)	
B002 - R0025 - Movement - (138.16 SQM)	Not Applicable	Circulation or storage space.
B002 - R0026 - Movement - (146.72 SQM)	Not Applicable	Circulation or storage space.
B002 - R0027 - Movement - (58.85 SQM)	Not Applicable	Circulation or storage space.
B002 - R0029 - Practical Activities - 1hb - (21.63 SQM)	● Student Space (10)	
B002 - R0030 - Home Base - (51.7 SQM) - Teaching Space: 1	● Student Space (23)	
B002 - R0031 - Home Base - (51.62 SQM) - Teaching Space: 1	● Student Space (23)	
B002 - R0032 - Practical Activities - 1hb - (21.38 SQM)	● Student Space (9)	
B002 - R0033 - Movement - (32.52 SQM)	Not Applicable	Circulation or storage space.
B003 - R0001 - Home Base - M - (50.96 SQM) - Teaching Space: 1	● Student Space (23)	
B003 - R0002 - Practical Activities - 1hb - (18.38 SQM)	● Student Space (8)	
B003 - R0003 - Movement - (20.87 SQM)	Not Applicable	Circulation or storage space.
B003 - R0010 - Practical Activities - 1hb - (18.29 SQM)	● Student Space (8)	
B003 - R0011 - Home Base - (50.42 SQM) - Teaching Space: 1	● Student Space (23)	
B003 - R0012 - Home Base - (50.42 SQM) - Teaching Space: 1	● Student Space (23)	
B003 - R0013 - Practical Activities - 1hb - (18.28 SQM)	● Student Space (8)	
B003 - R0014 - Movement - (20.91 SQM)	Not Applicable	Circulation or storage space.
B003 - R0021 - Practical Activities - 1hb - (18.39 SQM)	● Student Space (8)	
B003 - R0022 - Home Base - (50.96 SQM) - Teaching Space: 1	● Student Space (23)	
B003 - R0023 - Movement - (130.57 SQM)	Not Applicable	Circulation or storage space.
B003 - R0024 - Movement - (40.08 SQM)	Not Applicable	Circulation or storage space.
B004 - R0001 - Home Base - M - (50.97 SQM) - Teaching Space: 1	● Student Space (23)	
B004 - R0002 - Practical Activities - 1hb - (17.97 SQM)	● Student Space (8)	
B004 - R0003 - Movement - (21.03 SQM)	Not Applicable	Circulation or storage space.
B004 - R0010 - Practical Activities - 1hb - (18.28 SQM)	● Student Space (8)	
B004 - R0011 - Home Base - M - (50.41 SQM) - Teaching Space: 1	● Student Space (23)	
B004 - R0012 - Home Base - (50.41 SQM) - Teaching Space: 1	● Student Space (23)	
B004 - R0013 - Practical Activities - 1hb - (18.28 SQM)	● Student Space (8)	
B004 - R0020 - Movement - (20.91 SQM)	Not Applicable	Circulation or storage space.
B004 - R0021 - Practical Activities - 1hb - (18.3 SQM)	● Student Space (8)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B004 - R0022 - Home Base - (50.95 SQM) - Teaching Space: 1	● Student Space (23)	
B004 - R0023 - Movement - (131.32 SQM)	Not Applicable	Circulation or storage space.
B004 - R0024 - Movement - (37.97 SQM)	Not Applicable	Circulation or storage space.
B005 - R0001 - Home Base - (50.95 SQM) - Teaching Space: 1	● Student Space (23)	
B005 - R0002 - Practical Activities - 1hb - (18.39 SQM)	● Student Space (8)	
B005 - R0003 - Movement - (20.88 SQM)	Not Applicable	Circulation or storage space.
B005 - R0010 - Practical Activities - 1hb - (18.28 SQM)	● Student Space (8)	
B005 - R0011 - Home Base - (50.42 SQM) - Teaching Space: 1	● Student Space (23)	
B005 - R0012 - Home Base - (50.42 SQM) - Teaching Space: 1	● Student Space (23)	
B005 - R0013 - Practical Activities - 1hb - (18.28 SQM)	● Student Space (8)	
B005 - R0014 - Movement - (20.91 SQM)	Not Applicable	Circulation or storage space.
B005 - R0021 - Practical Activities - 1hb - (18.38 SQM)	● Student Space (8)	
B005 - R0022 - Home Base - (50.95 SQM) - Teaching Space: 1	● Student Space (23)	
B005 - R0023 - Movement - (130.6 SQM)	Not Applicable	Circulation or storage space.
B005 - R0024 - Movement - (35.65 SQM)	Not Applicable	Circulation or storage space.
B006 - R0001 - Sick Bay - (19.31 SQM)	● Student Space (8)	
B006 - R0006 - Interview - (12.29 SQM)	○ Office (3)	
B006 - R0008 - Staff Room - (73.22 SQM)	○ Office (18)	
B006 - R0011 - Duplicating Workroom - (9.49 SQM)	○ Office (2)	
B006 - R0013 - Principal - (22.36 SQM)	○ Office (5)	
B006 - R0014 - Deputy Principal - (14.78 SQM)	○ Office (3)	
B006 - R0015 - Clerical Office/Workroom - (20.33 SQM)	○ Office (5)	
B006 - R0016 - Clerical Office - (12.78 SQM)	○ Office (3)	
B006 - R0017 - Entry Vestibule - (9.73 SQM)	Not Applicable	Circulation or storage space.
B006 - R0018 - Movement - (57.09 SQM)	Not Applicable	Circulation or storage space.
B006 - R0019 - Movement - (14.84 SQM)	Not Applicable	Circulation or storage space.
B006 - R0022 - Canteen - (24.52 SQM)	Not Applicable	Circulation or storage space.
B006 - R0024 - Movement - (175.71 SQM)	Not Applicable	Circulation or storage space.
B007 - R0001 - Movement - (14.65 SQM)	Not Applicable	Circulation or storage space.
B007 - R0011 - Seminar/Study - (50.22 SQM)	○ Office (12)	
B007 - R0012 - Reading Area - (181.08 SQM)	● Student Space (84)	
B007 - R0013 - Movement - (138.25 SQM)	Not Applicable	Circulation or storage space.
B008 - R0001 - Entry Vestibule - (6.59 SQM)	Not Applicable	Circulation or storage space.
B009 - R0002 - Entry Vestibule - (13.89 SQM)	Not Applicable	Circulation or storage space.
B009 - R0005 - Home Base - Pre - (68.95 SQM) - Teaching Space: 1	● Student Space (31)	
B009 - R0006 - Practical Activities - Pre - (46.3 SQM)	● Student Space (21)	
B009 - R0015 - Movement - (69.34 SQM)	Not Applicable	Circulation or storage space.
B011 - R0001 - Communal Space - (144.75 SQM)	● Student Space (67)	
B011 - R0002 - Raised Platform - (60.86 SQM)	Not Applicable	Circulation or storage space.
B011 - R0016 - Movement - (6.11 SQM)	Not Applicable	Circulation or storage space.
B011 - R0017 - Movement - (12.7 SQM)	Not Applicable	Circulation or storage space.