

VENTILATION AUDIT REPORT

SCHOOL:	Brighton-Le-Sands Public School (1358)
AMU REGION:	Sydney
STATE ELECTORATE:	Rockdale
LOCAL GOVERNMENT AREA:	Bayside


1358 - Brighton-Le-Sands Public School
Site Plan (10107)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0011 - Movement - (10.66 SQM)	Not Applicable	Circulation or storage space.
B00A - R0012 - Staff Room - (10.78 SQM)	Office (2)	
B00A - R0013 - Staff Room - (15.41 SQM)	Office (3)	
B00A - R0022 - Home Base - (56.86 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0023 - Home Base - (56.85 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0038 - Home Base - (62.13 SQM) - Teaching Space: 1	Student Space (28)	
B00A - R0039 - Home Base - (52.58 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R0042 - Special Programs Room - (30.69 SQM)	Student Space (14)	
B00A - R0043 - Home Base - (52.17 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R0044 - Movement - (11.28 SQM)	Not Applicable	Circulation or storage space.
B00A - R0045 - Communal Space - (220.69 SQM)	Student Space (102)	
B00A - R0046 - Raised Platform - (56.7 SQM)	Not Applicable	Circulation or storage space.
B00A - R0048 - Practical Activities - 1hb - (11.33 SQM)	Student Space (5)	
B00A - R0049 - Communal Space - (95.65 SQM)	Student Space (44)	
B00A - R0050 - Practical Activities - 1hb - (15.31 SQM)	Student Space (7)	
B00A - R0052 - Withdrawal Space - 1hb - (10.55 SQM)	Student Space (4)	
B00A - R0053 - Practical Activities - 1hb - (20.69 SQM)	Student Space (9)	
B00A - R0059 - Practical Activities - 1hb - (18.99 SQM)	Student Space (8)	
B00A - R0061 - Withdrawal Space - 1hb - (10.73 SQM)	Student Space (4)	
B00A - R0062 - Practical Activities - 1hb - (16.69 SQM)	Student Space (7)	
B00A - R0064 - Practical Activities - 1hb - (11.39 SQM)	Student Space (5)	
B00A - R0065 - Home Base - (52.49 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R0066 - Withdrawal Space - 2hb - (10.07 SQM)	Student Space (4)	
B00B - R0002 - Home Base - (52.54 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0003 - Home Base - (52.54 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0004 - Movement - (17.38 SQM)	Not Applicable	Circulation or storage space.
B00B - R0005 - Special Programs Room - (6.52 SQM)	Student Space (3)	
B00B - R0006 - Special Programs Room - (19.25 SQM)	Student Space (8)	
B00B - R0007 - Home Base - (52.53 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0008 - Home Base - (52.53 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0009 - Home Base - (52.53 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0010 - Home Base - M - (61.27 SQM) - Teaching Space: 1	Student Space (28)	
B00B - R0013 - Movement - (32.67 SQM)	Not Applicable	Circulation or storage space.
B00B - R0017 - Raised Platform - (14.42 SQM)	Not Applicable	Circulation or storage space.
B00B - R0018 - Practical Activities - 1hb - (7.11 SQM)	Student Space (3)	
B00B - R0019 - Communal Space - (158.56 SQM)	Student Space (73)	
B00B - R0021 - Movement - (17.65 SQM)	Not Applicable	Circulation or storage space.
B00D - R0009 - Home Base - (51.04 SQM) - Teaching Space: 1	Student Space (23)	
B00D - R0010 - Practical Activities - 1hb - (14.57 SQM)	Student Space (6)	
B00D - R0012 - Withdrawal Space - 2hb - (10.45 SQM)	Student Space (4)	
B00D - R0013 - Movement - (8.01 SQM)	Not Applicable	Circulation or storage space.
B00D - R0014 - Home Base - (48.49 SQM) - Teaching Space: 1	Student Space (22)	
B00D - R0016 - Practical Activities - 1hb - (14.57 SQM)	Student Space (6)	
B00D - R0017 - Movement - (5.36 SQM)	Not Applicable	Circulation or storage space.
B00D - R0019 - Special Programs Room - (48.47 SQM)	Student Space (22)	
B00F - R0004 - Special Programs Room - (49.87 SQM)	Student Space (23)	
B00F - R0005 - Movement - (8.21 SQM)	Not Applicable	Circulation or storage space.
B00F - R0015 - Canteen - (51.99 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00I - R0001 - Staff Room - (19.65 SQM)	 Office (4)	
B00I - R0002 - Staff Room - (45.17 SQM)	 Office (11)	
B00I - R0004 - Deputy Principal - (12.84 SQM)	 Office (3)	
B00I - R0006 - Principal - (17.15 SQM)	 Office (4)	
B00I - R0007 - Duplicating Workroom - (20.29 SQM)	 Office (5)	
B00I - R0008 - Entry Vestibule - (23.87 SQM)	Not Applicable	Circulation or storage space.
B00I - R0009 - Clerical Office - (17.81 SQM)	 Office (4)	
B00I - R0010 - Sick Bay - (8.24 SQM)	 Student Space (3)	
B00I - R0012 - Interview - (13.11 SQM)	 Office (3)	
B00I - R0013 - Deputy Principal - (13.27 SQM)	 Office (3)	
B00I - R0017 - Movement - (35.04 SQM)	Not Applicable	Circulation or storage space.
B00J - R0002 - Practical Activities - 1hb - (19.4 SQM)	 Student Space (9)	
B00J - R0004 - Home Base - (59.19 SQM) - Teaching Space: 1	 Student Space (27)	
B00J - R0005 - Withdrawal Space - 2hb - (11.36 SQM)	 Student Space (5)	
B00J - R0006 - Home Base - (59.2 SQM) - Teaching Space: 1	 Student Space (27)	
B00J - R0008 - Practical Activities - 1hb - (19.4 SQM)	 Student Space (9)	
B00K - R0002 - Practical Activities - 1hb - (19.4 SQM)	 Student Space (9)	
B00K - R0004 - Home Base - (59.2 SQM) - Teaching Space: 1	 Student Space (27)	
B00K - R0005 - Withdrawal Space - 2hb - (11.36 SQM)	 Student Space (5)	
B00K - R0006 - Home Base - (59.19 SQM) - Teaching Space: 1	 Student Space (27)	
B00K - R0008 - Practical Activities - 1hb - (19.4 SQM)	 Student Space (9)	
B00L - R0002 - Practical Activities - 1hb - (19.4 SQM)	 Student Space (9)	
B00L - R0004 - Home Base - (59.2 SQM) - Teaching Space: 1	 Student Space (27)	
B00L - R0005 - Withdrawal Space - 2hb - (11.36 SQM)	 Student Space (5)	
B00L - R0006 - Home Base - (59.19 SQM) - Teaching Space: 1	 Student Space (27)	
B00L - R0008 - Practical Activities - 1hb - (19.4 SQM)	 Student Space (9)	
B00M - R0001 - Reading Area - (231.45 SQM)	 Student Space (107)	
B00N - R0002 - Practical Activities - 1hb - (19.36 SQM)	 Student Space (8)	
B00N - R0004 - Home Base - (58.76 SQM) - Teaching Space: 1	 Student Space (27)	
B00N - R0005 - Withdrawal Space - 2hb - (10.67 SQM)	 Student Space (4)	
B00N - R0006 - Home Base - (58.67 SQM) - Teaching Space: 1	 Student Space (27)	
B00N - R0008 - Practical Activities - 1hb - (19.36 SQM)	 Student Space (8)	
OS 601 10466 - OS 601 10466 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 601 11410 - OS 601 11410 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 601 14671 - OS 601 14671 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 602 11391 - OS 602 11391 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 12807 - OS 602 12807 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 603 10069 - OS 603 10069 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	 Student Space (35)	