

VENTILATION AUDIT REPORT















SCHOOL:	Bringelly Public School (1360)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Camden
LOCAL GOVERNMENT AREA:	Liverpool

1360 - Bringelly Public School
Site Plan (10108)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0003 - Home Base - (85.21 SQM) - Teaching Space: 1	 Student Space (39)	
B00A - R0005 - Home Base - (56.44 SQM) - Teaching Space: 1	 Student Space (26)	
B00A - R0010 - Movement - (7.18 SQM)	Not Applicable	Circulation or storage space.
B00A - R0017 - Movement - (63.27 SQM)	Not Applicable	Circulation or storage space.
B00A - R0020 - Movement - (5.58 SQM)	Not Applicable	Circulation or storage space.
B00A - R0026 - Staff Room - (24.77 SQM)	 Office (6)	
B00A - R9002 - Movement - (28.84 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Home Base - (53.6 SQM) - Teaching Space: 1	 Student Space (24)	
B00E - R0002 - Home Base - (53.54 SQM) - Teaching Space: 1	 Student Space (24)	
B00E - R0003 - Movement - (30.37 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Movement - (6.74 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Special Programs Room - (50.6 SQM)	 Student Space (23)	
B00F - R0003 - Entry Vestibule - (10.25 SQM)	Not Applicable	Circulation or storage space.
B00I - R0001 - Home Base - (61.48 SQM) - Teaching Space: 1	 Student Space (28)	
B00I - R0003 - Practical Activities - 1hb - (15.73 SQM)	 Student Space (7)	
B00I - R0004 - Movement - (13.96 SQM)	Not Applicable	Circulation or storage space.
B00I - R0005 - Withdrawal Space - 1hb - (11.96 SQM)	 Student Space (5)	
B00I - R0006 - Home Base - (61.49 SQM) - Teaching Space: 1	 Student Space (28)	
B00I - R0007 - Practical Activities - 1hb - (15.74 SQM)	 Student Space (7)	
B00I - R0009 - Movement - (14.08 SQM)	Not Applicable	Circulation or storage space.
B00I - R0010 - Movement - (36.65 SQM)	Not Applicable	Circulation or storage space.
B00J - R0001 - Movement - (31.2 SQM)	Not Applicable	Circulation or storage space.
B00J - R0002 - Reading Area - (91.98 SQM)	 Student Space (42)	
OS 502 11436 - OS 502 11436 - Admin Staff/Principal/Clerk/Dup/Clinic - (152 SQM)	 Office (38)	
OS 602 11246 - OS 602 11246 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	