

VENTILATION AUDIT REPORT

SCHOOL:	Brisbania Public School (1498)
AMU REGION:	Hunter/Central Coast
STATE ELECTORATE:	Terrigal
LOCAL GOVERNMENT AREA:	Central Coast

1498 - Brisbania Public School
Site Plan (10142)



1:1,194

Printed: 29-Sep-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0004 - Staff Room Annexe - (26.59 SQM)	Office (6)	
B00A - R0006 - Staff Room - (67.22 SQM)	Office (16)	
B00A - R0013 - Movement - (53.56 SQM)	Not Applicable	Circulation or storage space.
B00A - R1003 - Entry Vestibule - (10.99 SQM)	Not Applicable	Circulation or storage space.
B00A - R1004 - Clerical Office - (16.38 SQM)	Office (4)	
B00A - R1005 - Duplicating Workroom - (7.5 SQM)	Office (1)	
B00A - R1006 - Clerical Office - (15.72 SQM)	Office (3)	
B00A - R1007 - Sick Bay - (14.2 SQM)	Student Space (6)	
B00A - R1008 - Deputy Principal - (13.33 SQM)	Office (3)	
B00A - R1009 - Interview - (11.84 SQM)	Office (2)	
B00A - R1010 - Movement - (20.04 SQM)	Not Applicable	Circulation or storage space.
B00A - R1011 - Interview - (12.88 SQM)	Office (3)	
B00A - R1014 - Movement - (48.72 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Home Base - (89.48 SQM) - Teaching Space: 1	Student Space (41)	
B00B - R0003 - Practical Activities - 1hb - (18.6 SQM)	Student Space (8)	
B00B - R0005 - Home Base - (89.8 SQM) - Teaching Space: 1	Student Space (41)	
B00B - R0006 - Movement - (42.5 SQM)	Not Applicable	Circulation or storage space.
B00B - R0007 - Movement - (33.03 SQM)	Not Applicable	Circulation or storage space.
B00B - R0008 - Practical Activities - 1hb - (18.6 SQM)	Student Space (8)	
B00B - R9004 - Movement - (14.89 SQM)	Not Applicable	Circulation or storage space.
B00B - R9006 - Movement - (28.15 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Practical Activities - 1hb - (39.91 SQM)	Student Space (18)	
B00C - R0003 - Home Base - (59.37 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R0004 - Movement - (16.47 SQM)	Not Applicable	Circulation or storage space.
B00C - R0005 - Withdrawal Space - 1hb - (11.54 SQM)	Student Space (5)	
B00C - R0006 - Home Base - (59.37 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R0009 - Movement - (16.47 SQM)	Not Applicable	Circulation or storage space.
B00C - R9001 - Canteen - (26.23 SQM)	Not Applicable	Circulation or storage space.
B00C - R9020 - Communal Space - (96.95 SQM)	Student Space (44)	
B00C - R9022 - Raised Platform - (89.33 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Practical Activities - 1hb - (40.91 SQM)	Student Space (18)	
B00D - R0004 - Home Base - (59.38 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0005 - Movement - (9.98 SQM)	Not Applicable	Circulation or storage space.
B00D - R0006 - Withdrawal Space - 1hb - (11.54 SQM)	Student Space (5)	
B00D - R0007 - Home Base - (59.38 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0011 - Movement - (9.98 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Practical Activities - 1hb - (41.09 SQM)	Student Space (19)	
B00E - R0004 - Home Base - (59.38 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0005 - Movement - (9.98 SQM)	Not Applicable	Circulation or storage space.
B00E - R0006 - Withdrawal Space - 1hb - (11.54 SQM)	Student Space (5)	
B00E - R0007 - Movement - (9.98 SQM)	Not Applicable	Circulation or storage space.
B00E - R0008 - Home Base - (59.38 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R0001 - Practical Activities - 1hb - (44.52 SQM)	Student Space (20)	
B00F - R0003 - Home Base - (59.37 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R0004 - Movement - (9.98 SQM)	Not Applicable	Circulation or storage space.
B00F - R0005 - Withdrawal Space - 1hb - (11.76 SQM)	Student Space (5)	
B00F - R0006 - Movement - (9.98 SQM)	Not Applicable	Circulation or storage space.
B00F - R0007 - Home Base - (59.37 SQM) - Teaching Space: 1	Student Space (27)	
B00G - M0002 - Practical Activities - 1hb - (40.91 SQM)	Student Space (18)	
B00G - M0005 - Home Base - (62.57 SQM)	Student Space (29)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - M0006 - Movement - (16.41 SQM)	Not Applicable	Circulation or storage space.
B00G - M0007 - Withdrawal Space - 1hb - (11.86 SQM)	● Student Space (5)	
B00G - M0008 - Movement - (7.66 SQM)	Not Applicable	Circulation or storage space.
B00G - M0009 - Home Base - (62.57 SQM)	● Student Space (29)	
B00G - M0012 - Movement - (63.58 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Movement - (238.92 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Movement - (14.31 SQM)	Not Applicable	Circulation or storage space.
B00G - R0009 - Practical Activities - (40.93 SQM)	● Student Space (18)	
B00G - R0012 - Home Base X2 - (126.8 SQM) - Teaching Space: 2	● Student Space (58)	
B00G - R0013 - Movement - (16.42 SQM)	Not Applicable	Circulation or storage space.
B00G - R0014 - Withdrawal - M - (11.87 SQM)	● Student Space (5)	
B00G - R0015 - Movement - (10.4 SQM)	Not Applicable	Circulation or storage space.
B00G - R9006 - Movement - (13.52 SQM)	Not Applicable	Circulation or storage space.
B00H - R0002 - Special Programs Room - (31.39 SQM)	● Student Space (14)	
B00H - R0007 - Reading Area - (144.13 SQM)	● Student Space (66)	
B00H - R0008 - Special Programs Room - (36.17 SQM)	● Student Space (16)	
B00I - R0001 - Practical Activities - 1hb - (15.67 SQM)	● Student Space (7)	
B00I - R0004 - Home Base - (60.28 SQM) - Teaching Space: 1	● Student Space (27)	
B00I - R0005 - Withdrawal Space - 2hb - (11.64 SQM)	● Student Space (5)	
B00I - R0006 - Practical Activities - 1hb - (14.28 SQM)	● Student Space (6)	
B00I - R0009 - Home Base - (60.46 SQM) - Teaching Space: 1	● Student Space (28)	
B00I - R0010 - Movement - (5.51 SQM)	Not Applicable	Circulation or storage space.
B00I - R0012 - Special Programs Room - (31.51 SQM)	● Student Space (14)	
B00I - R1001 - Practical Activities - 1hb - (15.74 SQM)	● Student Space (7)	
B00I - R1004 - Home Base - (60.1 SQM) - Teaching Space: 1	● Student Space (27)	
B00I - R1005 - Withdrawal Space - 2hb - (11.64 SQM)	● Student Space (5)	
B00I - R1006 - Practical Activities - 1hb - (14.24 SQM)	● Student Space (6)	
B00I - R1009 - Home Base - (60.26 SQM) - Teaching Space: 1	● Student Space (27)	
B00J - R0001 - Child Care Centre - (48.81 SQM)	● Student Space (22)	
B00J - R0002 - Child Care Centre - (9.06 SQM)	● Student Space (4)	
B00J - R0003 - Child Care Centre - (5.2 SQM)	● Student Space (2)	
B00J - R0004 - Child Care Centre - (13.74 SQM)	● Student Space (6)	
B00J - R0005 - Child Care Centre - (7.16 SQM)	● Student Space (3)	
B00J - R0010 - Child Care Centre - (43.74 SQM)	● Student Space (20)	
B00J - R0011 - Child Care Centre - (17.69 SQM)	● Student Space (8)	
B00J - R0012 - Child Care Centre - (9.89 SQM)	● Student Space (4)	
B00J - R0013 - Child Care Centre - (17.94 SQM)	● Student Space (8)	
B00J - R0014 - Child Care Centre - (20.38 SQM)	● Student Space (9)	
OS 602 10841 - OS 602 10841 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 13637 - OS 602 13637 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 15868 - OS 602 15868 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	