





## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R0003 - Seminar/Study - (79.12 SQM)	Office (19)	
B00E - R0004 - Home Base - (51.29 SQM) - Teaching Space: 1	Student Space (23)	
B00E - R0008 - General Learning Space - (51.22 SQM) - Teaching Space: 1	Student Space (23)	
B00E - R0015 - Entry Vestibule - (6.86 SQM)	Not Applicable	Circulation or storage space.
B00E - R0017 - Reading Area - (135.76 SQM)	Student Space (62)	
B00E - R0022 - Raised Platform - (27.21 SQM)	Not Applicable	Circulation or storage space.
B00E - R0023 - Movement - (33.48 SQM)	Not Applicable	Circulation or storage space.
B00E - R0037 - Entry Vestibule - (19.92 SQM)	Not Applicable	Circulation or storage space.
B00E - R0038 - Clerical Office - (30.45 SQM)	Office (7)	
B00E - R0039 - Duplicating Workroom - (30.82 SQM)	Office (7)	
B00E - R0040 - Interview - (19.62 SQM)	Office (4)	
B00E - R0041 - Principal - (27.06 SQM)	Office (6)	
B00E - R0042 - Deputy Principal - (23.27 SQM)	Office (5)	
B00E - R0043 - Movement - (141.03 SQM)	Not Applicable	Circulation or storage space.
B00E - R0049 - Movement - (38.24 SQM)	Not Applicable	Circulation or storage space.
B00E - R0050 - Movement - (11.25 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Home Base - (63.29 SQM) - Teaching Space: 1	Student Space (29)	
B00H - R0002 - Withdrawal Space - 1hb - (8.88 SQM)	Student Space (4)	
B00H - R0004 - Home Base - (63.37 SQM) - Teaching Space: 1	Student Space (29)	
B00H - R0005 - Withdrawal Space - 1hb - (8.88 SQM)	Student Space (4)	
B00H - R0007 - Practical Activities - 1hb - (162.93 SQM)	Student Space (75)	
B00H - R0011 - Home Base - (63.37 SQM) - Teaching Space: 1	Student Space (29)	
B00H - R0012 - Withdrawal Space - 1hb - (8.04 SQM)	Student Space (3)	
B00H - R0015 - Home Base - (63.37 SQM) - Teaching Space: 1	Student Space (29)	
B00H - R0016 - Withdrawal Space - 1hb - (8.86 SQM)	Student Space (4)	
B00H - R0019 - Movement - (22.23 SQM)	Not Applicable	Circulation or storage space.
B00I - R0004 - Staff Room - (6.64 SQM)	Office (1)	
B00I - R0006 - Movement - (5.35 SQM)	Not Applicable	Circulation or storage space.
B00I - R0007 - Hydrotherapy - Pool - (188.99 SQM)	Not Applicable	Circulation or storage space.
B00I - R0016 - Movement - (31.22 SQM)	Not Applicable	Circulation or storage space.
B00J - R0001 - Home Base - (57.57 SQM) - Teaching Space: 1	Student Space (26)	
B00J - R0002 - Withdrawal Space - 1hb - (9.01 SQM)	Student Space (4)	
B00J - R0004 - Practical Activities - 1hb - (83.8 SQM)	Student Space (38)	
B00J - R0010 - Home Base - (57.83 SQM) - Teaching Space: 1	Student Space (26)	
B00J - R0011 - Withdrawal Space - 1hb - (8.93 SQM)	Student Space (4)	
B00J - R0014 - Movement - (22.88 SQM)	Not Applicable	Circulation or storage space.
B00K - R0001 - Home Base - (63.37 SQM) - Teaching Space: 1	Student Space (29)	
B00K - R0002 - Withdrawal Space - 1hb - (8.86 SQM)	Student Space (4)	
B00K - R0004 - Home Base - (63.37 SQM) - Teaching Space: 1	Student Space (29)	
B00K - R0006 - Withdrawal Space - 1hb - (8.88 SQM)	Student Space (4)	
B00K - R0007 - Practical Activities - 1hb - (119.96 SQM)	Student Space (55)	
B00K - R0010 - Home Base - (63.73 SQM) - Teaching Space: 1	Student Space (29)	
B00K - R0011 - Withdrawal Space - 1hb - (8.77 SQM)	Student Space (4)	
B00K - R0013 - Home Base - (63.73 SQM) - Teaching Space: 1	Student Space (29)	
B00K - R0014 - Withdrawal Space - 1hb - (8.77 SQM)	Student Space (4)	
B00K - R0018 - Movement - (40.72 SQM)	Not Applicable	Circulation or storage space.
B00M - R0001 - Communal Space - (113.89 SQM)	Student Space (52)	
NS 120 10545 - NS 120 10545 - Learning Unit Primary Single - PWD - (76 SQM)	Student Space (35)	
NS 120 12822 - NS 120 12822 - Learning Unit Primary Single - PWD - (76 SQM)	Student Space (35)	

Entity Location	Audit Condition Classification (Capacity)	Comment
NS 120 12878 - NS 120 12878 - Learning Unit Primary Single - PWD - (76 SQM)	 Student Space (35)	
NS 120 13766 - NS 120 13766 - Learning Unit Primary Single - PWD - (76 SQM)	 Student Space (35)	