

VENTILATION AUDIT REPORT

SCHOOL:	Broken Hill Public School (1369)
AMU REGION:	North Western NSW
STATE ELECTORATE:	Barwon
LOCAL GOVERNMENT AREA:	Broken Hill

1369 - Broken Hill Public School
Site Plan (12397)



Printed: 20-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Home Base - (55.6 SQM) - Teaching Space: 1	● Student Space (25)	
B00A - R0003 - Movement - (20.19 SQM)	Not Applicable	Circulation or storage space.
B00A - R0005 - Staff Room - (55.77 SQM)	● Office (13)	
B00A - R0006 - Home Base - (55.85 SQM) - Teaching Space: 1	● Student Space (25)	
B00A - R0010 - Movement - (6.82 SQM)	Not Applicable	Circulation or storage space.
B00A - R0012 - Home Base - (55.77 SQM) - Teaching Space: 1	● Student Space (25)	
B00A - R0013 - Home Base - (55.53 SQM) - Teaching Space: 1	● Student Space (25)	
B00A - R0017 - Home Base - (55.69 SQM) - Teaching Space: 1	● Student Space (25)	
B00A - R0018 - Home Base - (55.85 SQM) - Teaching Space: 1	● Student Space (25)	
B00A - R0022 - Movement - (6.83 SQM)	Not Applicable	Circulation or storage space.
B00A - R0024 - Home Base - (55.92 SQM) - Teaching Space: 1	● Student Space (25)	
B00A - R0028 - Clerical Office - (15.58 SQM)	● Office (3)	
B00A - R0030 - Deputy Principal - (11.57 SQM)	● Office (2)	
B00A - R0031 - Entry Vestibule - (12.58 SQM)	Not Applicable	Circulation or storage space.
B00A - R0032 - Principal - (19.51 SQM)	● Office (4)	
B00A - R0035 - Sick Bay - (5.63 SQM)	● Student Space (2)	
B00A - R0041 - Movement - (326.81 SQM)	Not Applicable	Circulation or storage space.
B00A - R0042 - Staff Room Annexe - (15.4 SQM)	● Office (3)	
B00A - R0043 - Practical Activities - (10.81 SQM)	● Student Space (5)	
B00A - R0044 - Home Base - (80.26 SQM) - Teaching Space: 1	● Student Space (37)	
B00A - R0047 - Clerical Office - (39.39 SQM)	● Office (9)	
B00A - R0048 - Entry Vestibule - (19.03 SQM)	Not Applicable	Circulation or storage space.
B00A - R9004 - Movement - (24.9 SQM)	Not Applicable	Circulation or storage space.
B00A - R9005 - Communal Space - (195.01 SQM)	● Student Space (90)	
B00A - R9007 - Movement - (18 SQM)	Not Applicable	Circulation or storage space.
B00A - R9008 - Movement - (24.9 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Canteen - (17.23 SQM)	Not Applicable	Circulation or storage space.
B00B - R0005 - Reading Area - (168.5 SQM)	● Student Space (78)	
B00B - R0009 - Communal Space - (166.03 SQM)	● Student Space (77)	
B00B - R0010 - Movement - (41.13 SQM)	Not Applicable	Circulation or storage space.
B00B - R1001 - Home Base - (55.76 SQM) - Teaching Space: 1	● Student Space (25)	
B00B - R1003 - Withdrawal Space - 1hb - (6.55 SQM)	● Student Space (3)	
B00B - R1004 - Movement - (5.52 SQM)	Not Applicable	Circulation or storage space.
B00B - R1006 - Home Base - (55.69 SQM) - Teaching Space: 1	● Student Space (25)	
B00B - R1007 - Home Base - (71.98 SQM) - Teaching Space: 1	● Student Space (33)	
B00B - R1016 - Movement - (7.45 SQM)	Not Applicable	Circulation or storage space.
B00B - R1017 - Staff Room Annexe - (15.58 SQM)	● Office (3)	
B00B - R1018 - Withdrawal Space - 1hb - (23.47 SQM)	● Student Space (10)	
B00B - R1019 - Home Base - (55.84 SQM) - Teaching Space: 1	● Student Space (25)	
B00B - R1021 - Home Base - (55.83 SQM) - Teaching Space: 1	● Student Space (25)	
B00B - R1024 - Home Base - (55.68 SQM) - Teaching Space: 1	● Student Space (25)	
B00B - R1025 - Movement - (181.18 SQM)	Not Applicable	Circulation or storage space.
B00B - R1027 - Special Programs Room - (47.02 SQM)	● Student Space (21)	
B00C - R0004 - Movement - (61.64 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Entry Vestibule - (13.91 SQM)	Not Applicable	Circulation or storage space.
B00D - R0005 - Home Base - Pre - (69.04 SQM) - Teaching Space: 1	● Student Space (32)	
B00D - R0006 - Practical Activities - Pre - (46.35 SQM)	● Student Space (21)	
B00D - R0015 - Movement - (69.42 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Movement - (5.18 SQM)	Not Applicable	Circulation or storage space.
B00F - R0003 - Movement - (11.99 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00F - R0006 - Clerical Office - (12.76 SQM)	 Office (3)	
B00F - R0009 - Clerical Office - (16.86 SQM)	 Office (4)	