

VENTILATION AUDIT REPORT

SCHOOL:	Bronte Public School (1372)
AMU REGION:	Sydney
STATE ELECTORATE:	Coogee
LOCAL GOVERNMENT AREA:	Waverley

1372 - Bronte Public School
Site Plan (12400)
















1:481

Printed: 29-Aug-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Home Base - (50.98 SQM)	● Student Space (23)	
B00A - R0003 - Withdrawal Space - 1hb - (46.51 SQM)	● Student Space (21)	
B00A - R0004 - Home Base - (61.56 SQM) - Teaching Space: 1	● Student Space (28)	
B00A - R0007 - Movement - (25.26 SQM)	Not Applicable	Circulation or storage space.
B00A - R0008 - Principal - (12.31 SQM)	● Office (3)	
B00A - R0009 - Movement - (5.45 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Movement - (6.77 SQM)	Not Applicable	Circulation or storage space.
B00A - R0011 - Movement - (26.51 SQM)	Not Applicable	Circulation or storage space.
B00A - R0013 - Duplicating Workroom - (12.73 SQM)	● Office (3)	
B00A - R0018 - Movement - (8.75 SQM)	Not Applicable	Circulation or storage space.
B00A - R0019 - Home Base - (48.93 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R0021 - Clerical Office - (16.64 SQM)	● Office (4)	
B00A - R1001 - Home Base - (52.56 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R1002 - Staff Room - (49.54 SQM)	● Office (12)	
B00A - R1003 - Home Base - (50.63 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R1006 - Movement - (9.25 SQM)	Not Applicable	Circulation or storage space.
B00A - R1007 - Staff Room Annexe - (17.76 SQM)	● Office (4)	
B00A - R1009 - Movement - (16.6 SQM)	Not Applicable	Circulation or storage space.
B00B - R0003 - Movement - (42.14 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Practical Activities - 1hb - (20.62 SQM)	● Student Space (9)	
B00B - R0005 - Home Base - (51.74 SQM)	● Student Space (24)	
B00B - R0006 - Home Base - (47.79 SQM)	● Student Space (22)	
B00B - R0007 - Practical Activities - 1hb - (20.7 SQM)	● Student Space (9)	
B00B - R0011 - Home Base - (57.48 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R0012 - Withdrawal Space - 2hb - (7.78 SQM)	● Student Space (3)	
B00B - R0013 - Home Base - (56.25 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R1003 - Movement - (57.68 SQM)	Not Applicable	Circulation or storage space.
B00B - R1004 - Practical Activities - 1hb - (20.67 SQM)	● Student Space (9)	
B00B - R1005 - Home Base - (51.88 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1006 - Home Base - (47.95 SQM) - Teaching Space: 1	● Student Space (22)	
B00B - R1007 - Practical Activities - 1hb - (20.65 SQM)	● Student Space (9)	
B00D - R0001 - Movement - (12.25 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Home Base - (46.91 SQM) - Teaching Space: 1	● Student Space (21)	
B00D - R0003 - Practical Activities - 1hb - (8.7 SQM)	● Student Space (4)	
B00F - R0007 - Canteen - (18.34 SQM)	Not Applicable	Circulation or storage space.
B00F - R0013 - Communal Space - (187.1 SQM)	● Student Space (86)	
B00F - R0014 - Raised Platform - (38.38 SQM)	Not Applicable	Circulation or storage space.
B00F - R0015 - Movement - (8.43 SQM)	Not Applicable	Circulation or storage space.
B00F - R0016 - Movement - (6.74 SQM)	Not Applicable	Circulation or storage space.
B00H - R0003 - Reading Area - (160.46 SQM)	● Student Space (74)	
B00H - R0006 - Movement - (82.49 SQM)	Not Applicable	Circulation or storage space.
B00H - R0007 - Practical Activities - 1hb - (19.37 SQM)	● Student Space (8)	
B00H - R0009 - Home Base - (60.6 SQM) - Teaching Space: 1	● Student Space (28)	
B00H - R0010 - Withdrawal Space - 2hb - (11.64 SQM)	● Student Space (5)	
B00H - R0011 - Home Base - (60.32 SQM) - Teaching Space: 1	● Student Space (27)	
B00H - R0013 - Practical Activities - 1hb - (18.74 SQM)	● Student Space (8)	
B00H - R9003 - Practical Activities - 1hb - (18.93 SQM)	● Student Space (8)	
B00H - R9005 - Home Base - (60.29 SQM) - Teaching Space: 1	● Student Space (27)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00H - R9006 - Withdrawal Space - 2hb - (11.76 SQM)	 Student Space (5)	
B00H - R9007 - Home Base - (59.96 SQM) - Teaching Space: 1	 Student Space (27)	
B00H - R9009 - Practical Activities - 1hb - (19.13 SQM)	 Student Space (8)	
B00I - R0002 - Practical Activities - 1hb - (18.21 SQM)	 Student Space (8)	
B00I - R0003 - Home Base - (60.62 SQM) - Teaching Space: 1	 Student Space (28)	
B00I - R0004 - Withdrawal Space - 2hb - (12.68 SQM)	 Student Space (5)	
B00I - R0005 - Home Base - (60.5 SQM) - Teaching Space: 1	 Student Space (28)	
B00I - R0006 - Practical Activities - 1hb - (18.19 SQM)	 Student Space (8)	
B00I - R1002 - Practical Activities - 1hb - (18.48 SQM)	 Student Space (8)	
B00I - R1003 - Home Base - (60.51 SQM) - Teaching Space: 1	 Student Space (28)	
B00I - R1004 - Withdrawal Space - 2hb - (12.24 SQM)	 Student Space (5)	
B00I - R1005 - Home Base - (60.59 SQM) - Teaching Space: 1	 Student Space (28)	
B00I - R1006 - Practical Activities - 1hb - (18.42 SQM)	 Student Space (8)	