

VENTILATION AUDIT REPORT

SCHOOL:	Brunswick Heads Public School (1389)
AMU REGION:	North Coast
STATE ELECTORATE:	Ballina
LOCAL GOVERNMENT AREA:	Byron

1389 - Brunswick Heads Public School
Site Plan (13126)



1:546

Printed: 17-Apr-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Sick Bay - (13.14 SQM)	● Student Space (6)	
B00A - R0003 - Principal - (10.72 SQM)	● Office (2)	
B00A - R0004 - Deputy Principal - (9.69 SQM)	● Office (2)	
B00A - R0008 - Withdrawal Space - 2hb - (38.37 SQM)	● Student Space (17)	
B00A - R0010 - Practical Activities - 1hb - (14.75 SQM)	● Student Space (6)	
B00A - R0014 - Clerical Office - (20.14 SQM)	● Office (5)	
B00A - R0016 - Entry Vestibule - (12.4 SQM)	Not Applicable	Circulation or storage space.
B00A - R0017 - Clerical/Printing - (8.92 SQM)	Not Applicable	Circulation or storage space.
B00B - R0006 - Special Programs Room - (32.98 SQM)	● Student Space (15)	
B00B - R1006 - Practical Activities - 1hb - (7.17 SQM)	● Student Space (3)	
B00B - R1008 - Home Base - (60.95 SQM) - Teaching Space: 1	● Student Space (28)	
B00B - R1009 - Duplicating Workroom - (18.15 SQM)	● Office (4)	
B00B - R1010 - Movement - (11.73 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Home Base - (72.18 SQM) - Teaching Space: 1	● Student Space (33)	
B00E - R0007 - Home Base - (60.75 SQM) - Teaching Space: 1	● Student Space (28)	
B00E - R0009 - Movement - (6.49 SQM)	Not Applicable	Circulation or storage space.
B00E - R0011 - Reading Area - (112.14 SQM)	● Student Space (52)	
B00E - R0014 - Movement - (17.43 SQM)	Not Applicable	Circulation or storage space.
B00E - R1001 - Movement - (52.93 SQM)	Not Applicable	Circulation or storage space.
B00E - R1002 - Home Base - (84.4 SQM) - Teaching Space: 1	● Student Space (39)	
B00E - R1003 - Withdrawal Space - 1hb - (8.2 SQM)	● Student Space (3)	
B00E - R1007 - Home Base - (60.59 SQM) - Teaching Space: 1	● Student Space (28)	
B00E - R1009 - Movement - (6.51 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Staff Room - (34.02 SQM)	● Office (8)	
B00F - R0005 - Movement - (5.57 SQM)	Not Applicable	Circulation or storage space.
B00F - R0007 - Raised Platform - (20.97 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Practical Activities - 1hb - (20.03 SQM)	● Student Space (9)	
B00G - R0005 - Home Base - (59.21 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R0006 - Withdrawal Space - 1hb - (9.74 SQM)	● Student Space (4)	
B00G - R0007 - Home Base - (59.22 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R0009 - Practical Activities - 1hb - (20.05 SQM)	● Student Space (9)	
B00J - R0001 - Communal Space - (145.66 SQM)	● Student Space (67)	
B00J - R0002 - Raised Platform - (60.22 SQM)	Not Applicable	Circulation or storage space.
B00J - R0016 - Movement - (6.19 SQM)	Not Applicable	Circulation or storage space.
B00J - R0018 - Movement - (13.03 SQM)	Not Applicable	Circulation or storage space.
OS 606 13829 - OS 606 13829 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 606 19117 - OS 606 19117 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 606 19600 - OS 606 19600 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 801 12043 - OS 801 12043 - FSU - (57 SQM)	Not Applicable	Circulation or storage space.