



VENTILATION AUDIT REPORT

SCHOOL:	Budgewoi Public School (4183)
AMU REGION:	Hunter/Central Coast
STATE ELECTORATE:	Swansea
LOCAL GOVERNMENT AREA:	Central Coast

4183 - Budgewoi Public School
Site Plan (11593)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (9.05 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Home Base - (56.85 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R0005 - Movement - (11.2 SQM)	Not Applicable	Circulation or storage space.
B00A - R0007 - Home Base - (77.94 SQM) - Teaching Space: 1	● Student Space (36)	
B00A - R0008 - Home Base - (56.84 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R0010 - Movement - (8.82 SQM)	Not Applicable	Circulation or storage space.
B00A - R0011 - Movement - (6.28 SQM)	Not Applicable	Circulation or storage space.
B00A - R0013 - Special Programs Room - (52.78 SQM)	● Student Space (24)	
B00B - R0005 - Home Base - (57.98 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R0007 - Movement - (7.17 SQM)	Not Applicable	Circulation or storage space.
B00B - R0008 - Movement - (5.95 SQM)	Not Applicable	Circulation or storage space.
B00B - R0010 - Home Base - (57.99 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R0011 - Home Base - (58.15 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R0013 - Interview - (23.92 SQM)	○ Office (5)	
B00B - R0015 - Movement - (5.9 SQM)	Not Applicable	Circulation or storage space.
B00B - R0016 - Movement - (7.97 SQM)	Not Applicable	Circulation or storage space.
B00C - R0009 - Movement - (41.08 SQM)	Not Applicable	Circulation or storage space.
B00C - R0011 - Movement - (16.68 SQM)	Not Applicable	Circulation or storage space.
B00C - R0014 - Movement - (22.89 SQM)	Not Applicable	Circulation or storage space.
B00C - R1003 - Movement - (6.37 SQM)	Not Applicable	Circulation or storage space.
B00C - R1005 - Staff Room Annexe - (26.8 SQM)	○ Office (6)	
B00C - R1006 - Staff Room - (51.37 SQM)	○ Office (12)	
B00C - R1007 - Staff Room Annexe - (14.25 SQM)	○ Office (3)	
B00C - R1011 - Home Base - (56.13 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R1012 - Home Base - (56.93 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R1016 - Home Base - (56.13 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R1017 - Movement - (92.32 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Movement - (66.69 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Canteen - (46.37 SQM)	Not Applicable	Circulation or storage space.
B00E - R0003 - Movement - (23.09 SQM)	Not Applicable	Circulation or storage space.
B00E - R0008 - Movement - (14.98 SQM)	Not Applicable	Circulation or storage space.
B00E - R0018 - Raised Platform - (51.4 SQM)	Not Applicable	Circulation or storage space.
B00E - R0019 - Communal Space - (199.09 SQM)	● Student Space (92)	
B00E - R0022 - Movement - (6.69 SQM)	Not Applicable	Circulation or storage space.
B00F - R0003 - Movement - (18.94 SQM)	Not Applicable	Circulation or storage space.
B00F - R0006 - Special Programs Room - (42.83 SQM)	● Student Space (19)	
B00F - R0007 - Entry Vestibule - (20.03 SQM)	Not Applicable	Circulation or storage space.
B00F - R0008 - Reading Area - (217.28 SQM)	● Student Space (100)	
B00F - R0011 - Movement - (13.61 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Movement - (8.75 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Entry Vestibule - (14.77 SQM)	Not Applicable	Circulation or storage space.
B00G - R0003 - Clerical Office - (13.82 SQM)	○ Office (3)	
B00G - R0004 - Sick Bay - (9.33 SQM)	● Student Space (4)	
B00G - R0008 - Principal - (15.85 SQM)	○ Office (3)	
B00G - R0010 - Staff Room Annexe - (13.72 SQM)	○ Office (3)	
B00G - R0011 - Movement - (6.48 SQM)	Not Applicable	Circulation or storage space.
B00G - R0012 - Entry Vestibule - (14.7 SQM)	Not Applicable	Circulation or storage space.
B00G - R0013 - Staff Room Annexe - (13.8 SQM)	○ Office (3)	
B00G - R0017 - Duplicating Workroom - (34.35 SQM)	○ Office (8)	
B00G - R0018 - Interview - (14.07 SQM)	○ Office (3)	
B00G - R0019 - Movement - (25.13 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R0020 - Movement - (5.51 SQM)	Not Applicable	Circulation or storage space.
B00H - R0002 - Practical Activities - 1hb - (10.28 SQM)	● Student Space (4)	
B00H - R0003 - Home Base - (64.48 SQM) - Teaching Space: 1	● Student Space (29)	
B00H - R0004 - Home Base - (64.49 SQM) - Teaching Space: 1	● Student Space (29)	
B00H - R0005 - Practical Activities - 1hb - (10.28 SQM)	● Student Space (4)	
B00H - R0006 - Movement - (39.57 SQM)	Not Applicable	Circulation or storage space.
B00H - R1002 - Practical Activities - 1hb - (10.28 SQM)	● Student Space (4)	
B00H - R1003 - Home Base - (64.48 SQM) - Teaching Space: 1	● Student Space (29)	
B00H - R1004 - Home Base - (64.49 SQM) - Teaching Space: 1	● Student Space (29)	
B00H - R1005 - Practical Activities - 1hb - (10.28 SQM)	● Student Space (4)	
B00H - R1006 - Movement - (39.57 SQM)	Not Applicable	Circulation or storage space.
B00I - R0002 - Canteen - (13.11 SQM)	Not Applicable	Circulation or storage space.
B00I - R0005 - Movement - (28.93 SQM)	Not Applicable	Circulation or storage space.
B00J - R0001 - Practical Activities - 1hb - (19.75 SQM)	● Student Space (9)	
B00J - R0003 - Home Base - (59.33 SQM) - Teaching Space: 1	● Student Space (27)	
B00J - R0004 - Withdrawal Space - 2hb - (11.62 SQM)	● Student Space (5)	
B00J - R0005 - Home Base - (59.96 SQM) - Teaching Space: 1	● Student Space (27)	
B00J - R0006 - Practical Activities - 1hb - (19.19 SQM)	● Student Space (8)	
B00J - R0010 - Movement - (90.44 SQM)	Not Applicable	Circulation or storage space.
B00J - R1003 - Practical Activities - 1hb - (19.04 SQM)	● Student Space (8)	
B00J - R1005 - Home Base - (59.75 SQM) - Teaching Space: 1	● Student Space (27)	
B00J - R1006 - Withdrawal Space - 2hb - (11.69 SQM)	● Student Space (5)	
B00J - R1007 - Home Base - (59.76 SQM) - Teaching Space: 1	● Student Space (27)	
B00J - R1008 - Practical Activities - 1hb - (18.92 SQM)	● Student Space (8)	
B00J - R1010 - Movement - (52.26 SQM)	Not Applicable	Circulation or storage space.
B00J - R1011 - Movement - (77.17 SQM)	Not Applicable	Circulation or storage space.
B00K - R0001 - Practical Activities - 1hb - (17.06 SQM)	● Student Space (7)	
B00K - R0003 - Withdrawal Space - 1hb - (8.85 SQM)	● Student Space (4)	
B00K - R0005 - Home Base - (58.25 SQM) - Teaching Space: 1	● Student Space (27)	
B00K - R0009 - Practical Activities - 1hb - (14.18 SQM)	● Student Space (6)	
B00K - R0012 - Home Base - (60.34 SQM) - Teaching Space: 1	● Student Space (27)	
B00K - R0013 - Withdrawal Space - 2hb - (11.55 SQM)	● Student Space (5)	
B00K - R0014 - Practical Activities - 1hb - (14.32 SQM)	● Student Space (6)	
B00K - R0017 - Home Base - (60.28 SQM) - Teaching Space: 1	● Student Space (27)	
B00K - R1001 - Practical Activities - 1hb - (13.79 SQM)	● Student Space (6)	
B00K - R1004 - Home Base - (60.34 SQM) - Teaching Space: 1	● Student Space (27)	
B00K - R1005 - Withdrawal Space - 2hb - (11.51 SQM)	● Student Space (5)	
B00K - R1006 - Practical Activities - 1hb - (14.11 SQM)	● Student Space (6)	
B00K - R1009 - Home Base - (60.34 SQM) - Teaching Space: 1	● Student Space (27)	
B00K - R1010 - Practical Activities - 1hb - (16.39 SQM)	● Student Space (7)	
B00K - R1012 - Home Base - (57.17 SQM) - Teaching Space: 1	● Student Space (26)	
B00K - R1014 - Withdrawal Space - 1hb - (9.14 SQM)	● Student Space (4)	
NS 020 10508 - NS 020 10508 - Staff Study/Store - (38 SQM)	Not Applicable	Circulation or storage space.
OS 601 15317 - OS 601 15317 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 602 10057 - OS 602 10057 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 12501 - OS 602 12501 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	