

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Bulahdelah Central School (1402)</b>
<b>AMU REGION:</b>	<b>North Coast</b>
<b>STATE ELECTORATE:</b>	<b>Myall Lakes</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Mid-Coast</b>

1402 - Bulahdelah Central School  
Site Plan (13369)



1:1,252

Printed: 08-Sep-2021

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0004 - Staff Room Annexe - (22.3 SQM)	Office (5)	
B00A - R0005 - General Learning Space - (53.79 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R0008 - Computer Learning Space - (53.48 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R0012 - Food Technology L.S. - (133.93 SQM) - Teaching Space: 1	Student Space (62)	
B00B - R0002 - Staff Lounge - (97.09 SQM)	Office (24)	
B00B - R0008 - Staff Kitchen - (9.39 SQM)	Office (2)	
B00B - R0010 - Movement - (7.57 SQM)	Not Applicable	Circulation or storage space.
B00B - R0011 - Staff Room Annexe - (9.04 SQM)	Office (2)	
B00C - R0006 - Interview/Office - Type 1 - (27.01 SQM)	Office (6)	
B00C - R0007 - Seminar/Study - (12.83 SQM)	Office (3)	
B00C - R0008 - General Learning Space - Type 2 - (129.62 SQM) - Teaching Space: 1	Student Space (60)	
B00C - R0009 - Entry Vestibule - (22.04 SQM)	Not Applicable	Circulation or storage space.
B00C - R0011 - Ancillary Staff - (13.29 SQM)	Office (3)	
B00F - R0007 - Withdrawal Space - 1hb - (14.26 SQM)	Student Space (6)	
B00F - R0008 - Welding Area - (13.39 SQM)	Not Applicable	Circulation or storage space.
B00F - R0010 - Materials Technology L.S. - (127.57 SQM) - Teaching Space: 1	Student Space (59)	
B00G - R0009 - Canteen - (31.9 SQM)	Not Applicable	Circulation or storage space.
B00G - R0012 - Communal Space - (163.23 SQM)	Student Space (75)	
B00G - R0017 - Movement - (38.35 SQM)	Not Applicable	Circulation or storage space.
B00G - R0028 - Stage - (78 SQM)	Not Applicable	Circulation or storage space.
B00G - R0031 - Preparation - (12.31 SQM)	Not Applicable	Circulation or storage space.
B00G - R1001 - Movement - (8 SQM)	Not Applicable	Circulation or storage space.
B00G - R1006 - Staff Kitchen - (15.29 SQM)	Office (3)	
B00G - R1011 - Staff Study - (191.83 SQM)	Office (47)	
B00G - R1012 - Interview/Office - Type 1 - (19.43 SQM)	Office (4)	
B00H - R0001 - Interview/Meeting - (24.44 SQM)	Office (6)	
B00H - R0005 - Duplicating Workroom - (21.37 SQM)	Office (5)	
B00H - R0011 - Staff Room Annexe - (12.4 SQM)	Office (3)	
B00H - R0015 - Sick Bay - (12.05 SQM)	Student Space (5)	
B00H - R0021 - Principal - (18.96 SQM)	Office (4)	
B00H - R0022 - Entry Vestibule - (22.43 SQM)	Not Applicable	Circulation or storage space.
B00H - R0023 - Interview/Office - Type 1 - (13.3 SQM)	Office (3)	
B00H - R0024 - Movement - (15.41 SQM)	Not Applicable	Circulation or storage space.
B00H - R0025 - Administration - Clerical - (61.61 SQM)	Office (15)	
B00H - R0026 - Staff Kitchen - (5.16 SQM)	Office (1)	
B00H - R0029 - Student Reception - (10.09 SQM)	Not Applicable	Circulation or storage space.
B00H - R0030 - Movement - (11.82 SQM)	Not Applicable	Circulation or storage space.
B00H - R0031 - Deputy Principal - (13.3 SQM)	Office (3)	
B00J - R0002 - Movement - (9.92 SQM)	Not Applicable	Circulation or storage space.
B00J - R0003 - Home Base - (56.36 SQM) - Teaching Space: 1	Student Space (26)	
B00J - R0004 - Home Base - (56.43 SQM) - Teaching Space: 1	Student Space (26)	
B00J - R0006 - Movement - (17.27 SQM)	Not Applicable	Circulation or storage space.
B00J - R0009 - Home Base - (56.52 SQM) - Teaching Space: 1	Student Space (26)	
B00J - R0010 - Home Base - (78.2 SQM) - Teaching Space: 1	Student Space (36)	
B00J - R9003 - Movement - (29.74 SQM)	Not Applicable	Circulation or storage space.
B00K - R0002 - Special Programs Room - (58.11 SQM)	Student Space (26)	
B00K - R0004 - Movement - (17.18 SQM)	Not Applicable	Circulation or storage space.
B00K - R0007 - Home Base - (58.34 SQM) - Teaching Space: 1	Student Space (27)	
B00L - R0002 - Movement - (10.92 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00L - R0003 - General Learning Space - (53.49 SQM) - Teaching Space: 1	● Student Space (24)	
B00M - R0002 - General Learning Space - (43.81 SQM) - Teaching Space: 1	● Student Space (20)	
B00R - R0001 - Practice/Seminar - (18.18 SQM)	Not Applicable	Circulation or storage space.
B00R - R0002 - General Learning Space - (59.43 SQM) - Teaching Space: 1	● Student Space (27)	
B00R - R0003 - General Learning Space - (59.01 SQM) - Teaching Space: 1	● Student Space (27)	
B00R - R1001 - General Learning Space - (59.7 SQM) - Teaching Space: 1	● Student Space (27)	
B00R - R1002 - General Learning Space - (59.92 SQM) - Teaching Space: 1	● Student Space (27)	
B00R - R1003 - Visual Arts Workshop - (99.83 SQM)	● Student Space (46)	
B00R - R1007 - Welding Area - (12.14 SQM)	Not Applicable	Circulation or storage space.
B00R - R1011 - Outdoor Workshop - (84.65 SQM)	Not Applicable	Circulation or storage space.
B00S - R0001 - Gymnasium - (481.79 SQM)	● Student Space (223)	
B00V - R0001 - General Learning Space - Type 2 - (91.59 SQM) - Teaching Space: 1	● Student Space (42)	
B00V - R0002 - Seminar - Type 2 - (18.7 SQM)	● Office (4)	
B00W - R0008 - Reading Area - (200.04 SQM)	● Student Space (92)	
B00W - R0011 - Seminar/Study - (16.73 SQM)	● Office (4)	
B00W - R0012 - Seminar/Study - (10.76 SQM)	● Office (2)	
B00Y - R0003 - Kitchen - Type 2 - (95.21 SQM)	● Student Space (44)	
B00Y - R0004 - Preparation - Materials - (18.61 SQM)	Not Applicable	Circulation or storage space.
B0DD - R0003 - General Assistants - (16.9 SQM)	● Office (4)	
B0NN - R0001 - General Learning Space - (59.77 SQM) - Teaching Space: 1	● Student Space (27)	
B0NN - R0002 - Shared Learning Space - (75.07 SQM)	● Student Space (34)	
B0NN - R0003 - Practical Activity Area - (24.36 SQM)	● Student Space (11)	
B0NN - R0004 - General Learning Space - (64.66 SQM) - Teaching Space: 1	● Student Space (29)	
B0NN - R0010 - General Learning Space - (59.44 SQM) - Teaching Space: 1	● Student Space (27)	
B0NN - R0011 - General Learning Space - (59.85 SQM) - Teaching Space: 1	● Student Space (27)	
B0NN - R0012 - General Learning Space - (59.86 SQM) - Teaching Space: 1	● Student Space (27)	
B0NN - R0013 - Seminar - (24.72 SQM)	● Office (6)	
B0NN - R0014 - General Learning Space - (59.52 SQM) - Teaching Space: 1	● Student Space (27)	
B0NN - R0017 - Movement - (71.11 SQM)	Not Applicable	Circulation or storage space.
B0OO - R0001 - General Learning Space - (59.54 SQM) - Teaching Space: 1	● Student Space (27)	
B0OO - R0002 - Shared Learning Space - (50.37 SQM)	● Student Space (23)	
B0OO - R0003 - General Learning Space - (64.33 SQM) - Teaching Space: 1	● Student Space (29)	
B0OO - R0004 - Practical Activity Area - (15.98 SQM)	● Student Space (7)	
B0OO - R0008 - General Learning Space - (59.62 SQM) - Teaching Space: 1	● Student Space (27)	
B0OO - R0009 - General Learning Space - (60.28 SQM) - Teaching Space: 1	● Student Space (27)	
B0OO - R0010 - General Learning Space - (59.1 SQM) - Teaching Space: 1	● Student Space (27)	
B0OO - R0011 - Seminar - (25.58 SQM)	● Office (6)	
B0OO - R0013 - Movement - (46.55 SQM)	Not Applicable	Circulation or storage space.
B0PP - R0001 - General Learning Space - (60.18 SQM) - Teaching Space: 1	● Student Space (27)	
B0PP - R0002 - General Learning Space - (60.35 SQM) - Teaching Space: 1	● Student Space (27)	
B0PP - R0007 - General Learning Space - (46.04 SQM) - Teaching Space: 1	● Student Space (21)	
B0PP - R0008 - Laboratory L.S. - (75.02 SQM) - Teaching Space: 1	● Student Space (34)	
B0PP - R0009 - Preparation - Science - (49.75 SQM)	Not Applicable	Circulation or storage space.
B0PP - R0010 - Laboratory L.S. - (100.28 SQM) - Teaching Space: 1	● Student Space (46)	
B0RR - R0001 - Dark Room - (28.42 SQM)	● Office (7)	
NS 270 13186 - NS 270 13186 - Metal Technics/Heat Area/Storage - (95 SQM)	● Student Space (44)	
OS 616 19837 - OS 616 19837 - Learning Unit - Double Secondary - (133 SQM)	● Student Space (61)	