


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Bundanoon Public School (1414)</b>
<b>AMU REGION:</b>	<b>Southern NSW</b>
<b>STATE ELECTORATE:</b>	<b>Goulburn</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Wingecarribee</b>

1414 - Bundanoon Public School  
Site Plan (12407)



1:854

Printed: 02-Jul-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0007 - Interview - (13.14 SQM)	Office (3)	
B00A - R0009 - Principal - (14.53 SQM)	Office (3)	
B00A - R0010 - Clerical Office - (13.39 SQM)	Office (3)	
B00A - R0011 - Movement - (7.2 SQM)	Not Applicable	Circulation or storage space.
B00A - R0012 - Movement - (17.82 SQM)	Not Applicable	Circulation or storage space.
B00A - R0013 - Duplicating Workroom - (19.07 SQM)	Office (4)	
B00A - R0014 - Clerical Office/Workroom - (16.82 SQM)	Office (4)	
B00A - R0017 - Staff Kitchen - (15.9 SQM)	Office (3)	
B00A - R0018 - Staff Room - (38 SQM)	Office (9)	
B00A - R0019 - Movement - (12.26 SQM)	Not Applicable	Circulation or storage space.
B00B - R0003 - Movement - (7.27 SQM)	Not Applicable	Circulation or storage space.
B00B - R0007 - Movement - (15.85 SQM)	Not Applicable	Circulation or storage space.
B00B - R0009 - Reading Area - (99.31 SQM)	Student Space (46)	
B00C - R0001 - Practical Activities - 1hb - (46.85 SQM)	Student Space (21)	
B00C - R0004 - Home Base - (52.06 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0006 - Movement - (8.03 SQM)	Not Applicable	Circulation or storage space.
B00C - R0007 - Movement - (17.11 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Movement - (67.13 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Practical Activities - 1hb - (17.59 SQM)	Student Space (8)	
B00F - R0003 - Home Base - (59.62 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R0005 - Movement - (13.76 SQM)	Not Applicable	Circulation or storage space.
B00F - R0006 - Withdrawal Space - 1hb - (11.59 SQM)	Student Space (5)	
B00F - R0007 - Movement - (13.78 SQM)	Not Applicable	Circulation or storage space.
B00F - R0008 - Home Base - (59.59 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R0009 - Practical Activities - 1hb - (17.51 SQM)	Student Space (8)	
B00F - R0012 - Movement - (13.72 SQM)	Not Applicable	Circulation or storage space.
B00F - R0013 - Home Base - (59.44 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R0014 - Practical Activities - 1hb - (17.59 SQM)	Student Space (8)	
B00F - R0015 - Withdrawal Space - 1hb - (11.68 SQM)	Student Space (5)	
B00F - R0016 - Movement - (13.81 SQM)	Not Applicable	Circulation or storage space.
B00F - R0018 - Home Base - (59.57 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R0019 - Practical Activities - 1hb - (17.73 SQM)	Student Space (8)	
B00H - R0001 - Communal Space - (140.52 SQM)	Student Space (65)	
B00H - R0002 - Raised Platform - (61.5 SQM)	Not Applicable	Circulation or storage space.
B00H - R0016 - Movement - (7.88 SQM)	Not Applicable	Circulation or storage space.
B00H - R0017 - Movement - (14.13 SQM)	Not Applicable	Circulation or storage space.
NS 300 15109 - NS 300 15109 - FSU/Bulk Store/Toilet - (57 SQM)	Not Applicable	Circulation or storage space.
OS 602 15803 - OS 602 15803 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 603 14857 - OS 603 14857 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	Student Space (35)	