

VENTILATION AUDIT REPORT

SCHOOL:	Bundeena Public School (3765)
AMU REGION:	Sydney
STATE ELECTORATE:	Heathcote
LOCAL GOVERNMENT AREA:	Sutherland

3765 - Bundeena Public School
Site Plan (12408)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0004 - Movement - (6.32 SQM)	Not Applicable	Circulation or storage space.
B00A - R0015 - Home Base - (56.95 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R0016 - Special Programs Room - (56.96 SQM)	● Student Space (26)	
B00A - R0025 - Sick Bay - (9.39 SQM)	● Student Space (4)	
B00A - R0026 - Entry Vestibule - (12.29 SQM)	Not Applicable	Circulation or storage space.
B00A - R0030 - Principal - (18.64 SQM)	● Office (4)	
B00A - R0032 - Clerical Office/Workroom - (24.59 SQM)	● Office (6)	
B00A - R0033 - Clerical/Printing - (20.52 SQM)	Not Applicable	Circulation or storage space.
B00B - R0008 - Reading Area - (16.99 SQM)	● Student Space (7)	
B00B - R0009 - Movement - (13.77 SQM)	Not Applicable	Circulation or storage space.
B00B - R0011 - Staff Room - (51.28 SQM)	● Office (12)	
B00B - R0012 - Staff Kitchen - (9.59 SQM)	● Office (2)	
B00B - R0014 - Movement - (12.19 SQM)	Not Applicable	Circulation or storage space.
B00B - R0015 - Interview - (27.35 SQM)	● Office (6)	
B00C - R0002 - Canteen - (28.34 SQM)	Not Applicable	Circulation or storage space.
B00C - R0009 - Withdrawal Space - 1hb - (13.87 SQM)	● Student Space (6)	
B00C - R0010 - Communal Space - (207.53 SQM)	● Student Space (96)	
B00C - R0021 - Raised Platform - (48.52 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Home Base - (78.31 SQM) - Teaching Space: 1	● Student Space (36)	
B00F - R0003 - Home Base - (53.43 SQM) - Teaching Space: 1	● Student Space (24)	
B00F - R0004 - Special Programs Room - (16.63 SQM)	● Student Space (7)	
B00F - R0006 - Withdrawal Space - 1hb - (10.41 SQM)	● Student Space (4)	
B00G - R0008 - Movement - (26.75 SQM)	Not Applicable	Circulation or storage space.
B00G - R0009 - Home Base - (89.46 SQM) - Teaching Space: 1	● Student Space (41)	
B00J - R0003 - Home Base - (51.76 SQM) - Teaching Space: 1	● Student Space (24)	
B00J - R0004 - Withdrawal Space - 1hb - (12.88 SQM)	● Student Space (5)	
B00Q - R0002 - Practical Activities - 1hb - (15.74 SQM)	● Student Space (7)	
B00Q - R0003 - Home Base - (60.48 SQM) - Teaching Space: 1	● Student Space (28)	
B00Q - R0005 - Withdrawal Space - 1hb - (13.97 SQM)	● Student Space (6)	
B00Q - R0006 - Withdrawal Space - 1hb - (11.93 SQM)	● Student Space (5)	
B00Q - R0007 - Withdrawal Space - 1hb - (13.92 SQM)	● Student Space (6)	
B00Q - R0009 - Home Base - (60.75 SQM) - Teaching Space: 1	● Student Space (28)	
B00Q - R0010 - Practical Activities - 1hb - (15.94 SQM)	● Student Space (7)	
B00S - R0008 - Reading Area - (165.55 SQM)	● Student Space (76)	
OS 602 16092 - OS 602 16092 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	