

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Bungendore Public School (1421)</b>
<b>AMU REGION:</b>	<b>Southern NSW</b>
<b>STATE ELECTORATE:</b>	<b>Monaro</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Queanbeyan-Palerang</b>

1421 - Bungendore Public School  
Site Plan (12409)



1:973

Printed: 17-Dec-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0014 - Movement - (10.39 SQM)	Not Applicable	Circulation or storage space.
B00A - R0015 - Staff Room Annexe - (16.38 SQM)	Office (4)	
B00A - R0016 - Staff Room - (40.29 SQM)	Office (10)	
B00A - R0017 - Movement - (9.7 SQM)	Not Applicable	Circulation or storage space.
B00A - R0018 - Deputy Principal - (21.81 SQM)	Office (5)	
B00A - R0024 - Staff Kitchen - (5.4 SQM)	Office (1)	
B00B - R0004 - Home Base - (57.96 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0008 - Home Base - (62.15 SQM) - Teaching Space: 1	Student Space (28)	
B00B - R0009 - Practical Activities - 1hb - (13.41 SQM)	Student Space (6)	
B00E - R0001 - Practical Activities - 1hb - (18.44 SQM)	Student Space (8)	
B00E - R0003 - Movement - (5.16 SQM)	Not Applicable	Circulation or storage space.
B00E - R0004 - Home Base - (61.89 SQM) - Teaching Space: 1	Student Space (28)	
B00E - R0006 - Movement - (6.71 SQM)	Not Applicable	Circulation or storage space.
B00E - R0007 - Staff Study - (12.92 SQM)	Office (3)	
B00E - R0008 - Home Base - (62.92 SQM) - Teaching Space: 1	Student Space (29)	
B00E - R0010 - Movement - (13.7 SQM)	Not Applicable	Circulation or storage space.
B00E - R0011 - Home Base - (63.04 SQM) - Teaching Space: 1	Student Space (29)	
B00E - R0013 - Withdrawal Space - 1hb - (12.98 SQM)	Student Space (6)	
B00E - R0014 - Home Base - (62.01 SQM) - Teaching Space: 1	Student Space (28)	
B00E - R0016 - Movement - (6.71 SQM)	Not Applicable	Circulation or storage space.
B00E - R0020 - Practical Activities - 1hb - (11.62 SQM)	Student Space (5)	
B00E - R0023 - Practical Activities - 1hb - (15.95 SQM)	Student Space (7)	
B00E - R0028 - Movement - (49.98 SQM)	Not Applicable	Circulation or storage space.
B00G - R0005 - Clerical Office/Workroom - (12.38 SQM)	Office (3)	
B00G - R0007 - Principal - (13.25 SQM)	Office (3)	
B00G - R0011 - Sick Bay - (12.68 SQM)	Student Space (5)	
B00G - R0014 - Duplicating Workroom - (18.38 SQM)	Office (4)	
B00G - R0015 - Movement - (8.17 SQM)	Not Applicable	Circulation or storage space.
B00G - R0018 - Clerical Office - (12.3 SQM)	Office (3)	
B00G - R0020 - Entry Vestibule - (18.34 SQM)	Not Applicable	Circulation or storage space.
B00G - R0021 - Movement - (16.19 SQM)	Not Applicable	Circulation or storage space.
B00G - R0022 - Movement - (5.01 SQM)	Not Applicable	Circulation or storage space.
B00I - R0001 - Movement - (131.39 SQM)	Not Applicable	Circulation or storage space.
B00I - R0007 - Practical Activities - 1hb - (20.13 SQM)	Student Space (9)	
B00I - R0008 - Home Base - (57.44 SQM) - Teaching Space: 1	Student Space (26)	
B00I - R0009 - Withdrawal Space - 1hb - (11.13 SQM)	Student Space (5)	
B00I - R0010 - Home Base - (57.59 SQM) - Teaching Space: 1	Student Space (26)	
B00I - R0011 - Practical Activities - 1hb - (20.15 SQM)	Student Space (9)	
B00J - R0001 - Movement - (92.92 SQM)	Not Applicable	Circulation or storage space.
B00J - R0002 - Practical Activities - 1hb - (20.12 SQM)	Student Space (9)	
B00J - R0005 - Home Base - (57.59 SQM) - Teaching Space: 1	Student Space (26)	
B00J - R0006 - Withdrawal Space - 1hb - (11.13 SQM)	Student Space (5)	
B00J - R0007 - Home Base - (57.59 SQM) - Teaching Space: 1	Student Space (26)	
B00J - R0008 - Practical Activities - 1hb - (20 SQM)	Student Space (9)	
B00J - R0012 - Withdrawal Space - 1hb - (7.9 SQM)	Student Space (3)	
B00J - R0013 - Home Base - (57.75 SQM) - Teaching Space: 1	Student Space (26)	
B00J - R0014 - Practical Activities - 1hb - (23.78 SQM)	Student Space (11)	
B00K - R0001 - Movement - (89.94 SQM)	Not Applicable	Circulation or storage space.
B00K - R0002 - Movement - (44.84 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00K - R0003 - Reading Area - (397.95 SQM)	 Student Space (184)	
B00K - R0008 - Special Programs Room - (31.89 SQM)	 Student Space (14)	
B00K - R0011 - Canteen - (26.55 SQM)	Not Applicable	Circulation or storage space.
B00K - R0013 - Movement - (21.66 SQM)	Not Applicable	Circulation or storage space.
B00K - R0014 - Communal Space - (606.07 SQM)	 Student Space (281)	
B00K - R0026 - Movement - (7.42 SQM)	Not Applicable	Circulation or storage space.
B00K - R0028 - Raised Platform - (42.42 SQM)	Not Applicable	Circulation or storage space.
B00K - R0030 - Movement - (7.42 SQM)	Not Applicable	Circulation or storage space.
B00L - R0001 - Movement - (38.47 SQM)	Not Applicable	Circulation or storage space.
B00L - R0002 - Practical Activities - 1hb - (19.39 SQM)	 Student Space (8)	
B00L - R0004 - Home Base - (59.19 SQM) - Teaching Space: 1	 Student Space (27)	
B00L - R0005 - Withdrawal Space - 2hb - (11.35 SQM)	 Student Space (5)	
B00L - R0006 - Home Base - (59.18 SQM) - Teaching Space: 1	 Student Space (27)	
B00L - R0008 - Practical Activities - 1hb - (19.4 SQM)	 Student Space (9)	
B00M - R0001 - Staff Kitchen - (10.7 SQM)	 Office (2)	
B00M - R0006 - Special Programs Room - (68.16 SQM)	 Student Space (31)	
B00N - R0001 - Practical Activities - 1hb - (18.82 SQM)	 Student Space (8)	
B00N - R0003 - Home Base - (60.6 SQM) - Teaching Space: 1	 Student Space (28)	
B00N - R0004 - Withdrawal Space - 2hb - (11.45 SQM)	 Student Space (5)	
B00N - R0005 - Home Base - (60.67 SQM) - Teaching Space: 1	 Student Space (28)	
B00N - R0007 - Practical Activities - 1hb - (18.9 SQM)	 Student Space (8)	
B00O - R0001 - Practical Activities - 1hb - (18.83 SQM)	 Student Space (8)	
B00O - R0003 - Home Base - (60.59 SQM) - Teaching Space: 1	 Student Space (28)	
B00O - R0004 - Withdrawal Space - 2hb - (11.42 SQM)	 Student Space (5)	
B00O - R0005 - Home Base - (61.36 SQM) - Teaching Space: 1	 Student Space (28)	
B00O - R0007 - Practical Activities - 1hb - (19.42 SQM)	 Student Space (9)	
B00O - R0008 - Practical Activities - 1hb - (19.34 SQM)	 Student Space (8)	
B00O - R0010 - Home Base - (61.36 SQM) - Teaching Space: 1	 Student Space (28)	
B00O - R0011 - Home Base - (60.57 SQM) - Teaching Space: 1	 Student Space (28)	
B00O - R0013 - Practical Activities - 1hb - (18.97 SQM)	 Student Space (8)	
B00O - R0014 - Withdrawal Space - 2hb - (11.45 SQM)	 Student Space (5)	
OS 602 13297 - OS 602 13297 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 14263 - OS 602 14263 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 603 18196 - OS 603 18196 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	 Student Space (35)	
OS 606 19056 - OS 606 19056 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	