

VENTILATION AUDIT REPORT

SCHOOL:	Burraneer Bay Public School (4259)
AMU REGION:	Sydney
STATE ELECTORATE:	Cronulla
LOCAL GOVERNMENT AREA:	Sutherland

4259 - Burraneer Bay Public School
Site Plan (10120)



1:734

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Home Base - (56.94 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R0021 - Home Base/Practical Activities - (63.86 SQM) - Teaching Space: 1	● Student Space (29)	
B00A - R0022 - Entry Vestibule - (6.62 SQM)	Not Applicable	Circulation or storage space.
B00A - R0023 - Special Programs Room - (42.8 SQM)	● Student Space (19)	
B00B - R0001 - Home Base - (58.16 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R0006 - Home Base - (56.75 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R0001 - Home Base - (87.42 SQM) - Teaching Space: 1	● Student Space (40)	
B00C - R0007 - Home Base - (57.07 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R0010 - Movement - (6.3 SQM)	Not Applicable	Circulation or storage space.
B00C - R0012 - Home Base - (57.24 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R9001 - Practical Activities - 1hb - (54.28 SQM)	● Student Space (25)	
B00C - R9004 - Movement - (55.86 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Home Base - (55.81 SQM) - Teaching Space: 1	● Student Space (25)	
B00E - R0004 - Movement - (6.55 SQM)	Not Applicable	Circulation or storage space.
B00E - R0008 - Home Base - (56.98 SQM) - Teaching Space: 1	● Student Space (26)	
B00E - R0025 - Reading Area - (202.57 SQM)	● Student Space (93)	
B00E - R0031 - Entry Vestibule - (13.36 SQM)	Not Applicable	Circulation or storage space.
B00G - R0011 - Canteen - (51.67 SQM)	Not Applicable	Circulation or storage space.
B00J - R0001 - Home Base - (85.03 SQM) - Teaching Space: 1	● Student Space (39)	
B00L - R0001 - Movement - (53.48 SQM)	Not Applicable	Circulation or storage space.
B00L - R0002 - Home Base - (79.22 SQM) - Teaching Space: 1	● Student Space (36)	
B00L - R0003 - Practical Activities - 1hb - (13.5 SQM)	● Student Space (6)	
B00L - R0006 - Movement - (17.92 SQM)	Not Applicable	Circulation or storage space.
B00L - R0007 - Withdrawal Space - 1hb - (19.07 SQM)	● Student Space (8)	
B00L - R0009 - Movement - (8.87 SQM)	Not Applicable	Circulation or storage space.
B00L - R0011 - Movement - (11.14 SQM)	Not Applicable	Circulation or storage space.
B00L - R0014 - Home Base - (56.99 SQM) - Teaching Space: 1	● Student Space (26)	
B00L - R0017 - Home Base - (46.66 SQM) - Teaching Space: 1	● Student Space (21)	
B00L - R0018 - Home Base - (46.54 SQM) - Teaching Space: 1	● Student Space (21)	
B00L - R0019 - Duplicating Workroom - (12.99 SQM)	● Office (3)	
B00L - R0021 - Movement - (57.14 SQM)	Not Applicable	Circulation or storage space.
B00L - R0025 - Home Base - (46.86 SQM) - Teaching Space: 1	● Student Space (21)	
B00L - R0026 - Home Base - (46.88 SQM) - Teaching Space: 1	● Student Space (21)	
B00M - R0001 - Interview - (12.95 SQM)	● Office (3)	
B00M - R0002 - Entry Vestibule - (22.35 SQM)	Not Applicable	Circulation or storage space.
B00M - R0003 - Movement - (53.7 SQM)	Not Applicable	Circulation or storage space.
B00M - R0004 - Clerical Office - (59.95 SQM)	● Office (14)	
B00M - R0005 - Sick Bay - (8.79 SQM)	● Student Space (4)	
B00M - R0007 - Duplicating Workroom - (17.07 SQM)	● Office (4)	
B00M - R0014 - Staff Room - (65.46 SQM)	● Office (16)	
B00M - R0015 - Staff Room Annexe - (27.18 SQM)	● Office (6)	
B00M - R0016 - Deputy Principal - (12.95 SQM)	● Office (3)	
B00M - R0017 - Deputy Principal - (12.99 SQM)	● Office (3)	
B00M - R0018 - Principal - (17.07 SQM)	● Office (4)	
B00N - R0001 - Communal Space - (200.95 SQM)	● Student Space (93)	
B00N - R0002 - Movement - (8.83 SQM)	Not Applicable	Circulation or storage space.
B00N - R0003 - Raised Platform - (55.23 SQM)	Not Applicable	Circulation or storage space.
B00N - R0005 - Movement - (17.23 SQM)	Not Applicable	Circulation or storage space.
B00N - R0023 - Staff Kitchen - (12.8 SQM)	● Office (3)	
B00N - R0024 - Movement - (6.86 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B000 - R0001 - Home Base/Practical Activities - (59.61 SQM) - Teaching Space: 1	● Student Space (27)	
B000 - R0003 - Withdrawal Space - 1hb - (8.89 SQM)	● Student Space (4)	
B000 - R0004 - Practical Activities/Movement - 1hb - (18.5 SQM)	● Student Space (8)	
B000 - R0005 - Home Base/Practical Activities - (59.88 SQM) - Teaching Space: 1	● Student Space (27)	
B000 - R0006 - Practical Activities/Movement - 1hb - (18.81 SQM)	● Student Space (8)	
B000 - R0008 - Withdrawal Space - 2hb - (11.24 SQM)	● Student Space (5)	
B000 - R0009 - Home Base/Practical Activities - (60.15 SQM) - Teaching Space: 1	● Student Space (27)	
B000 - R0010 - Practical Activities/Movement - 1hb - (17.25 SQM)	● Student Space (8)	
B000 - R0013 - Special Programs Room - Type 1 - (32.65 SQM)	● Student Space (15)	
B000 - R1001 - Home Base/Practical Activities - (59.87 SQM) - Teaching Space: 1	● Student Space (27)	
B000 - R1003 - Withdrawal Space - 1hb - (8.89 SQM)	● Student Space (4)	
B000 - R1004 - Practical Activities/Movement - 1hb - (18.5 SQM)	● Student Space (8)	
B000 - R1005 - Home Base/Practical Activities - (59.88 SQM) - Teaching Space: 1	● Student Space (27)	
B000 - R1006 - Practical Activities/Movement - 1hb - (18.81 SQM)	● Student Space (8)	
B000 - R1008 - Withdrawal Space - 2hb - (11.24 SQM)	● Student Space (5)	
B000 - R1009 - Home Base/Practical Activities - (60.15 SQM) - Teaching Space: 1	● Student Space (27)	
B000 - R1010 - Practical Activities/Movement - 1hb - (18.19 SQM)	● Student Space (8)	
OS 601 13625 - OS 601 13625 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 13713 - OS 601 13713 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 14932 - OS 601 14932 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 602 12551 - OS 602 12551 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 603 14126 - OS 603 14126 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	● Student Space (35)	