

VENTILATION AUDIT REPORT

SCHOOL:	Burren Junction Public School (1447)
AMU REGION:	North Western NSW
STATE ELECTORATE:	Barwon
LOCAL GOVERNMENT AREA:	Walgett

1447 - Burren Junction Public School
Site Plan (12414)



1:658

Printed: 20-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (12.79 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Home Base - (53.85 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R0003 - Principal - (10.85 SQM)	● Office (2)	
B00A - R0004 - Duplicating Workroom - (11.12 SQM)	● Office (2)	
B00A - R0005 - Clerical Office/Workroom - (8.75 SQM)	● Office (2)	
B00B - R0001 - Canteen - (21.02 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Home Base - (49.91 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R0003 - Home Base - (46.95 SQM) - Teaching Space: 1	● Student Space (21)	
B00B - R0007 - Movement - (39.35 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Movement - (20.4 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Movement - (30.14 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Home Base - (77.76 SQM) - Teaching Space: 1	● Student Space (36)	
B00F - R0003 - Practical Activities - 1hb - (6.32 SQM)	● Student Space (2)	
B00F - R0005 - Movement - (10.31 SQM)	Not Applicable	Circulation or storage space.
B00F - R0007 - Staff Room - (14.97 SQM)	● Office (3)	
B00L - R0001 - Reading Area - (59.99 SQM)	● Student Space (27)	
OS 503 10236 - OS 503 10236 - Admin Lib Staff/Principal/Clerk/Store - (152 SQM)	● Office (38)	