


VENTILATION AUDIT REPORT

SCHOOL:	Burwood Girls High School (8152)
AMU REGION:	Sydney
STATE ELECTORATE:	Strathfield
LOCAL GOVERNMENT AREA:	Burwood

8152 - Burwood Girls High School
Site Plan (12416)



1:1,029

Printed: 29-May-2020





Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0003 - Computer Learning Space - (52.96 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R0004 - General Learning Space - (47.23 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R0005 - General Learning Space - (47.23 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R0006 - General Learning Space - (47.24 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R0009 - Pupil Entry - (17.43 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Administration - Clerical - (24.83 SQM)	● Office (6)	
B00A - R0011 - Administration - Clerical - (47.1 SQM)	● Office (11)	
B00A - R0012 - General Learning Space - (47.27 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R0013 - General Learning Space - (47.3 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R0014 - Staff Study - (56.95 SQM)	● Office (14)	
B00A - R0019 - Movement - (265.8 SQM)	Not Applicable	Circulation or storage space.
B00A - R0020 - General Learning Space - (47.1 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R0021 - General Learning Space - (47.1 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R0022 - Interview/Office - Type 1 - (17.66 SQM)	● Office (4)	
B00A - R0023 - General Learning Space - (37.8 SQM) - Teaching Space: 1	● Student Space (17)	
B00A - R0024 - General Learning Space - (56.4 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R0026 - Clinic - Girls - (12.66 SQM)	● Office (3)	
B00A - R0027 - Design L.S. - (50.33 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R0028 - Design L.S. - (53.53 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R0029 - Leading Teacher - (16.85 SQM)	● Office (4)	
B00A - R0035 - Principal Office - (24.93 SQM)	● Office (6)	
B00A - R1001 - Study Space - (9.08 SQM)	Not Applicable	Circulation or storage space.
B00A - R1002 - General Learning Space - (56.35 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R1003 - General Learning Space - (49.99 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R1004 - Music Learning Space - (49.93 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R1005 - General Learning Space - (48.86 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R1006 - Design L.S. - (79.36 SQM) - Teaching Space: 1	● Student Space (36)	
B00A - R1007 - General Learning Space - (49.79 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R1008 - General Learning Space - (49.16 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R1009 - General Learning Space - (49.07 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R1010 - Design L.S. - (69.86 SQM) - Teaching Space: 1	● Student Space (32)	
B00A - R1014 - General Learning Space - (49.91 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R1015 - General Learning Space - (50.73 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R1016 - Staff Study - (37.21 SQM)	● Office (9)	
B00A - R1017 - Design L.S. - (55.67 SQM) - Teaching Space: 1	● Student Space (25)	
B00A - R1020 - Interview/Office - Type 1 - (9.98 SQM)	● Office (2)	
B00A - R1022 - Staff Study - (36.15 SQM)	● Office (9)	
B00A - R1024 - Movement - (242.08 SQM)	Not Applicable	Circulation or storage space.
B00A - R1029 - Staff Study - (36.56 SQM)	● Office (9)	
B00A - R1030 - Staff Study - (35.86 SQM)	● Office (8)	
B00A - R9001 - Darkroom Space - (28.65 SQM)	● Office (7)	
B00A - R9014 - Movement - (54.49 SQM)	Not Applicable	Circulation or storage space.
B00A - R9015 - Movement - (90.28 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Staff Study - (22.33 SQM)	● Office (5)	
B00B - R0002 - Food Technology L.S. - (77.36 SQM) - Teaching Space: 1	● Student Space (35)	
B00B - R0004 - Food Technology L.S. - (77.41 SQM) - Teaching Space: 1	● Student Space (35)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R0005 - Movement - (13.64 SQM)	Not Applicable	Circulation or storage space.
B00B - R0006 - Movement - (24.87 SQM)	Not Applicable	Circulation or storage space.
B00B - R0007 - Movement - (34.66 SQM)	Not Applicable	Circulation or storage space.
B00B - R0009 - Food/Research Space - (16.1 SQM)	Not Applicable	Circulation or storage space.
B00B - R0011 - Food/Research Space - (10.6 SQM)	Not Applicable	Circulation or storage space.
B00B - R9002 - Darkroom Space - (5.31 SQM)	Office (1)	
B00B - R9003 - Darkroom Space - (18.86 SQM)	Office (4)	
B00C - R0004 - Practice/Seminar - (8.08 SQM)	Not Applicable	Circulation or storage space.
B00C - R0005 - Music Learning Space - (66.52 SQM) - Teaching Space: 1	Student Space (30)	
B00C - R0024 - Music Learning Space - (82.96 SQM) - Teaching Space: 1	Student Space (38)	
B00C - R0026 - Music Learning Space - (40.78 SQM) - Teaching Space: 1	Student Space (18)	
B00C - R0028 - Principal Office - (18.83 SQM)	Office (4)	
B00C - R0029 - Interview/Meeting - (12.32 SQM)	Office (3)	
B00C - R0030 - Interview/Meeting - (12.4 SQM)	Office (3)	
B00C - R0031 - Administration - Clerical - (96.91 SQM)	Office (24)	
B00C - R0033 - Public Reception - (16.28 SQM)	Not Applicable	Circulation or storage space.
B00C - R0034 - Interview/Meeting - (12.38 SQM)	Office (3)	
B00C - R0038 - Staff Kitchen - (5.44 SQM)	Office (1)	
B00C - R0039 - Student Reception - (39.4 SQM)	Not Applicable	Circulation or storage space.
B00C - R0041 - Movement - (21.75 SQM)	Not Applicable	Circulation or storage space.
B00C - R0043 - Movement - (27.96 SQM)	Not Applicable	Circulation or storage space.
B00C - R0045 - Clinic - (10.88 SQM)	Office (2)	
B00C - R0046 - Deputy Principal Office - (15.93 SQM)	Office (3)	
B00C - R0047 - Deputy Principal Office - (14.74 SQM)	Office (3)	
B00C - R0048 - Movement - (18.38 SQM)	Not Applicable	Circulation or storage space.
B00C - R1001 - Art Learning Space - (69.12 SQM) - Teaching Space: 1	Student Space (32)	
B00C - R1003 - Art Learning Space - (66.13 SQM) - Teaching Space: 1	Student Space (30)	
B00C - R1007 - Art Learning Space - (67.77 SQM) - Teaching Space: 1	Student Space (31)	
B00C - R1008 - Movement - (19.42 SQM)	Not Applicable	Circulation or storage space.
B00C - R1012 - Workshop - (10.62 SQM)	Student Space (4)	
B00C - R1014 - Movement - (89.22 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Movement - (11.62 SQM)	Not Applicable	Circulation or storage space.
B00D - R0005 - Movement - (11.57 SQM)	Not Applicable	Circulation or storage space.
B00D - R0006 - Commonroom - (28.63 SQM)	Office (7)	
B00D - R0007 - Student Canteen - (49.34 SQM)	Not Applicable	Circulation or storage space.
B00D - R0012 - Movement - (273.09 SQM)	Not Applicable	Circulation or storage space.
B00D - R1001 - Laboratory L.S. - (89.21 SQM) - Teaching Space: 1	Student Space (41)	
B00D - R1004 - General Learning Space - (46.15 SQM) - Teaching Space: 1	Student Space (21)	
B00D - R1005 - Laboratory L.S. - (91.6 SQM) - Teaching Space: 1	Student Space (42)	
B00D - R1006 - Staff Study - (32.3 SQM)	Office (8)	
B00D - R1012 - Movement - (106.34 SQM)	Not Applicable	Circulation or storage space.
B00D - R2001 - Design L.S. - (92.78 SQM) - Teaching Space: 1	Student Space (43)	
B00D - R2002 - Performance Workspace - (45.5 SQM) - Teaching Space: 1	Student Space (21)	
B00D - R2003 - General Learning Space - (48.12 SQM) - Teaching Space: 1	Student Space (22)	
B00D - R2005 - Computer Learning Space - (80.5 SQM) - Teaching Space: 1	Student Space (37)	
B00D - R2006 - Staff Study - (31.66 SQM)	Office (7)	
B00D - R2007 - Movement - (93.54 SQM)	Not Applicable	Circulation or storage space.
B00E - M1001 - Workroom - (15.24 SQM)	Office (3)	
B00E - M1002 - Main Area - (67.67 SQM)	Not Applicable	Circulation or storage space.
B00E - M1003 - Workroom - (23.58 SQM)	Office (5)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - M1004 - Workroom - (13.68 SQM)	Office (3)	
B00E - R0001 - Laboratory L.S. - (91.16 SQM) - Teaching Space: 1	Student Space (42)	
B00E - R0004 - Laboratory L.S. - (91.45 SQM) - Teaching Space: 1	Student Space (42)	
B00E - R0007 - Laboratory L.S. - (91.05 SQM) - Teaching Space: 1	Student Space (42)	
B00E - R0008 - Laboratory L.S. - (91.16 SQM) - Teaching Space: 1	Student Space (42)	
B00E - R0011 - Movement - (40.22 SQM)	Not Applicable	Circulation or storage space.
B00E - R0016 - Computer Learning Space - (48.6 SQM) - Teaching Space: 1	Student Space (22)	
B00E - R0017 - Preparation - (48.87 SQM)	Not Applicable	Circulation or storage space.
B00E - R1001 - Seminar - (13.24 SQM)	Office (3)	
B00E - R1002 - Seminar - (11.39 SQM)	Office (2)	
B00E - R1008 - Seminar - (11.49 SQM)	Office (2)	
B00E - R1009 - Seminar - (13.29 SQM)	Office (3)	
B00E - R1010 - Audio Visual Workroom - (28.71 SQM)	Student Space (13)	
B00E - R1011 - Workroom - (12.69 SQM)	Office (3)	
B00E - R1012 - Workroom - (15.73 SQM)	Office (3)	
B00E - R1016 - Workroom - (71.31 SQM)	Office (17)	
B00E - R1017 - Main Area - (325.57 SQM)	Not Applicable	Circulation or storage space.
B00F - M0009 - Movement - (5.22 SQM)	Not Applicable	Circulation or storage space.
B00F - M0011 - Movement - (5.22 SQM)	Not Applicable	Circulation or storage space.
B00F - M0014 - Stage - (10.63 SQM)	Not Applicable	Circulation or storage space.
B00F - R0008 - Staff Kitchen - (18.78 SQM)	Office (4)	
B00F - R0010 - Movement - (71.41 SQM)	Not Applicable	Circulation or storage space.
B00F - R0012 - Stage - (110.57 SQM)	Not Applicable	Circulation or storage space.
B00F - R0023 - Multi-Purpose Space - (455.62 SQM)	Student Space (211)	
B00F - R9001 - General Assistants - (103.71 SQM)	Office (25)	
B00J - R0004 - Gymnasium - (70.55 SQM)	Student Space (32)	
B00K - R0001 - General Learning Space - (52.57 SQM) - Teaching Space: 1	Student Space (24)	
B00K - R0002 - General Learning Space - (52.5 SQM) - Teaching Space: 1	Student Space (24)	
B00K - R0004 - Staff Study - (12.79 SQM)	Office (3)	
B00M - R0001 - General Learning Space - (47.06 SQM) - Teaching Space: 1	Student Space (21)	
B00M - R0003 - General Learning Space - (47.13 SQM) - Teaching Space: 1	Student Space (21)	
B00N - R0001 - Performance Workspace - (46.66 SQM) - Teaching Space: 1	Student Space (21)	
B00N - R0002 - Performance Workspace - (46.66 SQM) - Teaching Space: 1	Student Space (21)	
B00N - R0004 - Movement - (7.29 SQM)	Not Applicable	Circulation or storage space.
B00N - R0005 - Movement - (12.97 SQM)	Not Applicable	Circulation or storage space.
B00O - R0001 - Movement Studio - (126.95 SQM)	Not Applicable	Circulation or storage space.
B00O - R0007 - Staff Study - (22.62 SQM)	Office (5)	
B00O - R0009 - Movement Studio - (26.93 SQM)	Not Applicable	Circulation or storage space.
B00P - R0001 - General Learning Space - (58.11 SQM) - Teaching Space: 1	Student Space (26)	
B00P - R0002 - General Learning Space - (57.7 SQM) - Teaching Space: 1	Student Space (26)	
B00P - R0004 - Seminar - (18.74 SQM)	Office (4)	
B00P - R0005 - Fitness Laboratory - (92.98 SQM)	Student Space (43)	
B00Q - R0001 - Practice/Seminar - (8.5 SQM)	Not Applicable	Circulation or storage space.
B00Q - R0002 - Practice/Seminar - (8.15 SQM)	Not Applicable	Circulation or storage space.
B00Q - R0004 - Practice/Seminar - (8.5 SQM)	Not Applicable	Circulation or storage space.
B00R - R0002 - Practice/Seminar - (23.91 SQM)	Not Applicable	Circulation or storage space.
B00R - R0003 - Practice/Seminar - (8.32 SQM)	Not Applicable	Circulation or storage space.
OS 600 17423 - OS 600 17423 - Learning Unit - Small - (57 SQM)	Student Space (26)	
OS 600 18288 - OS 600 18288 - Learning Unit - Small - (57 SQM)	Student Space (26)	

Entity Location	Audit Condition Classification (Capacity)	Comment
OS 601 10821 - OS 601 10821 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 601 11613 - OS 601 11613 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 601 11743 - OS 601 11743 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 601 15296 - OS 601 15296 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	