


VENTILATION AUDIT REPORT

SCHOOL:	Busby Public School (4337)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Liverpool
LOCAL GOVERNMENT AREA:	Liverpool



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B001 - R0001 - Movement - (28.74 SQM)	Not Applicable	Circulation or storage space.
B001 - R0004 - Canteen - (19.42 SQM)	Not Applicable	Circulation or storage space.
B001 - R0005 - Staff Room - (32.02 SQM)	Office (8)	
B001 - R0012 - Interview - (18.8 SQM)	Office (4)	
B001 - R0013 - Movement - (12.66 SQM)	Not Applicable	Circulation or storage space.
B001 - R0016 - Entry Vestibule - (21.41 SQM)	Not Applicable	Circulation or storage space.
B001 - R0018 - Staff Room Annexe - (19.06 SQM)	Office (4)	
B002 - R0004 - Home Base - (56.32 SQM) - Teaching Space: 1	Student Space (26)	
B002 - R0005 - Home Base - (84.55 SQM) - Teaching Space: 1	Student Space (39)	
B002 - R0008 - Movement - (6.21 SQM)	Not Applicable	Circulation or storage space.
B002 - R0013 - Home Base - (84.63 SQM) - Teaching Space: 1	Student Space (39)	
B002 - R0014 - Home Base - (56.24 SQM) - Teaching Space: 1	Student Space (26)	
B003 - R0002 - Movement - (5.7 SQM)	Not Applicable	Circulation or storage space.
B003 - R0004 - Home Base - P - (57.24 SQM) - Teaching Space: 1	Student Space (26)	
B003 - R0005 - Practical Activities - P - 1hb - (16.51 SQM)	Student Space (7)	
B003 - R0008 - Home Base - P - (56.68 SQM) - Teaching Space: 1	Student Space (26)	
B003 - R0009 - Home Base - P - (56.68 SQM) - Teaching Space: 1	Student Space (26)	
B003 - R0014 - Movement - (5.77 SQM)	Not Applicable	Circulation or storage space.
B003 - R0017 - Home Base - (57.31 SQM) - Teaching Space: 1	Student Space (26)	
B004 - R0007 - Movement - (54.79 SQM)	Not Applicable	Circulation or storage space.
B004 - R1001 - Home Base - (56.56 SQM) - Teaching Space: 1	Student Space (26)	
B004 - R1005 - Movement - (6.55 SQM)	Not Applicable	Circulation or storage space.
B004 - R1007 - Home Base - (56.33 SQM) - Teaching Space: 1	Student Space (26)	
B004 - R1009 - Home Base - (56.26 SQM) - Teaching Space: 1	Student Space (26)	
B004 - R1012 - Movement - (6.52 SQM)	Not Applicable	Circulation or storage space.
B004 - R1015 - Home Base - (56.8 SQM) - Teaching Space: 1	Student Space (26)	
B006 - R0002 - Raised Platform - (26.79 SQM)	Not Applicable	Circulation or storage space.
B006 - R0004 - Communal Space - (115.15 SQM)	Student Space (53)	
B006 - R0005 - Movement - (27.6 SQM)	Not Applicable	Circulation or storage space.
B008 - R0001 - Movement - (13.09 SQM)	Not Applicable	Circulation or storage space.
B008 - R0002 - Home Base - (46.79 SQM) - Teaching Space: 1	Student Space (21)	
B009 - R0001 - Movement - (5.98 SQM)	Not Applicable	Circulation or storage space.
B009 - R0003 - Home Base - (57.16 SQM) - Teaching Space: 1	Student Space (26)	
B009 - R0008 - Home Base - (57.31 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0001 - Duplicating Workroom - (23.7 SQM)	Office (5)	
B00A - R0004 - Clerical Office - (22.93 SQM)	Office (5)	
B00A - R0007 - Movement - (8.31 SQM)	Not Applicable	Circulation or storage space.
B00A - R0008 - Entry Vestibule - (17.59 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Principal - (17.22 SQM)	Office (4)	
B00A - R0017 - Sick Bay - (7.41 SQM)	Student Space (3)	
B00A - R0018 - Interview - (16.11 SQM)	Office (4)	
B00A - R0019 - Movement - (50.43 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Home Base - (56.86 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0004 - Movement - (8.26 SQM)	Not Applicable	Circulation or storage space.
B00B - R0007 - Home Base - (56.62 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0008 - Home Base - (56.55 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0011 - Movement - (8.35 SQM)	Not Applicable	Circulation or storage space.
B00B - R0014 - Home Base - (56.93 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R9006 - Movement - (54.86 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R0001 - Movement - (9.19 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Home Base - (56.92 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R0006 - Movement - (5.05 SQM)	Not Applicable	Circulation or storage space.
B00C - R0010 - Home Base - (56.46 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R0011 - Home Base - (56.54 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R0019 - Home Base - (56.69 SQM) - Teaching Space: 1	● Student Space (26)	
B00F - R0001 - Home Base - (56.78 SQM) - Teaching Space: 1	● Student Space (26)	
B00F - R0005 - Movement - (5.93 SQM)	Not Applicable	Circulation or storage space.
B00F - R0009 - Home Base - (56.31 SQM) - Teaching Space: 1	● Student Space (26)	
B00F - R0010 - Home Base - (56.31 SQM) - Teaching Space: 1	● Student Space (26)	
B00F - R0014 - Movement - (5.95 SQM)	Not Applicable	Circulation or storage space.
B00F - R0018 - Home Base - (56.62 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R0002 - Reading Area - (145.62 SQM)	● Student Space (67)	
B00H - R0001 - Communal Space - (145.12 SQM)	● Student Space (67)	
B00H - R0002 - Movement - (7.12 SQM)	Not Applicable	Circulation or storage space.
B00H - R0003 - Raised Platform - (60.34 SQM)	Not Applicable	Circulation or storage space.
B00H - R0004 - Movement - (11.03 SQM)	Not Applicable	Circulation or storage space.
B00H - R0005 - Movement - (12.77 SQM)	Not Applicable	Circulation or storage space.