


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Buxton Public School (1460)</b>
<b>AMU REGION:</b>	<b>South Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Wollondilly</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Wollondilly</b>

1460 - Buxton Public School  
Site Plan (07607)



1.958

Printed: 18-Aug-2021

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Entry Vestibule - (11.59 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Clerical Office - (17.51 SQM)	Office (4)	
B00A - R0005 - Principal - (13.08 SQM)	Office (3)	
B00A - R0006 - Interview - (13.08 SQM)	Office (3)	
B00A - R0009 - Movement - (23.27 SQM)	Not Applicable	Circulation or storage space.
B00A - R0014 - Staff Room Annexe - (12.82 SQM)	Office (3)	
B00A - R0018 - Deputy Principal - (12.55 SQM)	Office (3)	
B00A - R0021 - Duplicating Workroom - (19.9 SQM)	Office (4)	
B00A - R0023 - Movement - (75.28 SQM)	Not Applicable	Circulation or storage space.
B00A - R0024 - Sick Bay - (8.57 SQM)	Student Space (3)	
B00A - R0026 - Movement - (46.84 SQM)	Not Applicable	Circulation or storage space.
B00A - R0030 - Staff Room - (21.19 SQM)	Office (5)	
B00A - R0031 - Staff Room - (55.26 SQM)	Office (13)	
B00B - R0001 - Canteen - (19.75 SQM)	Not Applicable	Circulation or storage space.
B00B - R0007 - Movement - (29.08 SQM)	Not Applicable	Circulation or storage space.
B00B - R0010 - Movement - (12.04 SQM)	Not Applicable	Circulation or storage space.
B00B - R0011 - Raised Platform - (50.72 SQM)	Not Applicable	Circulation or storage space.
B00B - R0012 - Movement - (12.06 SQM)	Not Applicable	Circulation or storage space.
B00B - R0013 - Communal Space - (137.66 SQM)	Student Space (63)	
B00B - R0014 - Movement - (136.36 SQM)	Not Applicable	Circulation or storage space.
B00B - R0021 - Movement - (23.15 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Practical Activities - 1hb - (20.98 SQM)	Student Space (9)	
B00C - R0002 - Home Base - (58.35 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R0004 - Withdrawal Space - 1hb - (10.58 SQM)	Student Space (4)	
B00C - R0005 - Home Base - (58.37 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R0006 - Practical Activities - 1hb - (21.24 SQM)	Student Space (9)	
B00C - R0011 - Reading Area - (96.38 SQM)	Student Space (44)	
B00C - R0012 - Seminar/Study - (43.62 SQM)	Office (10)	
B00C - R0016 - Movement - (215.84 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Practical Activities - 1hb - (20.98 SQM)	Student Space (9)	
B00D - R0003 - Withdrawal Space - 1hb - (10.47 SQM)	Student Space (4)	
B00D - R0004 - Home Base - (58.29 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0005 - Home Base - (57.76 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0007 - Practical Activities - 1hb - (21.18 SQM)	Student Space (9)	
B00D - R0008 - Practical Activities - 1hb - (21.7 SQM)	Student Space (10)	
B00D - R0010 - Home Base - (57.02 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0017 - Movement - (161.65 SQM)	Not Applicable	Circulation or storage space.
B00E - R0003 - Practical Activities - 1hb - (20.99 SQM)	Student Space (9)	
B00E - R0004 - Withdrawal Space - 1hb - (10.52 SQM)	Student Space (4)	
B00E - R0005 - Home Base - (58.27 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0006 - Home Base - (58.02 SQM) - Teaching Space: 1	Student Space (26)	
B00E - R0008 - Practical Activities - 1hb - (20.96 SQM)	Student Space (9)	
B00E - R0009 - Movement - (92.99 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Practical Activities/Movement - 1hb - (18.64 SQM)	Student Space (8)	
B00F - R0004 - Home Base - (60.42 SQM) - Teaching Space: 1	Student Space (28)	
B00F - R0005 - Withdrawal Space - 2hb - (11.74 SQM)	Student Space (5)	
B00F - R0006 - Home Base - (60.42 SQM) - Teaching Space: 1	Student Space (28)	
B00F - R0008 - Practical Activities/Movement - 1hb - (16.16 SQM)	Student Space (7)	
B00G - R0002 - Movement - (5.76 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R0003 - Special Programs Room - (33.17 SQM)	 Student Space (15)	