


VENTILATION AUDIT REPORT

SCHOOL:	Byron Bay High School (8577)
AMU REGION:	North Coast
STATE ELECTORATE:	Ballina
LOCAL GOVERNMENT AREA:	Byron

8577 - Byron Bay High School
Site Plan (12423)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - General Assistants - (11.77 SQM)	Office (2)	
B00A - R0002 - Public Entry - (19.79 SQM)	Not Applicable	Circulation or storage space.
B00A - R0003 - Administration - Clerical - (35.52 SQM)	Office (8)	
B00A - R0004 - Administration - Clerical - (11.62 SQM)	Office (2)	
B00A - R0005 - Interview/Office - Type 1 - (11.98 SQM)	Office (2)	
B00A - R0007 - Principal Office - (21.27 SQM)	Office (5)	
B00A - R0009 - Duplicating Workroom - (24.92 SQM)	Office (6)	
B00A - R0011 - Clinic - Girls - (12.56 SQM)	Office (3)	
B00A - R0014 - Clinic - Boys - (15.9 SQM)	Office (3)	
B00A - R0015 - Ancillary Staff - (21.81 SQM)	Office (5)	
B00A - R0016 - Deputy Principal Office - (15.82 SQM)	Office (3)	
B00A - R0017 - Pupil Entry - (10.97 SQM)	Not Applicable	Circulation or storage space.
B00A - R0018 - Movement - (53.89 SQM)	Not Applicable	Circulation or storage space.
B00A - R0019 - Movement - (18.23 SQM)	Not Applicable	Circulation or storage space.
B00A - R0020 - Movement - (12.45 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Multi-Purpose Space - (455.14 SQM)	Student Space (211)	
B00B - R0007 - Staff Study - (18.06 SQM)	Office (4)	
B00B - R0012 - Movement - (22.62 SQM)	Not Applicable	Circulation or storage space.
B00B - R0013 - Stage - (83.55 SQM)	Not Applicable	Circulation or storage space.
B00B - R0015 - Movement - (22.61 SQM)	Not Applicable	Circulation or storage space.
B00B - R0026 - Movement - (646.25 SQM)	Not Applicable	Circulation or storage space.
B00B - R0027 - Movement - (124.76 SQM)	Not Applicable	Circulation or storage space.
B00C - R0003 - Computer Learning Space - (55.61 SQM) - Teaching Space: 1	Student Space (25)	
B00C - R0004 - Staff Study - (28.2 SQM)	Office (7)	
B00C - R0005 - Materials Technology L.S. - (89.67 SQM) - Teaching Space: 1	Student Space (41)	
B00C - R0006 - Wood Technology Bay - (32.69 SQM)	Not Applicable	Circulation or storage space.
B00C - R0007 - Materials Technology L.S. - (90.19 SQM) - Teaching Space: 1	Student Space (41)	
B00C - R0010 - Workshop - (58.76 SQM)	Student Space (27)	
B00C - R0011 - Welding Area - (12.24 SQM)	Not Applicable	Circulation or storage space.
B00C - R0012 - Materials Technology L.S. - (90.68 SQM) - Teaching Space: 1	Student Space (42)	
B00C - R0013 - Metal Technology Bay - (33.05 SQM)	Not Applicable	Circulation or storage space.
B00C - R0014 - Materials Technology L.S. - (90.24 SQM) - Teaching Space: 1	Student Space (41)	
B00C - R0015 - Design L.S. - (56.24 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0016 - Seminar/Technology Space - (27.79 SQM)	Office (6)	
B00C - R0017 - Movement - (170.29 SQM)	Not Applicable	Circulation or storage space.
B00C - R0025 - Movement - (100.22 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Art Learning Space - (58.11 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0004 - Art Learning Space - (58.44 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0006 - Music Learning Space - (57.8 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0009 - Music Learning Space - (80.19 SQM) - Teaching Space: 1	Student Space (37)	
B00D - R0010 - Practice/Seminar - (30.35 SQM)	Not Applicable	Circulation or storage space.
B00D - R0011 - Staff Study - (11.96 SQM)	Office (2)	
B00D - R0012 - Staff Study - (25.94 SQM)	Office (6)	
B00D - R0016 - Movement - (5.88 SQM)	Not Applicable	Circulation or storage space.
B00D - R0017 - Art Learning Space - (58.71 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0022 - Movement - (155.99 SQM)	Not Applicable	Circulation or storage space.
B00D - R0023 - Movement - (90.12 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Laboratory L.S. - (79.28 SQM) - Teaching Space: 1	Student Space (36)	
B00E - R0003 - Preparation - (30.6 SQM)	Not Applicable	Circulation or storage space.
B00E - R0004 - Laboratory L.S. - (79.03 SQM) - Teaching Space: 1	Student Space (36)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R0005 - Laboratory L.S. - (79.93 SQM) - Teaching Space: 1	● Student Space (37)	
B00E - R0006 - Preparation - (21.28 SQM)	Not Applicable	Circulation or storage space.
B00E - R0008 - Staff Study - (36.97 SQM)	● Office (9)	
B00E - R0011 - Laboratory L.S. - (79.48 SQM) - Teaching Space: 1	● Student Space (36)	
B00E - R0012 - Preparation - (30.84 SQM)	Not Applicable	Circulation or storage space.
B00E - R0013 - Laboratory L.S. - (79.04 SQM) - Teaching Space: 1	● Student Space (36)	
B00E - R0017 - Movement - (86.75 SQM)	Not Applicable	Circulation or storage space.
B00E - R0019 - Movement - (157.23 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Computer Learning Space - (67.78 SQM) - Teaching Space: 1	● Student Space (31)	
B00F - R0004 - Food Technology L.S. - (106.65 SQM) - Teaching Space: 1	● Student Space (49)	
B00F - R0005 - Preparation - (25.06 SQM)	Not Applicable	Circulation or storage space.
B00F - R0006 - Seminar - (10.58 SQM)	● Office (2)	
B00F - R0007 - Food Technology L.S. - (106.92 SQM) - Teaching Space: 1	● Student Space (49)	
B00F - R0008 - Interview/Office - Type 1 - (10.51 SQM)	● Office (2)	
B00F - R0011 - Staff Study - (21.8 SQM)	● Office (5)	
B00F - R0012 - Materials Technology L.S. - (68.2 SQM) - Teaching Space: 1	● Student Space (31)	
B00F - R0017 - Movement - (127.46 SQM)	Not Applicable	Circulation or storage space.
B00F - R0018 - Movement - (108.95 SQM)	Not Applicable	Circulation or storage space.
B00F - R0019 - Movement - (40.24 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - General Learning Space - (47.36 SQM) - Teaching Space: 1	● Student Space (21)	
B00G - R0002 - Darkroom Space - (26.19 SQM)	● Office (6)	
B00G - R0004 - General Learning Space - (47.32 SQM) - Teaching Space: 1	● Student Space (21)	
B00G - R0005 - General Learning Space - (47.4 SQM) - Teaching Space: 1	● Student Space (21)	
B00G - R0006 - General Learning Space - (47.35 SQM) - Teaching Space: 1	● Student Space (21)	
B00G - R0007 - General Learning Space - (48.03 SQM) - Teaching Space: 1	● Student Space (22)	
B00G - R0009 - Study Space - (14.99 SQM)	Not Applicable	Circulation or storage space.
B00G - R0010 - Seminar - (15.09 SQM)	● Office (3)	
B00G - R0012 - General Learning Space - (47.85 SQM) - Teaching Space: 1	● Student Space (22)	
B00G - R0013 - General Learning Space - (47.55 SQM) - Teaching Space: 1	● Student Space (22)	
B00G - R0014 - Design/Technology L.S. - (47.42 SQM) - Teaching Space: 1	● Student Space (22)	
B00G - R0015 - Design/Technology L.S. - (47.4 SQM) - Teaching Space: 1	● Student Space (21)	
B00G - R0016 - Design/Technology L.S. - (47.51 SQM) - Teaching Space: 1	● Student Space (22)	
B00G - R0018 - Staff Study - (42.78 SQM)	● Office (10)	
B00G - R0019 - General Learning Space - (42.25 SQM) - Teaching Space: 1	● Student Space (19)	
B00G - R0020 - General Learning Space - (43.41 SQM) - Teaching Space: 1	● Student Space (20)	
B00G - R0021 - Staff Study - (41.53 SQM)	● Office (10)	
B00G - R0022 - Study Space - (16.38 SQM)	Not Applicable	Circulation or storage space.
B00G - R0023 - Tiered Learning Area - (49.7 SQM)	● Student Space (23)	
B00G - R0025 - Seminar - (10.7 SQM)	● Office (2)	
B00G - R0027 - Interview/Office - Type 1 - (10.73 SQM)	● Office (2)	
B00G - R0030 - Movement - (221.92 SQM)	Not Applicable	Circulation or storage space.
B00G - R0036 - Movement - (14.05 SQM)	Not Applicable	Circulation or storage space.
B00G - R0038 - Darkroom Space - (27.89 SQM)	● Office (6)	
B00G - R0039 - Movement - (338.59 SQM)	Not Applicable	Circulation or storage space.
B00G - R1007 - General Learning Space - (41.42 SQM) - Teaching Space: 1	● Student Space (19)	
B00G - R1008 - Seminar - (27.29 SQM)	● Office (6)	
B00G - R1009 - Senior Study - (55.27 SQM)	● Office (13)	
B00G - R1010 - Commonroom - (84.71 SQM)	● Office (21)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R1012 - Staff Study - (40.18 SQM)	Office (10)	
B00G - R1014 - General Learning Space - (41.31 SQM) - Teaching Space: 1	Student Space (19)	
B00G - R1015 - Movement - (98.75 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Pupil Entry - (35.36 SQM)	Not Applicable	Circulation or storage space.
B00H - R0002 - Main Area - (332.4 SQM)	Not Applicable	Circulation or storage space.
B00H - R0003 - Workroom - (50.18 SQM)	Office (12)	
B00H - R0004 - Audio Visual Workroom - (23.51 SQM)	Student Space (10)	
B00H - R0005 - Seminar - (12.2 SQM)	Office (3)	
B00H - R0006 - Seminar - (12.22 SQM)	Office (3)	
B00H - R0007 - Seminar - (12.48 SQM)	Office (3)	
B00H - R0009 - Movement - (8.52 SQM)	Not Applicable	Circulation or storage space.
B00I - R0001 - Growing/Breeding - (11.64 SQM)	Not Applicable	Circulation or storage space.
B00J - R0001 - Student Canteen - (58.58 SQM)	Not Applicable	Circulation or storage space.
B00L - R0001 - Movement - (28.88 SQM)	Not Applicable	Circulation or storage space.
B00L - R0002 - Performance Workspace - (259.73 SQM) - Teaching Space: 1	Student Space (120)	
B00L - R0003 - Movement - (47.43 SQM)	Not Applicable	Circulation or storage space.
B00L - R0004 - Movement - (83.12 SQM)	Not Applicable	Circulation or storage space.
B00M - R0002 - Gymnasium - (347.52 SQM)	Student Space (161)	
B00M - R0003 - General Learning Space - Type 13 - (46.05 SQM) - Teaching Space: 1	Student Space (21)	
OS 600 17126 - OS 600 17126 - Learning Unit - Small - (57 SQM)	Student Space (26)	
OS 601 11207 - OS 601 11207 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 601 14891 - OS 601 14891 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 601 15780 - OS 601 15780 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 601 17728 - OS 601 17728 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	