

VENTILATION AUDIT REPORT

SCHOOL:	Byron Bay Public School (1470)
AMU REGION:	North Coast
STATE ELECTORATE:	Ballina
LOCAL GOVERNMENT AREA:	Byron

1470 - Byron Bay Public School
Site Plan (11429)


















Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (69.37 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Staff Room - (49.61 SQM)	Office (12)	
B00A - R0003 - Staff Room Annexe - (19.24 SQM)	Office (4)	
B00A - R0004 - Movement - (44.42 SQM)	Not Applicable	Circulation or storage space.
B00A - R0011 - Deputy Principal - (14.58 SQM)	Office (3)	
B00A - R0012 - Duplicating Workroom - (20.87 SQM)	Office (5)	
B00A - R0013 - Sick Bay - (12.94 SQM)	Student Space (6)	
B00A - R0015 - Principal - (16.28 SQM)	Office (4)	
B00A - R0016 - Deputy Principal - (15.12 SQM)	Office (3)	
B00A - R0017 - Movement - (10.09 SQM)	Not Applicable	Circulation or storage space.
B00A - R0018 - Interview - (15.38 SQM)	Office (3)	
B00A - R0019 - Clerical Office - (18.93 SQM)	Office (4)	
B00A - R0020 - Entry Vestibule - (12.14 SQM)	Not Applicable	Circulation or storage space.
B00A - R0021 - Movement - (41.67 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Movement - (123.95 SQM)	Not Applicable	Circulation or storage space.
B00B - R0012 - Special Programs Room - (54.36 SQM)	Student Space (25)	
B00B - R0013 - Special Programs Room - (31.17 SQM)	Student Space (14)	
B00B - R0014 - Home Base - (112.54 SQM) - Teaching Space: 1	Student Space (52)	
B00C - R0001 - Movement - (6.63 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Staff Room Annexe - (10.25 SQM)	Office (2)	
B00C - R0003 - Home Base - (48.88 SQM) - Teaching Space: 1	Student Space (22)	
B00C - R0004 - Practical Activities - 1hb - (14.29 SQM)	Student Space (6)	
B00C - R0006 - Withdrawal Space - 1hb - (9.4 SQM)	Student Space (4)	
B00C - R0007 - Special Programs Room - (47.57 SQM)	Student Space (22)	
B00C - R0008 - Practical Activities - 1hb - (13.86 SQM)	Student Space (6)	
B00D - R0002 - Practical Activities - 1hb - (23.1 SQM)	Student Space (10)	
B00D - R0003 - Home Base - (66.66 SQM) - Teaching Space: 1	Student Space (30)	
B00D - R0008 - Withdrawal Space - 1hb - (7.62 SQM)	Student Space (3)	
B00E - R0001 - Practical Activities - 1hb - (14.93 SQM)	Student Space (6)	
B00E - R0003 - Home Base - (81.86 SQM) - Teaching Space: 1	Student Space (37)	
B00E - R0005 - Withdrawal Space - 1hb - (15.05 SQM)	Student Space (6)	
B00E - R0006 - Movement - (24.36 SQM)	Not Applicable	Circulation or storage space.
B00E - R1002 - Practical Activities - 1hb - (20.12 SQM)	Student Space (9)	
B00E - R1005 - Staff Room Annexe - (21.44 SQM)	Office (5)	
B00E - R1007 - Withdrawal Space - 1hb - (7.37 SQM)	Student Space (3)	
B00E - R1008 - Home Base - (66.17 SQM) - Teaching Space: 1	Student Space (30)	
B00F - R0001 - Movement - (116.84 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Withdrawal Space - 1hb - (6.13 SQM)	Student Space (2)	
B00F - R0005 - Home Base - (57.2 SQM) - Teaching Space: 1	Student Space (26)	
B00F - R0006 - Practical Activities - 1hb - (20.1 SQM)	Student Space (9)	
B00F - R0007 - Home Base - (57.04 SQM) - Teaching Space: 1	Student Space (26)	
B00F - R0008 - Practical Activities - 1hb - (19.96 SQM)	Student Space (9)	
B00F - R0009 - Withdrawal Space - 1hb - (12.02 SQM)	Student Space (5)	
B00F - R0015 - Home Base - (58.59 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R0016 - Practical Activities - 1hb - (20.5 SQM)	Student Space (9)	
B00F - R0017 - Home Base - (56.89 SQM) - Teaching Space: 1	Student Space (26)	
B00F - R0018 - Practical Activities - 1hb - (20.15 SQM)	Student Space (9)	
B00F - R0019 - Withdrawal Space - 1hb - (6.11 SQM)	Student Space (2)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00F - R0022 - Movement - (5.11 SQM)	Not Applicable	Circulation or storage space.
B00F - R0023 - Movement - (5.12 SQM)	Not Applicable	Circulation or storage space.
B00F - R0024 - Movement - (5.07 SQM)	Not Applicable	Circulation or storage space.
B00F - R0025 - Movement - (5.08 SQM)	Not Applicable	Circulation or storage space.
B00F - R1001 - Movement - (124.22 SQM)	Not Applicable	Circulation or storage space.
B00F - R1002 - Withdrawal Space - 1hb - (6.99 SQM)	● Student Space (3)	
B00F - R1005 - Home Base - (57.75 SQM) - Teaching Space: 1	● Student Space (26)	
B00F - R1006 - Practical Activities - 1hb - (20.62 SQM)	● Student Space (9)	
B00F - R1007 - Home Base - (57.83 SQM) - Teaching Space: 1	● Student Space (26)	
B00F - R1008 - Practical Activities - 1hb - (20.65 SQM)	● Student Space (9)	
B00F - R1009 - Withdrawal Space - 1hb - (12.61 SQM)	● Student Space (5)	
B00F - R1015 - Home Base - (59.07 SQM) - Teaching Space: 1	● Student Space (27)	
B00F - R1016 - Practical Activities - 1hb - (21.2 SQM)	● Student Space (9)	
B00F - R1017 - Home Base - (57.52 SQM) - Teaching Space: 1	● Student Space (26)	
B00F - R1018 - Practical Activities - 1hb - (20.83 SQM)	● Student Space (9)	
B00F - R1019 - Withdrawal Space - 1hb - (6.97 SQM)	● Student Space (3)	
B00G - R0004 - Canteen - (37.72 SQM)	Not Applicable	Circulation or storage space.
B00H - R0002 - Raised Platform - (34.75 SQM)	Not Applicable	Circulation or storage space.
B00H - R0011 - Communal Space - (257.75 SQM)	● Student Space (119)	
B00I - R0004 - Movement - (69.76 SQM)	Not Applicable	Circulation or storage space.
B00K - R0002 - Special Programs Room - (61.43 SQM)	● Student Space (28)	
B00N - R0001 - Movement - (38.58 SQM)	Not Applicable	Circulation or storage space.
B00N - R0002 - Practical Activities - 1hb - (19.45 SQM)	● Student Space (9)	
B00N - R0004 - Home Base - (59.36 SQM) - Teaching Space: 1	● Student Space (27)	
B00N - R0005 - Withdrawal Space - 2hb - (11.39 SQM)	● Student Space (5)	
B00N - R0006 - Home Base - (59.35 SQM) - Teaching Space: 1	● Student Space (27)	
B00N - R0008 - Practical Activities - 1hb - (19.46 SQM)	● Student Space (9)	
B00P - R0002 - Reading Area - (235.84 SQM)	● Student Space (109)	
B00P - R1002 - Practical Activities - 1hb - (18.55 SQM)	● Student Space (8)	
B00P - R1003 - Home Base - (59.58 SQM) - Teaching Space: 1	● Student Space (27)	
B00P - R1004 - Special Programs Room - (9 SQM)	● Student Space (4)	
B00P - R1006 - Practical Activities - 1hb - (20.12 SQM)	● Student Space (9)	
B00P - R1008 - Home Base - (61.1 SQM) - Teaching Space: 1	● Student Space (28)	
B00P - R1009 - Special Programs Room - (11.76 SQM)	● Student Space (5)	
B00P - R1010 - Home Base - (60.42 SQM) - Teaching Space: 1	● Student Space (28)	
B00P - R1011 - Practical Activities - 1hb - (20.53 SQM)	● Student Space (9)	
B00Q - R0002 - Home Base - (66.14 SQM) - Teaching Space: 1	● Student Space (30)	
B00Q - R0003 - Practical Activities - 1hb - (18.92 SQM)	● Student Space (8)	
B00Q - R0004 - Withdrawal Space - 1hb - (8.38 SQM)	● Student Space (3)	
B00Q - R0005 - Home Base - (64.67 SQM) - Teaching Space: 1	● Student Space (30)	
B00Q - R0006 - Practical Activities - 1hb - (21.69 SQM)	● Student Space (10)	
B00Q - R0007 - Withdrawal Space - 2hb - (14.45 SQM)	● Student Space (6)	
B00Q - R0008 - Home Base - (59.67 SQM) - Teaching Space: 1	● Student Space (27)	
B00Q - R0009 - Practical Activities - 1hb - (23.07 SQM)	● Student Space (10)	
B00Q - R0014 - Home Base - (59.26 SQM) - Teaching Space: 1	● Student Space (27)	
B00Q - R0015 - Practical Activities - 1hb - (22.81 SQM)	● Student Space (10)	
B00Q - R0016 - Withdrawal Space - 2hb - (14.35 SQM)	● Student Space (6)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00Q - R0017 - Home Base - (65.45 SQM) - Teaching Space: 1	 Student Space (30)	
B00Q - R0018 - Practical Activities - 1hb - (20.9 SQM)	 Student Space (9)	
B00Q - R1001 - Home Base - (66.35 SQM) - Teaching Space: 1	 Student Space (30)	
B00Q - R1002 - Practical Activities - 1hb - (17.47 SQM)	 Student Space (8)	
B00Q - R1003 - Withdrawal Space - 1hb - (10.3 SQM)	 Student Space (4)	
B00Q - R1004 - Home Base - (66.06 SQM) - Teaching Space: 1	 Student Space (30)	
B00Q - R1005 - Practical Activities - 1hb - (19.46 SQM)	 Student Space (9)	
B00Q - R1006 - Withdrawal Space - 2hb - (16.91 SQM)	 Student Space (7)	
B00Q - R1007 - Home Base - (60.03 SQM) - Teaching Space: 1	 Student Space (27)	
B00Q - R1008 - Practical Activities - 1hb - (19.38 SQM)	 Student Space (8)	
B00Q - R1013 - Home Base - (61.25 SQM) - Teaching Space: 1	 Student Space (28)	
B00Q - R1014 - Practical Activities - 1hb - (20.91 SQM)	 Student Space (9)	
B00Q - R1015 - Withdrawal Space - 2hb - (17.39 SQM)	 Student Space (8)	
B00Q - R1016 - Home Base - (68.43 SQM) - Teaching Space: 1	 Student Space (31)	
B00Q - R1017 - Practical Activities - 1hb - (19.39 SQM)	 Student Space (8)	