

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Cabramatta High School (8209)</b>
<b>AMU REGION:</b>	<b>South Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Cabramatta</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Fairfield</b>

8209 - Cabramatta High School  
Site Plan (10127)



1:2,567

Printed: 21-Mar-2020

## Ventilation Audit Key
















Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B001 - R0003 - Staff Study - (211.74 SQM)	Office (52)	
B001 - R0004 - Staff Lounge - (122.13 SQM)	Office (30)	
B001 - R0011 - Staff Study - (13.76 SQM)	Office (3)	
B001 - R0012 - Interview/Meeting - (12.91 SQM)	Office (3)	
B001 - R0013 - Interview/Meeting - (12.95 SQM)	Office (3)	
B001 - R0015 - Movement - (41.31 SQM)	Not Applicable	Circulation or storage space.
B001 - R0016 - Staff Study - (275.98 SQM)	Office (68)	
B001 - R0020 - Interview/Meeting - (15.01 SQM)	Office (3)	
B002 - R0001 - General Learning Space - Type 1 - (59.3 SQM) - Teaching Space: 1	Student Space (27)	
B002 - R0003 - Kitchen - Type 2 - (101 SQM)	Student Space (46)	
B002 - R0004 - General Learning Space - Type 1 - (80.19 SQM) - Teaching Space: 1	Student Space (37)	
B002 - R0006 - Movement - (30.88 SQM)	Not Applicable	Circulation or storage space.
B002 - R0008 - Preparation - Materials - (36.96 SQM)	Not Applicable	Circulation or storage space.
B002 - R0011 - Interview/Office - Type 1 - (21.26 SQM)	Office (5)	
B002 - R0012 - General Learning Space - (59.38 SQM) - Teaching Space: 1	Student Space (27)	
B002 - R0013 - Kitchen - Type 2 - (101.28 SQM)	Student Space (46)	
B002 - R0015 - General Learning Space - (59.21 SQM) - Teaching Space: 1	Student Space (27)	
B003 - R0009 - General Learning Space - Type 1 - (59.44 SQM) - Teaching Space: 1	Student Space (27)	
B003 - R0010 - General Learning Space - (60.54 SQM) - Teaching Space: 1	Student Space (28)	
B003 - R0012 - Materials Workshop - Type 3 - (113.53 SQM)	Student Space (52)	
B003 - R0013 - Wood Technology Bay - (7.75 SQM)	Not Applicable	Circulation or storage space.
B003 - R0016 - Movement - (28.56 SQM)	Not Applicable	Circulation or storage space.
B003 - R0017 - General Learning Space - (61.1 SQM) - Teaching Space: 1	Student Space (28)	
B003 - R0018 - Materials Workshop - Type 3 - (122.03 SQM)	Student Space (56)	
B003 - R0019 - General Learning Space - (60.08 SQM) - Teaching Space: 1	Student Space (27)	
B003 - R0028 - Workshop Area - (95.19 SQM)	Student Space (44)	
B003 - R1005 - Preparation - Materials - (16.37 SQM)	Not Applicable	Circulation or storage space.
B003 - R1007 - General Learning Space - Type 1 - (60.11 SQM) - Teaching Space: 1	Student Space (27)	
B003 - R1009 - Kitchen - Type 1 - (132.41 SQM)	Student Space (61)	
B003 - R1010 - General Learning Space - (61.03 SQM) - Teaching Space: 1	Student Space (28)	
B003 - R1011 - Movement - (25.2 SQM)	Not Applicable	Circulation or storage space.
B003 - R1012 - Seminar - (21.66 SQM)	Office (5)	
B003 - R1014 - Art Learning Space - (68.83 SQM) - Teaching Space: 1	Student Space (31)	
B003 - R1015 - Visual Arts Workshop - (110.75 SQM)	Student Space (51)	
B003 - R1016 - Art Learning Space - (68.79 SQM) - Teaching Space: 1	Student Space (31)	
B004 - R0004 - Metal Technology Bay - (126.35 SQM)	Not Applicable	Circulation or storage space.
B004 - R0005 - Materials Technology L.S. - (60.51 SQM) - Teaching Space: 1	Student Space (28)	
B004 - R0006 - General Learning Space - (61.54 SQM) - Teaching Space: 1	Student Space (28)	
B004 - R0017 - Workshop Area - (38.01 SQM)	Student Space (17)	
B004 - R0018 - Welding Area - (14.91 SQM)	Not Applicable	Circulation or storage space.
B004 - R1004 - Dark Room - (25.07 SQM)	Office (6)	
B004 - R1005 - Movement - (26.1 SQM)	Not Applicable	Circulation or storage space.
B004 - R1007 - Art Learning Space - (69.01 SQM) - Teaching Space: 1	Student Space (32)	
B004 - R1008 - Visual Arts Workshop - (119.62 SQM)	Student Space (55)	
B004 - R1009 - Art Learning Space - (69.59 SQM) - Teaching Space: 1	Student Space (32)	
B005 - R0007 - Movement Studio - (125.83 SQM)	Not Applicable	Circulation or storage space.
B005 - R0015 - Stage - (31.87 SQM)	Not Applicable	Circulation or storage space.
B006 - R0002 - General Learning Space - Type 1 - (62.29 SQM) - Teaching Space: 1	Student Space (28)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B006 - R0004 - Seminar - Type 2 - (19.57 SQM)	Office (4)	
B006 - R0005 - Fitness Laboratory - (98.5 SQM)	Student Space (45)	
B006 - R0006 - General Learning Space - Type 1 - (62.29 SQM) - Teaching Space: 1	Student Space (28)	
B006 - R0016 - Movement - (7.5 SQM)	Not Applicable	Circulation or storage space.
B006 - R1002 - General Learning Space - Type 1 - (62.29 SQM) - Teaching Space: 1	Student Space (28)	
B006 - R1003 - Seminar - Type 1 - (21.05 SQM)	Office (5)	
B006 - R1005 - Performance Workshop - (96.55 SQM)	Student Space (44)	
B006 - R1006 - General Learning Space - Type 1 - (62.29 SQM) - Teaching Space: 1	Student Space (28)	
B006 - R1007 - General Learning Space - Type 1 - (47.27 SQM) - Teaching Space: 1	Student Space (21)	
B006 - R1010 - General Learning Space - Type 1 - (60.99 SQM) - Teaching Space: 1	Student Space (28)	
B006 - R1017 - Movement - (7.5 SQM)	Not Applicable	Circulation or storage space.
B007 - R0001 - Entry - (60.34 SQM)	Not Applicable	Circulation or storage space.
B007 - R0002 - General Learning Space - (58.56 SQM) - Teaching Space: 1	Student Space (27)	
B007 - R0003 - General Learning Space - (67.34 SQM) - Teaching Space: 1	Student Space (31)	
B007 - R0004 - General Learning Space - (59.51 SQM) - Teaching Space: 1	Student Space (27)	
B007 - R0005 - General Learning Space - (58.56 SQM) - Teaching Space: 1	Student Space (27)	
B007 - R0006 - Shared Learning Space - (51.81 SQM)	Student Space (24)	
B007 - R0007 - Entry - (13.05 SQM)	Not Applicable	Circulation or storage space.
B007 - R0008 - Interview/Meeting - (29.21 SQM)	Office (7)	
B007 - R0009 - General Learning Space - (61.04 SQM) - Teaching Space: 1	Student Space (28)	
B007 - R1001 - Entry - (60.58 SQM)	Not Applicable	Circulation or storage space.
B007 - R1002 - General Learning Space - (58.56 SQM) - Teaching Space: 1	Student Space (27)	
B007 - R1003 - General Learning Space - (67.34 SQM) - Teaching Space: 1	Student Space (31)	
B007 - R1004 - General Learning Space - (59.51 SQM) - Teaching Space: 1	Student Space (27)	
B007 - R1005 - General Learning Space - (58.56 SQM) - Teaching Space: 1	Student Space (27)	
B007 - R1006 - Shared Learning Space - (51.81 SQM)	Student Space (24)	
B007 - R1007 - Entry - (13.05 SQM)	Not Applicable	Circulation or storage space.
B007 - R1008 - Interview/Meeting - (29.21 SQM)	Office (7)	
B007 - R1009 - General Learning Space - (61.04 SQM) - Teaching Space: 1	Student Space (28)	
B008 - R0001 - Administration - Clerical - (22.31 SQM)	Office (5)	
B008 - R0003 - Entry - (14.18 SQM)	Not Applicable	Circulation or storage space.
B008 - R0005 - Tea Room - (5.04 SQM)	Not Applicable	Circulation or storage space.
B008 - R0006 - Staff Study - (12.48 SQM)	Office (3)	
B008 - R0007 - Administration - Clerical - (20.17 SQM)	Office (5)	
B008 - R0008 - Administration - Clerical - (84.31 SQM)	Office (21)	
B008 - R0010 - Administration - Executive - (13.13 SQM)	Office (3)	
B008 - R0011 - Clinic - (12.7 SQM)	Office (3)	
B008 - R0013 - Clinic - (12.88 SQM)	Office (3)	
B008 - R0014 - Deputy Principal Office - (14.68 SQM)	Office (3)	
B008 - R0015 - Deputy Principal Office - (13.11 SQM)	Office (3)	
B008 - R0016 - Interview/Meeting - (13.25 SQM)	Office (3)	
B008 - R0017 - Deputy Principal Office - (12.87 SQM)	Office (3)	
B008 - R0020 - Principal Office - (12.81 SQM)	Office (3)	
B008 - R0021 - Principal Office - (21.31 SQM)	Office (5)	
B008 - R0022 - Interview/Meeting - (26.92 SQM)	Office (6)	
B008 - R0024 - Student Reception - (50.74 SQM)	Not Applicable	Circulation or storage space.
B008 - R0025 - Interview/Meeting - (26.73 SQM)	Office (6)	
B00A - R0001 - General Learning Space - (64.05 SQM) - Teaching Space: 1	Student Space (29)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0007 - Computer Learning Space - (52 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R0009 - General Learning Space - (64.86 SQM) - Teaching Space: 1	● Student Space (30)	
B00A - R0010 - General Learning Space - (64.93 SQM) - Teaching Space: 1	● Student Space (30)	
B00A - R0013 - General Learning Space - (65.11 SQM) - Teaching Space: 1	● Student Space (30)	
B00A - R0015 - General Learning Space - (63.96 SQM) - Teaching Space: 1	● Student Space (29)	
B00A - R0017 - Movement - (26.61 SQM)	Not Applicable	Circulation or storage space.
B00A - R0024 - Movement - (58.62 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Commonroom - (64.37 SQM)	● Office (16)	
B00B - R0005 - Seminar - (19.12 SQM)	● Office (4)	
B00B - R0007 - General Learning Space - (48.12 SQM) - Teaching Space: 1	● Student Space (22)	
B00B - R0009 - General Learning Space - (65 SQM) - Teaching Space: 1	● Student Space (30)	
B00B - R0010 - General Learning Space - (65.27 SQM) - Teaching Space: 1	● Student Space (30)	
B00B - R0011 - General Learning Space - (48.25 SQM) - Teaching Space: 1	● Student Space (22)	
B00B - R0012 - General Learning Space - (64.15 SQM) - Teaching Space: 1	● Student Space (29)	
B00B - R0013 - Movement - (16.11 SQM)	Not Applicable	Circulation or storage space.
B00B - R0018 - Movement - (55 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Computer Learning Space - (64.32 SQM) - Teaching Space: 1	● Student Space (29)	
B00C - R0004 - General Learning Space - (51.93 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R0010 - General Learning Space - (52 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R0011 - General Learning Space - (51.93 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R0012 - General Learning Space - (81.57 SQM) - Teaching Space: 1	● Student Space (37)	
B00C - R0016 - General Learning Space - (80.58 SQM) - Teaching Space: 1	● Student Space (37)	
B00C - R0018 - Movement - (8.31 SQM)	Not Applicable	Circulation or storage space.
B00C - R0024 - Movement - (77.37 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - General Learning Space - (64.39 SQM) - Teaching Space: 1	● Student Space (29)	
B00D - R0007 - General Learning Space - (52.15 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R0008 - General Learning Space - (52.15 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R0010 - General Learning Space - (65.28 SQM) - Teaching Space: 1	● Student Space (30)	
B00D - R0011 - General Learning Space - (65.2 SQM) - Teaching Space: 1	● Student Space (30)	
B00D - R0012 - General Learning Space - (51.93 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R0016 - General Learning Space - (64.3 SQM) - Teaching Space: 1	● Student Space (29)	
B00D - R0017 - Movement - (20.34 SQM)	Not Applicable	Circulation or storage space.
B00D - R0022 - Interview/Office - Type 1 - (17.03 SQM)	● Office (4)	
B00D - R0024 - Movement - (63.83 SQM)	Not Applicable	Circulation or storage space.
B00E - R0012 - Laboratory L.S. - (72.28 SQM) - Teaching Space: 1	● Student Space (33)	
B00E - R0017 - Art Learning Space - (72.94 SQM) - Teaching Space: 1	● Student Space (33)	
B00E - R0018 - General Learning Space - (52.08 SQM) - Teaching Space: 1	● Student Space (24)	
B00F - R0009 - Music Learning Space - (52 SQM) - Teaching Space: 1	● Student Space (24)	
B00F - R0023 - General Learning Space - (31.02 SQM) - Teaching Space: 1	● Student Space (14)	
B00F - R0024 - General Learning Space - (52 SQM) - Teaching Space: 1	● Student Space (24)	
B00F - R0027 - Seminar - Type 1 - (26.29 SQM)	● Office (6)	
B00F - R0028 - General Learning Space - (63.74 SQM) - Teaching Space: 1	● Student Space (29)	
B00F - R0029 - General Learning Space - (75.96 SQM) - Teaching Space: 1	● Student Space (35)	
B00F - R0030 - General Learning Space - (34.33 SQM) - Teaching Space: 1	● Student Space (15)	
B00F - R0031 - Entry - (43.15 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Public Reception - (36.8 SQM)	Not Applicable	Circulation or storage space.
B00G - R0003 - Principal Office - (16.43 SQM)	● Office (4)	
B00G - R0005 - Administration - Executive - (10.18 SQM)	● Office (2)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R0009 - Clinic - (5.11 SQM)	Office (1)	
B00G - R0013 - Deputy Principal Office - (10.18 SQM)	Office (2)	
B00G - R0015 - Deputy Principal Office - (15.39 SQM)	Office (3)	
B00G - R0016 - Deputy Principal Office - (15.84 SQM)	Office (3)	
B00G - R0029 - Staff Lounge - (16.02 SQM)	Office (4)	
B00G - R0031 - Leading Teacher - (12.73 SQM)	Office (3)	
B00G - R0032 - Staff Study - (32.03 SQM)	Office (8)	
B00G - R0034 - Movement - (35.37 SQM)	Not Applicable	Circulation or storage space.
B00H - R0008 - Preparation - Science - (29.51 SQM)	Not Applicable	Circulation or storage space.
B00H - R0009 - Laboratory L.S. - (93.4 SQM) - Teaching Space: 1	Student Space (43)	
B00H - R0012 - Laboratory L.S. - (97.09 SQM) - Teaching Space: 1	Student Space (45)	
B00H - R0014 - General Learning Space - (68.31 SQM) - Teaching Space: 1	Student Space (31)	
B00H - R0016 - Movement - (30.92 SQM)	Not Applicable	Circulation or storage space.
B00J - R0010 - General Learning Space - (64.28 SQM) - Teaching Space: 1	Student Space (29)	
B00J - R0011 - General Learning Space - (42.59 SQM) - Teaching Space: 1	Student Space (19)	
B00J - R0012 - Interview/Office - Type 1 - (20.9 SQM)	Office (5)	
B00J - R0015 - Computer Learning Space - (64.64 SQM) - Teaching Space: 1	Student Space (29)	
B00J - R0016 - Staff Study - (20.88 SQM)	Office (5)	
B00J - R0017 - Movement - (53.41 SQM)	Not Applicable	Circulation or storage space.
B00M - M1007 - Study Space - (20.41 SQM)	Not Applicable	Circulation or storage space.
B00M - M1011 - Seminar - (76.75 SQM)	Office (19)	
B00M - M1012 - Computer Learning Space - (65.73 SQM) - Teaching Space: 1	Student Space (30)	
B00M - R0001 - Laboratory L.S. - (91.24 SQM) - Teaching Space: 1	Student Space (42)	
B00M - R0002 - Senior Study - (46.77 SQM)	Office (11)	
B00M - R0004 - Laboratory L.S. - (91.31 SQM) - Teaching Space: 1	Student Space (42)	
B00M - R0006 - Laboratory L.S. - (91.69 SQM) - Teaching Space: 1	Student Space (42)	
B00M - R0007 - Preparation - Science - (47.62 SQM)	Not Applicable	Circulation or storage space.
B00M - R0008 - Laboratory L.S. - (90.97 SQM) - Teaching Space: 1	Student Space (42)	
B00M - R0009 - Movement - (40.82 SQM)	Not Applicable	Circulation or storage space.
B00M - R1004 - Interview/Office - Type 1 - (12.74 SQM)	Office (3)	
B00M - R1007 - Study Space - (11.82 SQM)	Not Applicable	Circulation or storage space.
B00M - R1009 - Study Space - (11.63 SQM)	Not Applicable	Circulation or storage space.
B00M - R1010 - Interview/Office - Type 1 - (11.8 SQM)	Office (2)	
B00M - R1011 - Audio Visual Workroom - (27.89 SQM)	Student Space (12)	
B00M - R1022 - Main Area - (382.84 SQM)	Not Applicable	Circulation or storage space.
B00M - R1024 - Tea Room - (6.31 SQM)	Not Applicable	Circulation or storage space.
B00N - R0001 - Stage - (98.38 SQM)	Not Applicable	Circulation or storage space.
B00N - R0003 - Multi-Purpose Space - (452.84 SQM)	Student Space (210)	
B00N - R0006 - Movement - (21.19 SQM)	Not Applicable	Circulation or storage space.
B00N - R0017 - Staff Kitchen - (13.7 SQM)	Office (3)	
B00O - R0001 - General Learning Space - (64.39 SQM) - Teaching Space: 1	Student Space (29)	
B00O - R0004 - General Learning Space - (65.38 SQM) - Teaching Space: 1	Student Space (30)	
B00O - R0014 - General Learning Space - (64.3 SQM) - Teaching Space: 1	Student Space (29)	
B00O - R0018 - General Learning Space - (65.29 SQM) - Teaching Space: 1	Student Space (30)	
B00O - R0019 - General Learning Space - (52.07 SQM) - Teaching Space: 1	Student Space (24)	
B00O - R0022 - Seminar - (25.68 SQM)	Office (6)	
B00O - R0023 - Movement - (70.68 SQM)	Not Applicable	Circulation or storage space.
B00Q - R0002 - Student Canteen - (55.18 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00R - R0002 - Staff Study - (32.48 SQM)	 Office (8)	
B00R - R0004 - Music Learning Space - (65.02 SQM) - Teaching Space: 1	 Student Space (30)	
B00R - R0008 - Art Learning Space - (64.81 SQM) - Teaching Space: 1	 Student Space (30)	
B00R - R0013 - Art Learning Space - (64.23 SQM) - Teaching Space: 1	 Student Space (29)	
B00R - R0015 - Movement - (44.12 SQM)	Not Applicable	Circulation or storage space.
B00T - R0001 - General Learning Space - (94.18 SQM) - Teaching Space: 1	 Student Space (43)	
B00T - R0002 - Staff Study - (24.15 SQM)	 Office (6)	
B00T - R0003 - General Learning Space - (54.86 SQM) - Teaching Space: 1	 Student Space (25)	
B00T - R0009 - Computer Learning Space - (100.65 SQM) - Teaching Space: 1	 Student Space (46)	
B00T - R0011 - Movement - (26.8 SQM)	Not Applicable	Circulation or storage space.
B00V - R0006 - Tiered Learning Area - (41.31 SQM)	 Student Space (19)	
B00V - R1001 - Tiered Learning Area - (160.34 SQM)	 Student Space (74)	
B00W - R0001 - Tea Room - (11.2 SQM)	Not Applicable	Circulation or storage space.
BOBB - R0001 - General Assistants - (56.37 SQM)	 Office (14)	
NS 110 10651 - NS 110 10651 - Learning Unit - Single Secondary/Secure - (57 SQM)	 Student Space (26)	
NS 110 10885 - NS 110 10885 - Learning Unit - Single Secondary/Secure - (57 SQM)	 Student Space (26)	
NS 110 13250 - NS 110 13250 - Learning Unit - Single Secondary/Secure - (57 SQM)	 Student Space (26)	
OS 600 13862 - OS 600 13862 - Learning Unit - Small - (57 SQM)	 Student Space (26)	