

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Cabramatta Public School (1472)</b>
<b>AMU REGION:</b>	<b>South Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Cabramatta</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Fairfield</b>

1472 - Cabramatta Public School  
Site Plan (12064)



1:855

Printed: 23-Dec-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R0001 - Home Base - (45.09 SQM) - Teaching Space: 1	Student Space (20)	
B00D - R0005 - Home Base - (46.28 SQM) - Teaching Space: 1	Student Space (21)	
B00D - R0006 - Home Base - (48.05 SQM) - Teaching Space: 1	Student Space (22)	
B00D - R0007 - Home Base - (47.13 SQM) - Teaching Space: 1	Student Space (21)	
B00D - R0008 - Home Base - (47.92 SQM) - Teaching Space: 1	Student Space (22)	
B00D - R0009 - Practical Activities - 1hb - (36.09 SQM)	Student Space (16)	
B00D - R0010 - Practical Activities - 1hb - (73.49 SQM)	Student Space (34)	
B00D - R0011 - Movement - (20.03 SQM)	Not Applicable	Circulation or storage space.
B00D - R1001 - Home Base - (48.58 SQM) - Teaching Space: 1	Student Space (22)	
B00D - R1002 - Home Base - (48.58 SQM) - Teaching Space: 1	Student Space (22)	
B00D - R1003 - Practical Activities - 1hb - (37.81 SQM)	Student Space (17)	
B00D - R1004 - Movement - (21.65 SQM)	Not Applicable	Circulation or storage space.
B00D - R1005 - Staff Room Annexe - (12.6 SQM)	Office (3)	
B00D - R1006 - Withdrawal Space - 1hb - (14.35 SQM)	Student Space (6)	
B0A1 - R0001 - Home Base - (51.5 SQM) - Teaching Space: 1	Student Space (23)	
B0A1 - R0002 - Practical Activities - 1hb - (18.18 SQM)	Student Space (8)	
B0A1 - R0003 - Movement - (27.82 SQM)	Not Applicable	Circulation or storage space.
B0A1 - R0005 - Practical Activities - 1hb - (18.18 SQM)	Student Space (8)	
B0A1 - R0006 - Home Base - (49.94 SQM) - Teaching Space: 1	Student Space (23)	
B0A1 - R1001 - Home Base - (51.49 SQM) - Teaching Space: 1	Student Space (23)	
B0A1 - R1002 - Practical Activities - 1hb - (18.34 SQM)	Student Space (8)	
B0A1 - R1003 - Movement - (27.82 SQM)	Not Applicable	Circulation or storage space.
B0A1 - R1005 - Practical Activities - 1hb - (18.34 SQM)	Student Space (8)	
B0A1 - R1006 - Home Base - (49.94 SQM) - Teaching Space: 1	Student Space (23)	
B0A2 - R0001 - Movement - (80.7 SQM)	Not Applicable	Circulation or storage space.
B0A2 - R0002 - Practical Activities - 1hb - (18.34 SQM)	Student Space (8)	
B0A2 - R0003 - Home Base - (51.5 SQM) - Teaching Space: 1	Student Space (23)	
B0A2 - R0004 - Home Base - (51.5 SQM) - Teaching Space: 1	Student Space (23)	
B0A2 - R0005 - Practical Activities - 1hb - (18.34 SQM)	Student Space (8)	
B0A2 - R1001 - Movement - (69.78 SQM)	Not Applicable	Circulation or storage space.
B0A2 - R1002 - Practical Activities - 1hb - (18.18 SQM)	Student Space (8)	
B0A2 - R1003 - Home Base - (51.49 SQM) - Teaching Space: 1	Student Space (23)	
B0A2 - R1004 - Home Base - (51.49 SQM) - Teaching Space: 1	Student Space (23)	
B0A2 - R1005 - Practical Activities - 1hb - (18.18 SQM)	Student Space (8)	
B0A3 - R0007 - Movement - (17.3 SQM)	Not Applicable	Circulation or storage space.
B0A3 - R0008 - Movement - (17.3 SQM)	Not Applicable	Circulation or storage space.
B0A3 - R1007 - Movement - (17.29 SQM)	Not Applicable	Circulation or storage space.
B0A3 - R1008 - Movement - (17.29 SQM)	Not Applicable	Circulation or storage space.
B0A4 - R0002 - Staff Room Annexe - (9.63 SQM)	Office (2)	
B0A4 - R0003 - Practical Activities - 1hb - (10.21 SQM)	Student Space (4)	
B0A4 - R0005 - Home Base - (74.13 SQM) - Teaching Space: 1	Student Space (34)	
B0A4 - R0006 - Home Base - (74.13 SQM) - Teaching Space: 1	Student Space (34)	
B0A4 - R0008 - Practical Activities - 1hb - (10.21 SQM)	Student Space (4)	
B0A4 - R0014 - Movement - (65.46 SQM)	Not Applicable	Circulation or storage space.
B0A4 - R1001 - Practical Activities - 1hb - (18.18 SQM)	Student Space (8)	
B0A4 - R1002 - Home Base - (51.49 SQM) - Teaching Space: 1	Student Space (23)	
B0A4 - R1003 - Home Base - (51.5 SQM) - Teaching Space: 1	Student Space (23)	
B0A4 - R1004 - Practical Activities - 1hb - (18.18 SQM)	Student Space (8)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B0A4 - R1005 - Home Base - (51.81 SQM) - Teaching Space: 1	● Student Space (24)	
B0A4 - R1006 - Practical Activities - 1hb - (18.18 SQM)	● Student Space (8)	
B0A4 - R1012 - Movement - (56.63 SQM)	Not Applicable	Circulation or storage space.
B0A5 - R0001 - Home Base - (79.59 SQM) - Teaching Space: 1	● Student Space (36)	
B0A5 - R0002 - Practical Activities - 1hb - (10.21 SQM)	● Student Space (4)	
B0A5 - R0005 - Practical Activities - 1hb - (10.2 SQM)	● Student Space (4)	
B0A5 - R0007 - Home Base - (79.58 SQM) - Teaching Space: 1	● Student Space (36)	
B0A5 - R0008 - Movement - (57.08 SQM)	Not Applicable	Circulation or storage space.
B0A5 - R1001 - Home Base - (46.43 SQM) - Teaching Space: 1	● Student Space (21)	
B0A5 - R1002 - Special Programs Room - (46.35 SQM)	● Student Space (21)	
B0A5 - R1004 - Practical Activities - 1hb - (18.18 SQM)	● Student Space (8)	
B0A5 - R1005 - Home Base - (63.05 SQM) - Teaching Space: 1	● Student Space (29)	
B0A5 - R1007 - Movement - (48.59 SQM)	Not Applicable	Circulation or storage space.
B0B1 - R0001 - Communal Space - (273.1 SQM)	● Student Space (126)	
B0B1 - R0003 - Raised Platform - (58.43 SQM)	Not Applicable	Circulation or storage space.
B0B1 - R0007 - Canteen - (55.1 SQM)	Not Applicable	Circulation or storage space.
B0B1 - R0011 - Movement - (152.68 SQM)	Not Applicable	Circulation or storage space.
B0B1 - R1001 - Movement - (96.73 SQM)	Not Applicable	Circulation or storage space.
B0B2 - R0004 - Clerical Office - (13.7 SQM)	● Office (3)	
B0B2 - R0005 - Interview - (12.69 SQM)	● Office (3)	
B0B2 - R0006 - Sick Bay - (10.08 SQM)	● Student Space (4)	
B0B2 - R0007 - Principal - (22.31 SQM)	● Office (5)	
B0B2 - R0008 - Clerical Office - (12.6 SQM)	● Office (3)	
B0B2 - R0009 - Entry Vestibule - (14.43 SQM)	Not Applicable	Circulation or storage space.
B0B2 - R0010 - Deputy Principal - (13.24 SQM)	● Office (3)	
B0B2 - R0011 - Duplicating Workroom - (12.61 SQM)	● Office (3)	
B0B2 - R0012 - Staff Room Annexe - (12.6 SQM)	● Office (3)	
B0B2 - R0016 - Movement - (47.96 SQM)	Not Applicable	Circulation or storage space.
B0B2 - R0017 - Staff Room - (50.85 SQM)	● Office (12)	
B0B2 - R0018 - Staff Kitchen - (25.43 SQM)	● Office (6)	
B0B2 - R0019 - Staff Room Annexe - (34.14 SQM)	● Office (8)	
B0B2 - R1003 - Entry Vestibule - (11.55 SQM)	Not Applicable	Circulation or storage space.
B0B2 - R1009 - Seminar/Study - (14.89 SQM)	● Office (3)	
B0B2 - R1010 - Seminar/Study - (14.53 SQM)	● Office (3)	
B0B2 - R1011 - Reading Area - (250.61 SQM)	● Student Space (116)	
B0C1 - R0004 - Staff Room Annexe - (9.73 SQM)	● Office (2)	
B0C1 - R0005 - Practical Activities - 1hb - (18.73 SQM)	● Student Space (8)	
B0C1 - R0006 - Home Base - (51.27 SQM) - Teaching Space: 1	● Student Space (23)	
B0C1 - R0007 - Home Base - (51.19 SQM) - Teaching Space: 1	● Student Space (23)	
B0C1 - R0008 - Practical Activities - 1hb - (18.73 SQM)	● Student Space (8)	
B0C1 - R0010 - Movement - (75.03 SQM)	Not Applicable	Circulation or storage space.
B0C1 - R1002 - Movement - (68.45 SQM)	Not Applicable	Circulation or storage space.
B0C1 - R1005 - Practical Activities - 1hb - (18.73 SQM)	● Student Space (8)	
B0C1 - R1006 - Home Base - (51.42 SQM) - Teaching Space: 1	● Student Space (23)	
B0C1 - R1007 - Home Base - (51.65 SQM) - Teaching Space: 1	● Student Space (23)	
B0C1 - R1008 - Practical Activities - 1hb - (18.73 SQM)	● Student Space (8)	
B0C2 - R0001 - Home Base - (51.49 SQM) - Teaching Space: 1	● Student Space (23)	
B0C2 - R0002 - Practical Activities - 1hb - (18.73 SQM)	● Student Space (8)	
B0C2 - R0007 - Movement - (64.15 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B0C2 - R1001 - Home Base - (51.5 SQM) - Teaching Space: 1	● Student Space (23)	
B0C2 - R1002 - Practical Activities - 1hb - (18.1 SQM)	● Student Space (8)	
B0C2 - R1007 - Movement - (64.11 SQM)	Not Applicable	Circulation or storage space.
B0C3 - R0001 - Practical Activities - 1hb - (18.73 SQM)	● Student Space (8)	
B0C3 - R0002 - Home Base - (51.19 SQM) - Teaching Space: 1	● Student Space (23)	
B0C3 - R0003 - Home Base - (51.26 SQM) - Teaching Space: 1	● Student Space (23)	
B0C3 - R0004 - Practical Activities - 1hb - (18.73 SQM)	● Student Space (8)	
B0C3 - R0005 - Movement - (35.25 SQM)	Not Applicable	Circulation or storage space.
B0C3 - R0006 - Movement - (16.93 SQM)	Not Applicable	Circulation or storage space.
B0C3 - R0007 - Practical Activities - 1hb - (18.1 SQM)	● Student Space (8)	
B0C3 - R0008 - Home Base - (51.61 SQM) - Teaching Space: 1	● Student Space (23)	
B0C3 - R0011 - Practical Activities - 1hb - (23.68 SQM)	● Student Space (10)	
B0C3 - R0012 - Home Base - (46.74 SQM) - Teaching Space: 1	● Student Space (21)	
B0C3 - R1001 - Practical Activities - 1hb - (18.73 SQM)	● Student Space (8)	
B0C3 - R1002 - Home Base - (51.19 SQM) - Teaching Space: 1	● Student Space (23)	
B0C3 - R1003 - Home Base - (51.58 SQM) - Teaching Space: 1	● Student Space (23)	
B0C3 - R1004 - Practical Activities - 1hb - (18.73 SQM)	● Student Space (8)	
B0C3 - R1005 - Movement - (31.88 SQM)	Not Applicable	Circulation or storage space.
B0C3 - R1006 - Movement - (16.93 SQM)	Not Applicable	Circulation or storage space.
B0C3 - R1007 - Practical Activities - 1hb - (18.11 SQM)	● Student Space (8)	
B0C3 - R1008 - Home Base - (51.21 SQM) - Teaching Space: 1	● Student Space (23)	
B0C3 - R1009 - Practical Activities - 1hb - (18.73 SQM)	● Student Space (8)	
B0C3 - R1010 - Home Base - (51.5 SQM) - Teaching Space: 1	● Student Space (23)	
B0F1 - R0001 - Movement - (38.49 SQM)	Not Applicable	Circulation or storage space.
B0F1 - R0002 - Practical Activities - 1hb - (19.4 SQM)	● Student Space (9)	
B0F1 - R0004 - Home Base - (59.22 SQM) - Teaching Space: 1	● Student Space (27)	
B0F1 - R0005 - Withdrawal Space - 2hb - (11.36 SQM)	● Student Space (5)	
B0F1 - R0006 - Home Base - (59.22 SQM) - Teaching Space: 1	● Student Space (27)	
B0F1 - R0008 - Practical Activities - 1hb - (19.41 SQM)	● Student Space (9)	
B0F2 - R0001 - Movement - (38.49 SQM)	Not Applicable	Circulation or storage space.
B0F2 - R0002 - Practical Activities - 1hb - (19.4 SQM)	● Student Space (9)	
B0F2 - R0004 - Home Base - (59.22 SQM) - Teaching Space: 1	● Student Space (27)	
B0F2 - R0005 - Withdrawal Space - 2hb - (11.36 SQM)	● Student Space (5)	
B0F2 - R0006 - Home Base - (59.22 SQM) - Teaching Space: 1	● Student Space (27)	
B0F2 - R0008 - Practical Activities - 1hb - (19.41 SQM)	● Student Space (9)	
OS 601 11148 - OS 601 11148 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 14408 - OS 601 14408 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	