

VENTILATION AUDIT REPORT

SCHOOL:	Cabramatta West Public School (3980)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Cabramatta
LOCAL GOVERNMENT AREA:	Fairfield

3980 - Cabramatta West Public School
Site Plan (10915)



1:1,250

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Special Programs Room - (29.55 SQM)	● Student Space (13)	
B00A - R0002 - Withdrawal Space - 1hb - (28.12 SQM)	● Student Space (13)	
B00A - R0005 - Movement - (6.41 SQM)	Not Applicable	Circulation or storage space.
B00A - R0009 - Home Base - (56.88 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R0010 - Interview - (30.04 SQM)	● Office (7)	
B00C - R0001 - Principal - (19.37 SQM)	● Office (4)	
B00C - R0006 - Staff Room Annexe - (11.54 SQM)	● Office (2)	
B00C - R0010 - Entry Vestibule - (23.34 SQM)	Not Applicable	Circulation or storage space.
B00C - R0015 - Clerical Office - (31.65 SQM)	● Office (7)	
B00C - R0016 - Duplicating Workroom - (18.76 SQM)	● Office (4)	
B00C - R0017 - Sick Bay - (10.23 SQM)	● Student Space (4)	
B00C - R0018 - Home Base - (56.88 SQM) - Teaching Space: 1	● Student Space (26)	
B00E - R0001 - Home Base - (58.61 SQM) - Teaching Space: 1	● Student Space (27)	
B00E - R0004 - Movement - (6.37 SQM)	Not Applicable	Circulation or storage space.
B00E - R0008 - Home Base - (58.26 SQM) - Teaching Space: 1	● Student Space (27)	
B00F - R0001 - Staff Room - (58.6 SQM)	● Office (14)	
B00F - R0004 - Movement - (6.44 SQM)	Not Applicable	Circulation or storage space.
B00F - R0008 - Home Base - (57.41 SQM) - Teaching Space: 1	● Student Space (26)	
B00F - R0009 - Home Base - (56.18 SQM) - Teaching Space: 1	● Student Space (26)	
B00F - R0013 - Movement - (12.96 SQM)	Not Applicable	Circulation or storage space.
B00F - R0017 - Staff Room Annexe - (11.44 SQM)	● Office (2)	
B00F - R0020 - Home Base - (57.73 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R0005 - Home Base - (65.14 SQM) - Teaching Space: 1	● Student Space (30)	
B00G - R0007 - Home Base - (65.14 SQM) - Teaching Space: 1	● Student Space (30)	
B00G - R0016 - Staff Room Annexe - (16.97 SQM)	● Office (4)	
B00G - R0017 - Movement - (14.29 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Home Base - (57.67 SQM) - Teaching Space: 1	● Student Space (26)	
B00H - R0003 - Movement - (6.37 SQM)	Not Applicable	Circulation or storage space.
B00H - R0005 - Home Base - (56.72 SQM) - Teaching Space: 1	● Student Space (26)	
B00H - R0008 - Home Base - (56.88 SQM) - Teaching Space: 1	● Student Space (26)	
B00H - R0010 - Movement - (6.37 SQM)	Not Applicable	Circulation or storage space.
B00H - R0013 - Home Base - (58.05 SQM) - Teaching Space: 1	● Student Space (26)	
B00I - R0001 - Home Base - (67.06 SQM) - Teaching Space: 1	● Student Space (31)	
B00I - R0005 - Movement - (7.48 SQM)	Not Applicable	Circulation or storage space.
B00I - R0008 - Home Base - (67.7 SQM) - Teaching Space: 1	● Student Space (31)	
B00J - R0001 - Home Base - (46.91 SQM) - Teaching Space: 1	● Student Space (21)	
B00J - R0002 - Home Base - (46.59 SQM) - Teaching Space: 1	● Student Space (21)	
B00J - R0003 - Movement - (24.55 SQM)	Not Applicable	Circulation or storage space.
B00K - R0001 - Movement - (99.98 SQM)	Not Applicable	Circulation or storage space.
B00K - R0005 - Home Base - (93.28 SQM) - Teaching Space: 1	● Student Space (43)	
B00K - R0008 - Home Base - (66.89 SQM) - Teaching Space: 1	● Student Space (31)	
B00K - R0009 - Special Programs Room - (32.03 SQM)	● Student Space (14)	
B00L - R0001 - Outdoor Learning Area - (39.84 SQM)	Not Applicable	Circulation or storage space.
B00L - R0002 - Movement - (40.41 SQM)	Not Applicable	Circulation or storage space.
B00L - R0003 - Movement - (40.32 SQM)	Not Applicable	Circulation or storage space.
B00L - R0004 - Outdoor Learning Area - (40.32 SQM)	Not Applicable	Circulation or storage space.
B00L - R0005 - Practical Activities - 1hb - (14.1 SQM)	● Student Space (6)	
B00L - R0006 - Home Base - (66.92 SQM) - Teaching Space: 1	● Student Space (31)	
B00L - R0011 - Home Base - (66.64 SQM) - Teaching Space: 1	● Student Space (30)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00L - R0012 - Home Base - (66.64 SQM) - Teaching Space: 1	Student Space (30)	
B00L - R0015 - Practical Activities - 1hb - (14.1 SQM)	Student Space (6)	
B00L - R0017 - Home Base - (66.64 SQM) - Teaching Space: 1	Student Space (30)	
B00L - R0018 - Staff Room Annexe - (15.21 SQM)	Office (3)	
B00L - R0019 - Duplicating Workroom - (17.06 SQM)	Office (4)	
B00L - R0025 - Entry Vestibule - (14.06 SQM)	Not Applicable	Circulation or storage space.
B00M - R0002 - Special Programs Room - (27.52 SQM)	Student Space (12)	
B00M - R0003 - Home Base - (46.85 SQM) - Teaching Space: 1	Student Space (21)	
B00P - R0001 - Movement - (20.11 SQM)	Not Applicable	Circulation or storage space.
B00P - R0005 - Canteen - (43.09 SQM)	Not Applicable	Circulation or storage space.
B00P - R0006 - Movement - (20.12 SQM)	Not Applicable	Circulation or storage space.
B00P - R0007 - Movement - (41.99 SQM)	Not Applicable	Circulation or storage space.
B00T - R0001 - Movement - (38.47 SQM)	Not Applicable	Circulation or storage space.
B00T - R0002 - Practical Activities - 1hb - (19.4 SQM)	Student Space (9)	
B00T - R0004 - Home Base - (59.19 SQM) - Teaching Space: 1	Student Space (27)	
B00T - R0005 - Withdrawal Space - 2hb - (11.36 SQM)	Student Space (5)	
B00T - R0006 - Home Base - (59.2 SQM) - Teaching Space: 1	Student Space (27)	
B00T - R0008 - Practical Activities - 1hb - (19.4 SQM)	Student Space (9)	
B00U - R0001 - Entry Vestibule - (24.41 SQM)	Not Applicable	Circulation or storage space.
B00U - R0002 - Clerical Office - (34.36 SQM)	Office (8)	
B00U - R0003 - Duplicating Workroom - (24.38 SQM)	Office (6)	
B00U - R0004 - Sick Bay - (8.91 SQM)	Student Space (4)	
B00U - R0011 - Interview - (17.04 SQM)	Office (4)	
B00U - R0013 - Staff Room Annexe - (27.82 SQM)	Office (6)	
B00U - R0014 - Staff Room - (56.74 SQM)	Office (14)	
B00U - R0015 - Deputy Principal - (13.2 SQM)	Office (3)	
B00U - R0016 - Deputy Principal - (12.83 SQM)	Office (3)	
B00U - R0017 - Principal - (17.06 SQM)	Office (4)	
B00U - R0018 - Interview - (12.94 SQM)	Office (3)	
B00U - R0019 - Movement - (66.87 SQM)	Not Applicable	Circulation or storage space.
B00U - R0020 - Staff Kitchen - (8.22 SQM)	Office (2)	
B00V - R0001 - Reading Area - (232.11 SQM)	Student Space (107)	
B00W - R0001 - Communal Space - (203.79 SQM)	Student Space (94)	
B00W - R0002 - Raised Platform - (61.57 SQM)	Not Applicable	Circulation or storage space.
B00W - R0017 - Movement - (7.78 SQM)	Not Applicable	Circulation or storage space.
B00W - R0018 - Movement - (11.48 SQM)	Not Applicable	Circulation or storage space.
B00W - R0019 - Movement - (13.38 SQM)	Not Applicable	Circulation or storage space.
BOB1 - R0001 - Home Base - (53.58 SQM) - Teaching Space: 1	Student Space (24)	
BOB1 - R0002 - Home Base - (53.43 SQM) - Teaching Space: 1	Student Space (24)	
BOB1 - R0005 - Home Base - (53.43 SQM) - Teaching Space: 1	Student Space (24)	
BOB1 - R0006 - Home Base - (53.58 SQM) - Teaching Space: 1	Student Space (24)	
BOB1 - R0007 - Movement - (57.31 SQM)	Not Applicable	Circulation or storage space.
BOB2 - R0001 - Home Base - (53.44 SQM) - Teaching Space: 1	Student Space (24)	
BOB2 - R0002 - Home Base - (53.44 SQM) - Teaching Space: 1	Student Space (24)	
BOB2 - R0003 - Movement - (6.59 SQM)	Not Applicable	Circulation or storage space.
BOB2 - R0004 - Staff Room Annexe - (10.47 SQM)	Office (2)	
BOB2 - R0007 - Home Base - (53.58 SQM) - Teaching Space: 1	Student Space (24)	
BOB2 - R0008 - Home Base - (53.29 SQM) - Teaching Space: 1	Student Space (24)	
BOB2 - R0009 - Movement - (57.04 SQM)	Not Applicable	Circulation or storage space.