


VENTILATION AUDIT REPORT

SCHOOL:	Caddies Creek Public School (4615)
AMU REGION:	Western Sydney
STATE ELECTORATE:	Riverstone
LOCAL GOVERNMENT AREA:	Blacktown

4615 - Caddies Creek Public School
Site Plan (14603)


















Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Entry Vestibule - (24.13 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Clerical Office - (57.48 SQM)	Office (14)	
B00A - R0003 - Sick Bay - (8.79 SQM)	Student Space (4)	
B00A - R0005 - Principal - (16.92 SQM)	Office (4)	
B00A - R0011 - Staff Room - (58.84 SQM)	Office (14)	
B00A - R0012 - Staff Room Annexe - (25.79 SQM)	Office (6)	
B00A - R0013 - Deputy Principal - (12.7 SQM)	Office (3)	
B00A - R0014 - Deputy Principal - (12.66 SQM)	Office (3)	
B00A - R0016 - Interview - (12.81 SQM)	Office (3)	
B00A - R0017 - Movement - (39.29 SQM)	Not Applicable	Circulation or storage space.
B00A - R0018 - Home Base - M - (61.09 SQM) - Teaching Space: 1	Student Space (28)	
B00A - R0020 - Practical Activities - M - 1hb - (19.2 SQM)	Student Space (8)	
B00A - R0021 - Withdrawal - M - (11.28 SQM)	Student Space (5)	
B00A - R0022 - Practical Activities - M - 1hb - (19.2 SQM)	Student Space (8)	
B00A - R0024 - Home Base - M - (61.08 SQM) - Teaching Space: 1	Student Space (28)	
B00A - R0027 - Home Base - (60.27 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R0029 - Practical Activities - 1hb - (19.09 SQM)	Student Space (8)	
B00A - R0030 - Withdrawal Space - 2hb - (11.61 SQM)	Student Space (5)	
B00A - R0031 - Practical Activities - 1hb - (19.09 SQM)	Student Space (8)	
B00A - R0033 - Home Base - (59.91 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R0034 - Canteen - (47.59 SQM)	Not Applicable	Circulation or storage space.
B00A - R0036 - Movement - (441.07 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Home Base - (60.63 SQM) - Teaching Space: 1	Student Space (28)	
B00B - R0003 - Practical Activities - 1hb - (18.91 SQM)	Student Space (8)	
B00B - R0004 - Withdrawal Space - 2hb - (11.68 SQM)	Student Space (5)	
B00B - R0005 - Practical Activities - 1hb - (18.94 SQM)	Student Space (8)	
B00B - R0007 - Home Base - (60.63 SQM) - Teaching Space: 1	Student Space (28)	
B00B - R0011 - Movement - (5.54 SQM)	Not Applicable	Circulation or storage space.
B00B - R0012 - Special Programs Room - (32.55 SQM)	Student Space (15)	
B00B - R0013 - Reading Area - (231.81 SQM)	Student Space (107)	
B00B - R0021 - Movement - (286.07 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Home Base - (60.55 SQM) - Teaching Space: 1	Student Space (28)	
B00C - R0003 - Practical Activities - 1hb - (19.12 SQM)	Student Space (8)	
B00C - R0004 - Withdrawal Space - 2hb - (11.63 SQM)	Student Space (5)	
B00C - R0005 - Practical Activities - 1hb - (20.02 SQM)	Student Space (9)	
B00C - R0007 - Home Base - (60.55 SQM) - Teaching Space: 1	Student Space (28)	
B00C - R0009 - Home Base - (60.54 SQM) - Teaching Space: 1	Student Space (28)	
B00C - R0011 - Practical Activities - 1hb - (20.02 SQM)	Student Space (9)	
B00C - R0012 - Withdrawal Space - 2hb - (11.63 SQM)	Student Space (5)	
B00C - R0013 - Practical Activities - 1hb - (20.02 SQM)	Student Space (9)	
B00C - R0015 - Home Base - (60.54 SQM) - Teaching Space: 1	Student Space (28)	
B00C - R0020 - Home Base - (60.54 SQM) - Teaching Space: 1	Student Space (28)	
B00C - R0022 - Practical Activities - 1hb - (18.3 SQM)	Student Space (8)	
B00C - R0023 - Withdrawal Space - 2hb - (11.62 SQM)	Student Space (5)	
B00C - R0024 - Practical Activities - 1hb - (20.02 SQM)	Student Space (9)	
B00C - R0026 - Home Base - (60.54 SQM) - Teaching Space: 1	Student Space (28)	
B00C - R0027 - Movement - (155.1 SQM)	Not Applicable	Circulation or storage space.
B00D - R0007 - Movement - (6.76 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R0010 - Movement - (9 SQM)	Not Applicable	Circulation or storage space.
B00D - R0011 - Raised Platform - (53.01 SQM)	Not Applicable	Circulation or storage space.
B00D - R0012 - Movement - (28.21 SQM)	Not Applicable	Circulation or storage space.
B00D - R0015 - Movement - (6.81 SQM)	Not Applicable	Circulation or storage space.
B00D - R0019 - Communal Space - (203.61 SQM)	● Student Space (94)	
B00E - R0001 - Home Base - (60.48 SQM) - Teaching Space: 1	● Student Space (28)	
B00E - R0003 - Practical Activities - 1hb - (20.06 SQM)	● Student Space (9)	
B00E - R0004 - Withdrawal Space - 2hb - (11.6 SQM)	● Student Space (5)	
B00E - R0005 - Practical Activities - 1hb - (18.95 SQM)	● Student Space (8)	
B00E - R0007 - Home Base - (60.48 SQM) - Teaching Space: 1	● Student Space (28)	
B00E - R0009 - Special Programs Room - (35.57 SQM)	● Student Space (16)	
B00E - R0012 - Home Base - (60.48 SQM) - Teaching Space: 1	● Student Space (28)	
B00E - R0014 - Practical Activities - 1hb - (20.05 SQM)	● Student Space (9)	
B00E - R0015 - Withdrawal Space - 2hb - (11.6 SQM)	● Student Space (5)	
B00E - R0016 - Practical Activities - 1hb - (19.09 SQM)	● Student Space (8)	
B00E - R0018 - Home Base - (60.48 SQM) - Teaching Space: 1	● Student Space (28)	
B00E - R0020 - Movement - (116.49 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Movement - (38.49 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Practical Activities - 1hb - (19.4 SQM)	● Student Space (9)	
B00F - R0004 - Home Base - (59.22 SQM) - Teaching Space: 1	● Student Space (27)	
B00F - R0005 - Withdrawal Space - 2hb - (11.36 SQM)	● Student Space (5)	
B00F - R0006 - Home Base - (59.21 SQM) - Teaching Space: 1	● Student Space (27)	
B00F - R0008 - Practical Activities - 1hb - (19.42 SQM)	● Student Space (9)	
B00G - R0004 - Practical Activities - 1hb - (19.33 SQM)	● Student Space (8)	
B00G - R0006 - Withdrawal Space - 1hb - (11.45 SQM)	● Student Space (5)	
B00G - R0007 - Practical Activities - 1hb - (19.24 SQM)	● Student Space (8)	
B00G - R0009 - Practical Activities - 1hb - (19.39 SQM)	● Student Space (8)	
B00G - R0011 - Withdrawal Space - 2hb - (11.52 SQM)	● Student Space (5)	
B00G - R0012 - Practical Activities - 1hb - (19.52 SQM)	● Student Space (9)	
B00G - R0014 - Practical Activities - 1hb - (19.56 SQM)	● Student Space (9)	
B00G - R0016 - Withdrawal Space - 2hb - (11.59 SQM)	● Student Space (5)	
B00G - R0017 - Practical Activities - S - 1hb - (19.66 SQM)	● Student Space (9)	
B00G - R0020 - Home Base - (59.84 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R0021 - Home Base - (59.98 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R0022 - Home Base - (60.11 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R0023 - Home Base - (60.15 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R0024 - Home Base - (60.16 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R0025 - Home Base - (60.24 SQM) - Teaching Space: 1	● Student Space (27)	
B00H - R0001 - Special Programs Room - (65.82 SQM)	● Student Space (30)	
B00H - R0002 - Staff Room - (7.72 SQM)	● Office (1)	
B00H - R0003 - Staff Room - (7.67 SQM)	● Office (1)	
B00I - R0001 - Home Base - M - (54.54 SQM) - Teaching Space: 1	● Student Space (25)	
OS 602 10301 - OS 602 10301 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 10329 - OS 602 10329 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 11045 - OS 602 11045 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 11653 - OS 602 11653 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 12485 - OS 602 12485 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	

Entity Location	Audit Condition Classification (Capacity)	Comment
OS 602 13647 - OS 602 13647 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 13795 - OS 602 13795 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 14158 - OS 602 14158 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 14213 - OS 602 14213 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 14452 - OS 602 14452 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 14473 - OS 602 14473 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 14474 - OS 602 14474 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 15625 - OS 602 15625 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 15633 - OS 602 15633 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 16824 - OS 602 16824 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 603 11151 - OS 603 11151 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	 Student Space (35)	
OS 603 12620 - OS 603 12620 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	 Student Space (35)	
OS 603 13256 - OS 603 13256 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	 Student Space (35)	
OS 603 14360 - OS 603 14360 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	 Student Space (35)	
OS 751 17669 - OS 751 17669 - Learning Unit - ESL - (76 SQM)	 Student Space (35)	