

VENTILATION AUDIT REPORT

SCHOOL:	Callaghan College Wallsend Campus (8259)
AMU REGION:	Hunter/Central Coast
STATE ELECTORATE:	Wallsend
LOCAL GOVERNMENT AREA:	Newcastle

8259 - Callaghan College Wallsend Campus
Site Plan (10626)



1:1,776

Printed: 24-Nov-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Principal Office - (18.02 SQM)	Office (4)	
B00A - R0002 - Deputy Principal Office - (14.84 SQM)	Office (3)	
B00A - R0004 - Leading Teacher - (11.28 SQM)	Office (2)	
B00A - R0015 - Movement - (16.25 SQM)	Not Applicable	Circulation or storage space.
B00A - R0022 - Interview/Office - Type 1 - (5.17 SQM)	Office (1)	
B00A - R0023 - Interview/Office - Type 1 - (5.15 SQM)	Office (1)	
B00A - R0024 - Interview/Office - Type 1 - (13.95 SQM)	Office (3)	
B00A - R0029 - Seminar - (26.49 SQM)	Office (6)	
B00A - R0039 - Laboratory L.S. - (90.1 SQM) - Teaching Space: 1	Student Space (41)	
B00A - R0040 - Preparation - (17.17 SQM)	Not Applicable	Circulation or storage space.
B00A - R0041 - Darkroom Space - (10.48 SQM)	Office (2)	
B00A - R0042 - Tiered Learning Area - (52.92 SQM)	Student Space (24)	
B00A - R0043 - Growing/Breeding - (7.9 SQM)	Not Applicable	Circulation or storage space.
B00A - R0044 - Preparation - (17.67 SQM)	Not Applicable	Circulation or storage space.
B00A - R0045 - Laboratory L.S. - (99.87 SQM) - Teaching Space: 1	Student Space (46)	
B00A - R0047 - Movement - (6.59 SQM)	Not Applicable	Circulation or storage space.
B00A - R0048 - Movement - (24.14 SQM)	Not Applicable	Circulation or storage space.
B00A - R0049 - Movement - (14.62 SQM)	Not Applicable	Circulation or storage space.
B00A - R0053 - Movement - (127 SQM)	Not Applicable	Circulation or storage space.
B00A - R0060 - Movement - (18.45 SQM)	Not Applicable	Circulation or storage space.
B00A - R0061 - Movement - (16.17 SQM)	Not Applicable	Circulation or storage space.
B00A - R0062 - Administration - Clerical - (64.25 SQM)	Office (16)	
B00A - R0063 - Administration - Clerical - (13.29 SQM)	Office (3)	
B00A - R0064 - Movement - (19.79 SQM)	Not Applicable	Circulation or storage space.
B00A - R0065 - Movement - (41.16 SQM)	Not Applicable	Circulation or storage space.
B00A - R0068 - Student Canteen - (50.26 SQM)	Not Applicable	Circulation or storage space.
B00A - R0069 - Movement - (113.19 SQM)	Not Applicable	Circulation or storage space.
B00A - R0070 - Art Learning Space - (104.06 SQM) - Teaching Space: 1	Student Space (48)	
B00A - R0072 - Multi Media Workshop - (25.87 SQM)	Not Applicable	Circulation or storage space.
B00A - R0073 - Art Learning Space - (59.1 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R1005 - Clinic - Girls - (21.48 SQM)	Office (5)	
B00A - R1008 - Clinic - Boys - (21.5 SQM)	Office (5)	
B00A - R1009 - Staff Study - (52.99 SQM)	Office (13)	
B00A - R1012 - Interview/Office - Type 1 - (14.65 SQM)	Office (3)	
B00A - R1013 - Interview/Office - Type 1 - (8.27 SQM)	Office (2)	
B00A - R1015 - General Learning Space - (52.99 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1016 - General Learning Space - (52.77 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1019 - Materials Technology L.S. - (66.17 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R1023 - Materials Technology L.S. - (72.45 SQM) - Teaching Space: 1	Student Space (33)	
B00A - R1024 - Ancillary Staff - (12.6 SQM)	Office (3)	
B00A - R1027 - General Learning Space - (41.82 SQM) - Teaching Space: 1	Student Space (19)	
B00A - R1030 - General Learning Space - (52.77 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1031 - General Learning Space - (66.39 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R1032 - General Learning Space - (52.77 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1033 - General Learning Space - (72.45 SQM) - Teaching Space: 1	Student Space (33)	
B00A - R1043 - Movement - (17.83 SQM)	Not Applicable	Circulation or storage space.
B00A - R1045 - Movement - (53.27 SQM)	Not Applicable	Circulation or storage space.
B00A - R1048 - Principal Office - (18.95 SQM)	Office (4)	
B00A - R1049 - Deputy Principal Office - (26.24 SQM)	Office (6)	
B00A - R1050 - Movement - (209.03 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R1051 - General Learning Space - (46.12 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R1052 - Stage - (28.23 SQM)	Not Applicable	Circulation or storage space.
B00A - R1053 - Multi Media Workshop - (25.72 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Seminar - (11.06 SQM)	● Office (2)	
B00B - R0002 - Audio Visual Workroom - (10.84 SQM)	● Student Space (5)	
B00B - R0003 - Seminar - (11.02 SQM)	● Office (2)	
B00B - R0012 - Design L.S. - (52.78 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0020 - Movement - (16.51 SQM)	Not Applicable	Circulation or storage space.
B00B - R0023 - Movement - (10.74 SQM)	Not Applicable	Circulation or storage space.
B00B - R0025 - Movement - (37.14 SQM)	Not Applicable	Circulation or storage space.
B00B - R0026 - Movement - (47.09 SQM)	Not Applicable	Circulation or storage space.
B00B - R0028 - Computer Learning Space - (65.89 SQM) - Teaching Space: 1	● Student Space (30)	
B00B - R0029 - Entry - (31.4 SQM)	Not Applicable	Circulation or storage space.
B00B - R0031 - Staff Study - (19.86 SQM)	● Office (4)	
B00B - R0033 - Administration - Clerical - (12.85 SQM)	● Office (3)	
B00B - R0034 - Workroom - (99.71 SQM)	● Office (24)	
B00B - R0035 - Main Area - (414.86 SQM)	Not Applicable	Circulation or storage space.
B00B - R0037 - Movement - (9.35 SQM)	Not Applicable	Circulation or storage space.
B00B - R0038 - Computer Learning Space - (63.41 SQM) - Teaching Space: 1	● Student Space (29)	
B00B - R1009 - Computer Learning Space - (52.85 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1010 - Computer Learning Space - (52.85 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1016 - Movement - (65.84 SQM)	Not Applicable	Circulation or storage space.
B00B - R1017 - Movement - (81.95 SQM)	Not Applicable	Circulation or storage space.
B00B - R1018 - Staff Study - (174.58 SQM)	● Office (43)	
B00B - R1019 - Seminar - (14.96 SQM)	● Office (3)	
B00B - R1020 - Seminar - (14.96 SQM)	● Office (3)	
B00B - R1026 - Seminar - (15.57 SQM)	● Office (3)	
B00B - R1027 - Seminar - (14.7 SQM)	● Office (3)	
B00B - R1028 - Duplicating Workroom - (35.02 SQM)	● Office (8)	
B00B - R1029 - Staff Study - (219.21 SQM)	● Office (54)	
B00B - R1030 - Commonroom - (113.41 SQM)	● Office (28)	
B00B - R1031 - General Learning Space - (52.7 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R0001 - Laboratory L.S. - (87.36 SQM) - Teaching Space: 1	● Student Space (40)	
B00C - R0003 - Preparation - (27.97 SQM)	Not Applicable	Circulation or storage space.
B00C - R0004 - Laboratory L.S. - (86.8 SQM) - Teaching Space: 1	● Student Space (40)	
B00C - R0005 - Art Learning Space - (53.36 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R0013 - Movement - (98.52 SQM)	Not Applicable	Circulation or storage space.
B00C - R0015 - Movement - (15.43 SQM)	Not Applicable	Circulation or storage space.
B00C - R0017 - Movement - (14.99 SQM)	Not Applicable	Circulation or storage space.
B00C - R0020 - Laboratory L.S. - (106.01 SQM) - Teaching Space: 1	● Student Space (49)	
B00C - R0021 - Seminar - Type 1 - (30.25 SQM)	● Office (7)	
B00C - R1001 - General Learning Space - (53.29 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R1002 - General Learning Space - (52.91 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R1003 - General Learning Space - (52.77 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R1004 - Music Learning Space - (52.63 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R1007 - General Learning Space - (52.92 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R1010 - General Learning Space - (52.91 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R1015 - Movement - (90.49 SQM)	Not Applicable	Circulation or storage space.
B00C - R1019 - General Learning Space - (66.76 SQM) - Teaching Space: 1	● Student Space (30)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R9003 - Movement - (7 SQM)	Not Applicable	Circulation or storage space.
B00D - R0023 - General Learning Space - Bd/Cd/Ed - (74.92 SQM) - Teaching Space: 1	● Student Space (34)	
B00D - R0026 - Movement - (5.92 SQM)	Not Applicable	Circulation or storage space.
B00D - R0030 - General Learning Space - Type 1 - (64.98 SQM) - Teaching Space: 1	● Student Space (30)	
B00D - R0033 - Music Learning Space - (62.16 SQM) - Teaching Space: 1	● Student Space (28)	
B00D - R0034 - Performance Workspace - (100.42 SQM) - Teaching Space: 1	● Student Space (46)	
B00D - R0035 - Practice/Seminar - (19.95 SQM)	Not Applicable	Circulation or storage space.
B00D - R0038 - Practical Activities Area - 2 G.L.S. - (15.95 SQM)	● Student Space (7)	
B00E - M0003 - Movement - (21.72 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Student Canteen - (9.64 SQM)	Not Applicable	Circulation or storage space.
B00E - R0004 - Multi-Purpose Space - (355.5 SQM)	● Student Space (164)	
B00E - R0005 - Movement - (22.12 SQM)	Not Applicable	Circulation or storage space.
B00E - R0008 - Movement - (20.11 SQM)	Not Applicable	Circulation or storage space.
B00E - R0015 - Movement - (7.54 SQM)	Not Applicable	Circulation or storage space.
B00E - R0016 - Movement - (7.54 SQM)	Not Applicable	Circulation or storage space.
B00E - R0017 - Movement - (56.29 SQM)	Not Applicable	Circulation or storage space.
B00E - R0018 - Movement - (6.73 SQM)	Not Applicable	Circulation or storage space.
B00E - R0019 - Stage - (87.16 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Movement - (23.59 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Movement - (44.27 SQM)	Not Applicable	Circulation or storage space.
B00J - R0001 - General Learning Space - (59.71 SQM) - Teaching Space: 1	● Student Space (27)	
B00J - R0003 - General Learning Space - Type 9 - (59.18 SQM) - Teaching Space: 1	● Student Space (27)	
B00J - R0005 - General Learning Space - Type 8 - (59.68 SQM) - Teaching Space: 1	● Student Space (27)	
B00J - R0007 - General Learning Space - Type 9 - (59.85 SQM) - Teaching Space: 1	● Student Space (27)	
B00J - R0009 - Materials Workshop - Type 2 - (118.9 SQM)	● Student Space (55)	
B00J - R0012 - Materials Workshop - Type 2 - (118.94 SQM)	● Student Space (55)	
B00J - R0013 - Outdoor Workshop - (112.75 SQM)	Not Applicable	Circulation or storage space.
B00J - R0018 - Outdoor Workshop - (83.01 SQM)	Not Applicable	Circulation or storage space.
B00J - R1001 - General Learning Space - Type 7 - (64.34 SQM) - Teaching Space: 1	● Student Space (29)	
B00J - R1003 - General Learning Space - Type 6 - (59.95 SQM) - Teaching Space: 1	● Student Space (27)	
B00J - R1004 - General Learning Space - Type 7 - (63.91 SQM) - Teaching Space: 1	● Student Space (29)	
B00J - R1006 - General Learning Space - Type 6 - (58.85 SQM) - Teaching Space: 1	● Student Space (27)	
B00J - R1007 - Seminar/Technology Space - (36.37 SQM)	● Office (9)	
B00J - R1009 - Kitchen - Type 2 - (128.7 SQM)	● Student Space (59)	
B00J - R1011 - Preparation - Materials - (29.07 SQM)	Not Applicable	Circulation or storage space.
B00J - R1014 - Movement - (21.98 SQM)	Not Applicable	Circulation or storage space.
B00J - R1015 - Kitchen - Type 1 - (101.54 SQM)	● Student Space (47)	
OS 600 10446 - OS 600 10446 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 600 15504 - OS 600 15504 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 601 13105 - OS 601 13105 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 13915 - OS 601 13915 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 13945 - OS 601 13945 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 19024 - OS 601 19024 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 19725 - OS 601 19725 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 19856 - OS 601 19856 - Learning Unit - Standard/Withdrawal - (SQM)	● Student Space ()	
OS 720 13266 - OS 720 13266 - Science Laboratory/Prep Room - (114 SQM)	Not Applicable	Circulation or storage space.