

VENTILATION AUDIT REPORT

SCHOOL:	Cambridge Gardens Public School (4484)
AMU REGION:	Western Sydney
STATE ELECTORATE:	Penrith
LOCAL GOVERNMENT AREA:	Penrith

4484 - Cambridge Gardens Public School
Site Plan (10135)



1:948

Printed: 07-Oct-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (15.96 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Principal - (20.28 SQM)	Office (5)	
B00A - R0003 - Entry Vestibule - (14 SQM)	Not Applicable	Circulation or storage space.
B00A - R0004 - Clerical Office - (13.32 SQM)	Office (3)	
B00A - R0005 - Clerical Office/Workroom - (12.97 SQM)	Office (3)	
B00A - R0006 - Duplicating Workroom - (13.85 SQM)	Office (3)	
B00A - R0011 - Staff Room - (73.51 SQM)	Office (18)	
B00A - R0012 - Movement - (7.68 SQM)	Not Applicable	Circulation or storage space.
B00A - R0014 - Movement - (7.74 SQM)	Not Applicable	Circulation or storage space.
B00A - R0018 - Sick Bay - (8.19 SQM)	Student Space (3)	
B00A - R0020 - Clerical Office/Workroom - (12.93 SQM)	Office (3)	
B00A - R0021 - Interview - (12.89 SQM)	Office (3)	
B00A - R0022 - Movement - (25.62 SQM)	Not Applicable	Circulation or storage space.
B00A - R0023 - Movement - (5.23 SQM)	Not Applicable	Circulation or storage space.
B00A - R0024 - Deputy Principal - (14.81 SQM)	Office (3)	
B00B - R0001 - Movement - (99.97 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Home Base - (62.23 SQM) - Teaching Space: 1	Student Space (28)	
B00B - R0004 - Withdrawal Space - 1hb - (13.8 SQM)	Student Space (6)	
B00B - R0006 - Practical Activities - 1hb - (34.75 SQM)	Student Space (16)	
B00B - R0008 - Home Base - (62.02 SQM) - Teaching Space: 1	Student Space (28)	
B00B - R0010 - Practical Activities - 1hb - (17.73 SQM)	Student Space (8)	
B00B - R0011 - Home Base - (61.98 SQM) - Teaching Space: 1	Student Space (28)	
B00B - R0012 - Withdrawal Space - 1hb - (7.24 SQM)	Student Space (3)	
B00B - R0018 - Practical Activities - 1hb - (34.91 SQM)	Student Space (16)	
B00B - R0021 - Home Base - (62.1 SQM) - Teaching Space: 1	Student Space (28)	
B00B - R0023 - Withdrawal Space - 1hb - (13.71 SQM)	Student Space (6)	
B00B - R0024 - Home Base - (62.01 SQM) - Teaching Space: 1	Student Space (28)	
B00C - M0001 - Withdrawal Space - 1hb - (20.82 SQM)	Student Space (9)	
B00C - R0001 - Movement - (27.49 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Practical Activities - 1hb - (12.54 SQM)	Student Space (5)	
B00C - R0003 - Home Base - (83.24 SQM) - Teaching Space: 1	Student Space (38)	
B00C - R0005 - Movement - (27.3 SQM)	Not Applicable	Circulation or storage space.
B00C - R0006 - Practical Activities - 1hb - (12.03 SQM)	Student Space (5)	
B00C - R0007 - Home Base - (75.67 SQM) - Teaching Space: 1	Student Space (35)	
B00C - R0009 - Movement - (10.53 SQM)	Not Applicable	Circulation or storage space.
B00C - R0015 - Movement - (29.34 SQM)	Not Applicable	Circulation or storage space.
B00C - R0016 - Practical Activities - 1hb - (12.11 SQM)	Student Space (5)	
B00C - R0017 - Home Base - (75.34 SQM) - Teaching Space: 1	Student Space (34)	
B00C - R0019 - Movement - (51.86 SQM)	Not Applicable	Circulation or storage space.
B00D - R0004 - Canteen - (45.52 SQM)	Not Applicable	Circulation or storage space.
B00D - R0006 - Movement - (21.63 SQM)	Not Applicable	Circulation or storage space.
B00D - R0007 - Communal Space - (235.12 SQM)	Student Space (109)	
B00D - R0010 - Movement - (17.81 SQM)	Not Applicable	Circulation or storage space.
B00D - R0013 - Raised Platform - (44.36 SQM)	Not Applicable	Circulation or storage space.
B00D - R0016 - Movement - (42.17 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Movement - (29.95 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Withdrawal Space - 1hb - (79.63 SQM)	Student Space (36)	
B00G - R0001 - Movement - (18.28 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Practical Activities - 1hb - (12.26 SQM)	Student Space (5)	
B00G - R0003 - Home Base - (63.69 SQM) - Teaching Space: 1	Student Space (29)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R0004 - Movement - (18.27 SQM)	Not Applicable	Circulation or storage space.
B00G - R0005 - Practical Activities - 1hb - (12.09 SQM)	● Student Space (5)	
B00G - R0006 - Home Base - (58.81 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R0007 - Movement - (9.3 SQM)	Not Applicable	Circulation or storage space.
B00G - R0012 - Movement - (35.91 SQM)	Not Applicable	Circulation or storage space.
B00G - R0014 - Movement - (18.28 SQM)	Not Applicable	Circulation or storage space.
B00G - R0015 - Practical Activities - 1hb - (12.21 SQM)	● Student Space (5)	
B00G - R0016 - Home Base - (58.58 SQM) - Teaching Space: 1	● Student Space (27)	
B00I - R0001 - Movement - (31.05 SQM)	Not Applicable	Circulation or storage space.
B00I - R0009 - Reading Area - (42.52 SQM)	● Student Space (19)	
B00I - R0012 - Reading Area - (223.16 SQM)	● Student Space (103)	
B00J - R0001 - Movement - (18.41 SQM)	Not Applicable	Circulation or storage space.
B00J - R0002 - Home Base - (64.03 SQM) - Teaching Space: 1	● Student Space (29)	
B00J - R0003 - Practical Activities - 1hb - (12.05 SQM)	● Student Space (5)	
B00J - R0004 - Home Base - (58.09 SQM) - Teaching Space: 1	● Student Space (26)	
B00J - R0005 - Practical Activities - 1hb - (12.09 SQM)	● Student Space (5)	
B00J - R0006 - Movement - (20.24 SQM)	Not Applicable	Circulation or storage space.
B00J - R0008 - Movement - (36 SQM)	Not Applicable	Circulation or storage space.
B00J - R0013 - Movement - (9.43 SQM)	Not Applicable	Circulation or storage space.
B00J - R0014 - Home Base - (57.25 SQM) - Teaching Space: 1	● Student Space (26)	
B00J - R0015 - Practical Activities - 1hb - (12.27 SQM)	● Student Space (5)	
B00J - R0016 - Movement - (18.23 SQM)	Not Applicable	Circulation or storage space.
OS 602 15329 - OS 602 15329 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 19446 - OS 602 19446 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 19469 - OS 602 19469 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 606 17094 - OS 606 17094 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 606 19040 - OS 606 19040 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 606 19184 - OS 606 19184 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	