


VENTILATION AUDIT REPORT

SCHOOL:	Camden Haven High School (8280)
AMU REGION:	North Coast
STATE ELECTORATE:	Port Macquarie
LOCAL GOVERNMENT AREA:	Port Macquarie-Hastings

8280 - Camden Haven High School
Site Plan (14607)



1:1,729











Printed: 28-Nov-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Public Entry - (32.14 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Interview/Office - Type 1 - (12.84 SQM)	Office (3)	
B00A - R0003 - Interview/Office - Type 1 - (12.82 SQM)	Office (3)	
B00A - R0004 - Interview/Office - Type 1 - (12.86 SQM)	Office (3)	
B00A - R0005 - Interview/Office - Type 1 - (12.82 SQM)	Office (3)	
B00A - R0006 - Principal Office - (18.82 SQM)	Office (4)	
B00A - R0007 - Interview/Office - Type 1 - (12.86 SQM)	Office (3)	
B00A - R0008 - Interview/Office - Type 1 - (12.86 SQM)	Office (3)	
B00A - R0010 - Public Entry - (18.88 SQM)	Not Applicable	Circulation or storage space.
B00A - R0011 - Administration - Clerical - (91.69 SQM)	Office (22)	
B00A - R0012 - Interview/Office - Type 1 - (12.78 SQM)	Office (3)	
B00A - R0013 - Clinic - Boys - (13.86 SQM)	Office (3)	
B00A - R0016 - Clinic - Girls - (14.01 SQM)	Office (3)	
B00A - R0017 - Interview/Office - Type 1 - (12.82 SQM)	Office (3)	
B00A - R0021 - Deputy Principal Office - (15.53 SQM)	Office (3)	
B00A - R0022 - Pupil Entry - (46.36 SQM)	Not Applicable	Circulation or storage space.
B00A - R0023 - Interview/Office - Type 1 - (13.66 SQM)	Office (3)	
B00A - R0024 - Duplicating Workroom - (37.6 SQM)	Office (9)	
B00A - R0031 - Movement - (25.77 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - General Learning Space - (58.64 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R1002 - General Learning Space - (59.22 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R1003 - Seminar - (29.21 SQM)	Office (7)	
B00A - R1005 - Seminar - (23.95 SQM)	Office (5)	
B00A - R1007 - Public Entry - (13.5 SQM)	Not Applicable	Circulation or storage space.
B00A - R1008 - Administration - Clerical - (54.34 SQM)	Office (13)	
B00A - R1009 - Administration - Clerical - (109.36 SQM)	Office (27)	
B00B - R0005 - Wood Technology Bay - (35.07 SQM)	Not Applicable	Circulation or storage space.
B00B - R0007 - Materials Technology L.S. - (98.5 SQM) - Teaching Space: 1	Student Space (45)	
B00B - R0008 - Workshop - (68.95 SQM)	Student Space (31)	
B00B - R0011 - Materials Technology L.S. - (97.3 SQM) - Teaching Space: 1	Student Space (45)	
B00B - R0012 - Metal Technology Bay - (35.15 SQM)	Not Applicable	Circulation or storage space.
B00B - R0014 - General Learning Space - (59.85 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0015 - General Assistants - (12.99 SQM)	Office (3)	
B00B - R1001 - Design/Technology L.S. - (81.82 SQM) - Teaching Space: 1	Student Space (37)	
B00B - R1004 - Design/Technology L.S. - (77.46 SQM) - Teaching Space: 1	Student Space (35)	
B00B - R1005 - Design/Technology L.S. - (97.8 SQM) - Teaching Space: 1	Student Space (45)	
B00B - R1006 - Seminar - (14.99 SQM)	Office (3)	
B00B - R1008 - Design/Technology L.S. - (75.18 SQM) - Teaching Space: 1	Student Space (34)	
B00B - R1013 - Food Technology L.S. - (77.12 SQM) - Teaching Space: 1	Student Space (35)	
B00B - R1014 - Food/Research Space - (39.88 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - General Learning Space - (57.67 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0003 - General Learning Space - (59.13 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R0004 - Serviced Learning Space - (59.13 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R0005 - Special Learning Space - (59.13 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R0006 - Movement - (9.44 SQM)	Not Applicable	Circulation or storage space.
B00C - R1001 - General Learning Space - (57.67 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R1003 - General Learning Space - (59.13 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R1004 - General Learning Space - (58.98 SQM) - Teaching Space: 1	Student Space (27)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R1005 - General Learning Space - (58.83 SQM) - Teaching Space: 1	● Student Space (27)	
B00C - R1006 - Study Space - (29.92 SQM)	Not Applicable	Circulation or storage space.
B00D - R0005 - Darkroom Space - (27.91 SQM)	● Office (6)	
B00D - R0008 - Interview/Office - Type 1 - (12.43 SQM)	● Office (3)	
B00D - R0010 - Art Learning Space - (59.21 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R0011 - Workshop - (49.55 SQM)	● Student Space (22)	
B00D - R0013 - Art Learning Space - (58.04 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R1001 - General Learning Space - (62.23 SQM) - Teaching Space: 1	● Student Space (28)	
B00D - R1003 - General Learning Space - (59.14 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R1004 - General Learning Space - (59.21 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R1005 - General Learning Space - (59.06 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R1006 - General Learning Space - (57.52 SQM) - Teaching Space: 1	● Student Space (26)	
B00E - R0004 - Deputy Principal Office - (22.48 SQM)	● Office (5)	
B00E - R0005 - Movement - (24.28 SQM)	Not Applicable	Circulation or storage space.
B00E - R0013 - Commonroom - (153.2 SQM)	● Office (38)	
B00E - R1006 - Staff Study - (268.31 SQM)	● Office (67)	
B00F - R0001 - Laboratory L.S. - (90.04 SQM) - Teaching Space: 1	● Student Space (41)	
B00F - R0002 - Laboratory L.S. - (90.57 SQM) - Teaching Space: 1	● Student Space (42)	
B00F - R0003 - Laboratory L.S. - (90.29 SQM) - Teaching Space: 1	● Student Space (41)	
B00F - R0004 - Laboratory L.S. - (89.77 SQM) - Teaching Space: 1	● Student Space (41)	
B00F - R0007 - Preparation - (56.49 SQM)	Not Applicable	Circulation or storage space.
B00F - R0009 - Movement - (22.52 SQM)	Not Applicable	Circulation or storage space.
B00F - R0010 - Growing/Breeding - (19.14 SQM)	Not Applicable	Circulation or storage space.
B00F - R1001 - Seminar - (16.04 SQM)	● Office (4)	
B00F - R1002 - Seminar - (16 SQM)	● Office (4)	
B00F - R1004 - Staff Study - (328.74 SQM)	● Office (82)	
B00G - R0008 - Practice/Seminar - (27.67 SQM)	Not Applicable	Circulation or storage space.
B00G - R0009 - Music Learning Space - (80.79 SQM) - Teaching Space: 1	● Student Space (37)	
B00G - R1003 - Study Space - (28.4 SQM)	Not Applicable	Circulation or storage space.
B00G - R1004 - General Learning Space - (58.83 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R1005 - General Learning Space - (59.13 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R1006 - General Learning Space - (57.48 SQM) - Teaching Space: 1	● Student Space (26)	
B00J - R0007 - Performance Workspace - (158.44 SQM) - Teaching Space: 1	● Student Space (73)	
B00K - R0010 - Multi-Purpose Space - (764.39 SQM)	● Student Space (354)	
B00K - R0014 - Stage - (103.48 SQM)	Not Applicable	Circulation or storage space.
B00K - R0018 - Movement - (12.99 SQM)	Not Applicable	Circulation or storage space.
B00K - R0019 - Movement - (13.49 SQM)	Not Applicable	Circulation or storage space.
B00K - R1001 - Entry - (71.93 SQM)	Not Applicable	Circulation or storage space.
B00K - R1003 - Student Canteen - (33.85 SQM)	Not Applicable	Circulation or storage space.
B00L - R0001 - Main Area - (350.53 SQM)	Not Applicable	Circulation or storage space.
B00L - R0002 - Seminar - (12.63 SQM)	● Office (3)	
B00L - R0003 - Seminar - (12.6 SQM)	● Office (3)	
B00L - R0005 - Audio Visual Workroom - (25.46 SQM)	● Student Space (11)	
B00L - R0006 - Computer Learning Space - (65.28 SQM) - Teaching Space: 1	● Student Space (30)	
B00L - R0008 - Entry - (28.05 SQM)	Not Applicable	Circulation or storage space.
B00L - R0009 - Seminar - (12.73 SQM)	● Office (3)	
B00L - R0011 - Senior Study - (60.7 SQM)	● Office (15)	
B00L - R0012 - Workroom - (42.76 SQM)	● Office (10)	
B00L - R0013 - Seminar - (12.47 SQM)	● Office (3)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00L - R0014 - Entry - (14.51 SQM)	Not Applicable	Circulation or storage space.
B00L - R9001 - Student Canteen - (48.18 SQM)	Not Applicable	Circulation or storage space.
B00N - R0001 - Practice/Seminar - (96.33 SQM)	Not Applicable	Circulation or storage space.
B00R - R0002 - Staff Kitchen - (15.39 SQM)	 Office (3)	
B00R - R0003 - General Learning Space - (31.59 SQM) - Teaching Space: 1	 Student Space (14)	
B00R - R0004 - General Learning Space - (31.65 SQM) - Teaching Space: 1	 Student Space (14)	
B00R - R0005 - Staff Study - (15.42 SQM)	 Office (3)	
B00R - R0006 - General Learning Space - (31.57 SQM) - Teaching Space: 1	 Student Space (14)	
B00R - R0007 - General Learning Space - (31.7 SQM) - Teaching Space: 1	 Student Space (14)	
B00T - R0002 - Visual Arts Workshop - (26.51 SQM)	 Student Space (12)	
B00T - R0003 - General Learning Space - Type 2 - (111.78 SQM) - Teaching Space: 1	 Student Space (51)	
NS 210 15050 - NS 210 15050 - Home Science/Preparation Area/Laundry - (95 SQM)	 Office (23)	
OS 521 10496 - OS 521 10496 - Staff Study - (76 SQM)	 Office (19)	