

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Campbellfield Public School (4490)</b>
<b>AMU REGION:</b>	<b>South Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Macquarie Fields</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Campbelltown</b>

4490 - Campbellfield Public School  
Site Plan (10137)



1:1,166

Printed: 21-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B001 - R0001 - Duplicating Workroom - (12.56 SQM)	Office (3)	
B001 - R0002 - Sick Bay - (9.46 SQM)	Student Space (4)	
B001 - R0006 - Clerical Office - (13.05 SQM)	Office (3)	
B001 - R0009 - Staff Room - (57.27 SQM)	Office (14)	
B001 - R0010 - Movement - (8.54 SQM)	Not Applicable	Circulation or storage space.
B001 - R0011 - Staff Room Annexe - (12.96 SQM)	Office (3)	
B001 - R0012 - Staff Room Annexe - (12.6 SQM)	Office (3)	
B001 - R0014 - Principal - (20.04 SQM)	Office (5)	
B001 - R0016 - Clerical Office - (11.82 SQM)	Office (2)	
B001 - R0020 - Movement - (12.7 SQM)	Not Applicable	Circulation or storage space.
B001 - R0021 - Movement - (62.95 SQM)	Not Applicable	Circulation or storage space.
B001 - R0022 - Entry Vestibule - (12.66 SQM)	Not Applicable	Circulation or storage space.
B001 - R0023 - Movement - (42.45 SQM)	Not Applicable	Circulation or storage space.
B001 - R1002 - Movement - (9.15 SQM)	Not Applicable	Circulation or storage space.
B001 - R1018 - Reading Area - (280.11 SQM)	Student Space (129)	
B002 - R0007 - Home Base - (68.59 SQM) - Teaching Space: 1	Student Space (31)	
B002 - R0008 - Practical Activities - 1hb - (19.67 SQM)	Student Space (9)	
B002 - R0011 - Withdrawal Space - 1hb - (9.88 SQM)	Student Space (4)	
B002 - R0012 - Movement - (9.69 SQM)	Not Applicable	Circulation or storage space.
B002 - R0013 - Home Base - (59.77 SQM) - Teaching Space: 1	Student Space (27)	
B002 - R0015 - Practical Activities - 1hb - (15.4 SQM)	Student Space (7)	
B002 - R0018 - Practical Activities - 1hb - (15.29 SQM)	Student Space (7)	
B002 - R0019 - Home Base - (59.83 SQM) - Teaching Space: 1	Student Space (27)	
B002 - R0021 - Movement - (144.23 SQM)	Not Applicable	Circulation or storage space.
B002 - R0023 - Movement - (15.37 SQM)	Not Applicable	Circulation or storage space.
B004 - R0007 - Movement - (27.21 SQM)	Not Applicable	Circulation or storage space.
B005 - M0002 - Withdrawal Space - 1hb - (5.06 SQM)	Student Space (2)	
B005 - M0003 - Withdrawal Space - 1hb - (5.02 SQM)	Student Space (2)	
B005 - M0004 - Withdrawal Space - 1hb - (5.02 SQM)	Student Space (2)	
B005 - R0001 - Home Base - (53.45 SQM) - Teaching Space: 1	Student Space (24)	
B005 - R0005 - Home Base - (52.39 SQM) - Teaching Space: 1	Student Space (24)	
B005 - R0006 - Practical Activities - 1hb - (12.42 SQM)	Student Space (5)	
B005 - R0008 - Practical Activities - 1hb - (12.3 SQM)	Student Space (5)	
B005 - R0009 - Practical Activities - 1hb - (19.07 SQM)	Student Space (8)	
B005 - R0011 - Withdrawal Space - 1hb - (6.76 SQM)	Student Space (3)	
B005 - R0012 - Home Base - (57.25 SQM) - Teaching Space: 1	Student Space (26)	
B005 - R0013 - Movement - (16.61 SQM)	Not Applicable	Circulation or storage space.
B005 - R0014 - Interview - (9 SQM)	Office (2)	
B005 - R0015 - Home Base - (52.45 SQM) - Teaching Space: 1	Student Space (24)	
B005 - R0019 - Home Base - (51.53 SQM) - Teaching Space: 1	Student Space (23)	
B005 - R0020 - Practical Activities - 1hb - (12.08 SQM)	Student Space (5)	
B005 - R0022 - Practical Activities - 1hb - (12.08 SQM)	Student Space (5)	
B005 - R0023 - Practical Activities - 1hb - (18.9 SQM)	Student Space (8)	
B005 - R0025 - Withdrawal Space - 1hb - (6.76 SQM)	Student Space (3)	
B005 - R0026 - Home Base - (56.38 SQM) - Teaching Space: 1	Student Space (26)	
B005 - R0028 - Movement - (249.48 SQM)	Not Applicable	Circulation or storage space.
B006 - R0001 - Canteen - (40.82 SQM)	Not Applicable	Circulation or storage space.
B006 - R0006 - Raised Platform - (58.79 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B006 - R0007 - Communal Space - (225.97 SQM)	● Student Space (104)	
B006 - R0014 - Movement - (78.13 SQM)	Not Applicable	Circulation or storage space.
B006 - R0015 - Movement - (130.82 SQM)	Not Applicable	Circulation or storage space.
B007 - M0003 - Withdrawal Space - 1hb - (5.11 SQM)	● Student Space (2)	
B007 - R0003 - Staff Room Annexe - (13.37 SQM)	● Office (3)	
B007 - R0004 - Home Base - (52.93 SQM) - Teaching Space: 1	● Student Space (24)	
B007 - R0006 - Withdrawal Space - 1hb - (10.16 SQM)	● Student Space (4)	
B007 - R0007 - Home Base - (53.03 SQM) - Teaching Space: 1	● Student Space (24)	
B007 - R0009 - Practical Activities - 1hb - (12.3 SQM)	● Student Space (5)	
B007 - R0011 - Practical Activities - 1hb - (12.3 SQM)	● Student Space (5)	
B007 - R0012 - Practical Activities - 1hb - (18.76 SQM)	● Student Space (8)	
B007 - R0014 - Withdrawal Space - 1hb - (6.73 SQM)	● Student Space (3)	
B007 - R0015 - Home Base - (57.62 SQM) - Teaching Space: 1	● Student Space (26)	
B007 - R0016 - Movement - (13 SQM)	Not Applicable	Circulation or storage space.
B007 - R0019 - Home Base - (53.55 SQM) - Teaching Space: 1	● Student Space (24)	
B007 - R0021 - Withdrawal Space - 1hb - (10.53 SQM)	● Student Space (4)	
B007 - R0023 - Home Base - (54.02 SQM) - Teaching Space: 1	● Student Space (25)	
B007 - R0024 - Practical Activities - 1hb - (11.91 SQM)	● Student Space (5)	
B007 - R0026 - Practical Activities - 1hb - (11.86 SQM)	● Student Space (5)	
B007 - R0027 - Practical Activities - 1hb - (19.37 SQM)	● Student Space (8)	
B007 - R0029 - Withdrawal Space - 1hb - (6.92 SQM)	● Student Space (3)	
B007 - R0030 - Home Base - (57.67 SQM) - Teaching Space: 1	● Student Space (26)	
B007 - R0035 - Movement - (287.91 SQM)	Not Applicable	Circulation or storage space.
B008 - M0003 - Withdrawal Space - 1hb - (5.01 SQM)	● Student Space (2)	
B008 - M0004 - Withdrawal Space - 1hb - (5.01 SQM)	● Student Space (2)	
B008 - R0004 - Home Base - (57.57 SQM) - Teaching Space: 1	● Student Space (26)	
B008 - R0005 - Withdrawal Space - 1hb - (6.68 SQM)	● Student Space (3)	
B008 - R0007 - Practical Activities - 1hb - (19.02 SQM)	● Student Space (8)	
B008 - R0008 - Practical Activities - 1hb - (12.19 SQM)	● Student Space (5)	
B008 - R0010 - Practical Activities - 1hb - (12.28 SQM)	● Student Space (5)	
B008 - R0011 - Home Base - (54.12 SQM) - Teaching Space: 1	● Student Space (25)	
B008 - R0013 - Withdrawal Space - 1hb - (10.4 SQM)	● Student Space (4)	
B008 - R0014 - Home Base - (54.35 SQM) - Teaching Space: 1	● Student Space (25)	
B008 - R0016 - Movement - (17.28 SQM)	Not Applicable	Circulation or storage space.
B008 - R0018 - Home Base - (56.76 SQM) - Teaching Space: 1	● Student Space (26)	
B008 - R0019 - Withdrawal Space - 1hb - (6.84 SQM)	● Student Space (3)	
B008 - R0021 - Practical Activities - 1hb - (18.87 SQM)	● Student Space (8)	
B008 - R0023 - Practical Activities - 1hb - (9.79 SQM)	● Student Space (4)	
B008 - R0024 - Home Base - (54.14 SQM) - Teaching Space: 1	● Student Space (25)	
B008 - R0027 - Home Base - (54.16 SQM) - Teaching Space: 1	● Student Space (25)	
B008 - R0028 - Practical Activities - 1hb - (9.81 SQM)	● Student Space (4)	
B008 - R0030 - Withdrawal Space - 1hb - (10.37 SQM)	● Student Space (4)	
B008 - R0031 - Movement - (288.47 SQM)	Not Applicable	Circulation or storage space.